



1 EXISTING BOILER CONTROL WIRING  
 N.T.S.

LOW VOLTAGE CABLING ROUTED TO GUARD HOUSE FOR BOILER ALARM.  
 BOILER POWER DISCONNECT



2 SWITCHBOARD 2  
 N.T.S.



3 REAR SWITCHBOARD 2  
 N.T.S.

**KEYED NOTES:**

- 1 PROPOSED LOCATION OF NEW SWITCHBOARD SECTION. FIELD VERIFY COMPATIBILITY. PREPARE SECTIONS TO ACCEPT MODIFICATIONS PROPOSED. WHERE EXISTING CONDITIONS MANDATE RELOCATION OF NEW SWITCHBOARD SECTION TO NEW LOCATION COORDINATE WITH AE FIRM.

L'Oreal USA Products  
 NLR - BOILER REPLACEMENT  
 11500 Maybelline Rd  
 North Little Rock, AR 72117

Design Phase \_\_\_\_\_  
**CONSTRUCTION DOCUMENTS**

Revisions

No.	Date	Description

Stamp

Notes

- 1. CROMWELL ARCHITECTS ENGINEERS, INC. ALL RIGHTS RESERVED
- 2. THIS SHEET DESIGNED FOR COLOR PRINTING. CRITICAL INFORMATION MAY BE LOST WITH BLACK AND WHITE PRINTING.

Project Number \_\_\_\_\_  
 Issue Date \_\_\_\_\_  
 Sheet Title \_\_\_\_\_

**ELECTRICAL DETAILS**  
 Sheet Number \_\_\_\_\_  
**E-501**