



GENERAL NOTES

- BOLLARDS MUST BE INSTALLED SUCH THAT THE USE OF HYDRANT OUTLETS AND FDC INLETS ARE UNOBSTRUCTED.
- SEE ELECTRICAL DRAWINGS FOR INFORMATION ON SITE LIGHTING.
- PROVIDE THRUST BLOCKS PER DETAIL B3/CU501 AT ALL WATER LINE BENDS.
- UTILITY LINE SIZING BASED ON BUILDING LOADS.
- CONNECTION POINTS TO THE LSRM SITE UTILITIES ARE BASED ON UTILITY PLANS.
- FIREWATER TANK/PUMPHOUSE AND CONNECTED WATER LINE DETAILS PENDING FURTHER INFORMATION AND DIRECTION FROM CLIENT.
- PRESSURIZED SYSTEMS MUST HAVE VALVES INSTALLED NORMALLY CLOSED AT STUB LOCATIONS.

KEYNOTES

- CONSTRUCT WATER MAIN/LATERAL. PIPE BEDDING PER DETAIL A2/CU502
- CONSTRUCT FIRE WATER MAIN/LATERAL. PIPE BEDDING PER DETAIL A2/CU502
- CONSTRUCT ELECTRICAL LINE (SEE ELECTRICAL DRAWINGS)
- CONSTRUCT GAS LATERAL. PIPE BEDDING PER DETAIL A2/CU502
- CONSTRUCT WATER STUB FOR BUILDING CONNECTION, PER DETAIL B4/CU502
- CONSTRUCT FIRE WATER STUB FOR BUILDING CONNECTION, PER DETAIL B4/CU502
- CONSTRUCT GAS STUB PER DETAIL B4/CU502
- CONSTRUCT WATER VALVE PER DETAIL A1 AND A3/CU501
- CONSTRUCT FIRE HYDRANT PER DETAIL A5/CU501
- CONSTRUCT 2" COMPRESSED AIR LINE. PIPE BEDDING PER DETAIL A2/CU502
- FIRE WATER STUB, PLUG WITH AT-GRADE GROUND MARKER PER DETAIL B4/CU502
- WATER STUB, PLUG WITH AT GRADE GROUND MARKER PER DETAIL B4/CU502
- CONSTRUCT POST INDICATOR VALVE PER DETAIL B6/CU502.
- GATE VALVE NORMALLY CLOSED PER DETAIL A1 AND A3/CU501
- CONSTRUCT COMPRESSED AIR STUB FOR BUILDING CONNECTION PER B4/CU502

LEGEND

CA	COMPRESSED AIR
W	DOMESTIC WATER
G	NATURAL GAS
F	FIRE WATER
---	ELECTRICAL
[Symbol]	SITE LIGHTING
[Symbol]	WATER VALVE
[Symbol]	WATER VALVE NC
[Symbol]	FIRE HYDRANT
[Symbol]	AIR RELIEF VALVE
[PIV]	POST INDICATOR VALVE
[X]	ELECTRICAL EASEMENT
ES	ELECTRICAL SECONDARY
W _x	EXISTING WATER
G _x	EXISTING NATURAL GAS
SS _x	EXISTING SANITARY SEWER
E _x	EXISTING ELECTRICAL
C _x	EXISTING COMPRESSED AIR

KEY PLAN

A1

SITE UTILITY PLAN - AREA 2

SCALE 1" = 40'

PLAN NORTH

TRUE N

Site Development
Camden OSD
Camden, Arkansas
Aerjet Rocketdyne

SITE UTILITY PLAN - AREA 2

SHEET NO
CU102

SCALE
AS SHOWN

DATE
07/01/2024

PROJ
D3547405

DWG
CU102.dwg

SHEET
49 of 99

REUSE OF DOCUMENTS

NO.	DATE	REVISION	CHK	APP'D	BY	DATE
B	2024-07-19	100% ISSUED FOR CONSTRUCTION - DEVELOPMENT	DS	TM		
A	2024-07-01	100% ISSUED FOR REVIEW - DEVELOPMENT	DS	TM		

THIS DOCUMENT AND THE IDEAS AND DESIGNS INCORPORATED HEREIN, AS AN INSTRUMENT OF PROFESSIONAL SERVICE, IS THE PROPERTY OF JACOBS AND IS NOT TO BE REPRODUCED, COPIED, OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, WITHOUT THE WRITTEN PERMISSION OF JACOBS.

© Jacobs Solutions 2023. ALL RIGHTS RESERVED.