


4"(TYP.) 2"(TYP.)

4"(TYP.)

2"(TYP.)

C1 ELECTRICAL DUCT BANK



NOTE: PROVIDE SLACK CABLE AT HAND HOLES AND ENTRANCE/EXIT CONDUIT. PROVIDE SCHEDULE 80 PVC CONDUIT BELOW ROADWAYS, PARKING, AND DRIVES

C3 DUCTBANK DETAIL





ARKANSAS REGISTERED PROFESSIONAL ENGINEER * * * No.12803 09-18-2024	

Jaco	ps
1999 Bryan Street Suite 3500 Tel: 214-638-0145	Dallas, TX 75201 Fax: 214-638-0447
Entity: Jacobs Engineering Group Inc. License Type: Engineering	c. License Exp Date: 12/31/2024
	Suite 3500 incering Group In

HEET NO

ALE As indicated
TE 09/18/2024
OJ D3754500

Autodesk Docs://US_D3754500_FED_Aerojet Rocketdyne/D37545N0_CMDN_OSD_Standard Details_ELEC.rvt