


- A. REFER TO SHEET E-001 FOR ABBREVIATIONS, LEGENDS, AND SYMBOLS.
- B. REFER TO STANDARD DETAILS PACKAGE FOR LIGHTING FIXTURE SCHEDULE.
- C. REFER TO SHEET SERIES "EZ" FOR HAZARDOUS LOCATIONS. LIGHTING RELATED SYSTEMS LOCATED IN THOSE AREAS MUST MEET THE IDENTIFIED CLASSIFICATION.
- D. COORDINATE LIGHTING FIXTURES WITH MECHANICAL EQUIPMENT, DUCTS, CABLE TRAY, AND PIPES FOR OPTIMAL LIGHT OUTPUT.
- E. SENSORS ARE SHOWN FOR GENERAL REFERENCE ONLY. COORDINATE SENSOR LOCATIONS AND QUANTITIES WITH MANUFACTURER'S RECOMMENDATIONS FOR PROPER OPERATION OF THE ULTRASONIC TECHNOLOGY OCCUPANCY SENSORS IN ALL RESTROOM.



Jacobs

899 River Street Suite 5500
Tel: 214-638-0145
Dallas, TX 75201
Fax: 214-638-0447

Enry, Jacobs Engineering Group Inc.
License # 176
License Exp Date: 12/31/2024
Joerle Type: Engineering

[illegible]

GMLRS
Camden OSD
Calhoun County, Arkansas
Aerojet Rocketdyne

ELECTRICAL
LIGHTING PLAN
GROUND FLOOR - AREA D

SHEET NO	
EL104	
SCALE	As indicate
DATE	09/18/202
PROJ	D37545C
DWG	CHEN-CSD_SMLPS_IL

0 4' 8' 16' 24'

1/8" = 1'-0"

PLAN NORTH

TRUE N

