



- A. ALL RACEWAY ROUTING AND ELECTRICAL EQUIPMENT ARE DRAWN DIAGRAMMATICALLY; CONTRACTOR RESPONSIBLE FOR FINAL RACEWAY ROUTING, PATH OF UNDERGROUND DUCT/BANK, AND CONDUCTOR SIZING ADHERING TO NEC RECOMMENDED VOLTAGE DROP.
- B. ROUTE COMMUNICATION RACEWAY FOR EMERGENCY POWER DISTRIBUTION SYSTEM IN SEPARATE DUCT/BANK.
- C. RACEWAY ROUTING TO EXTERIOR INSTALLED HVAC AND MOTOR UNITS TO BE UNDERGROUND FROM PANELBOARD TO LOCAL POWER DISCONNECTING MEANS.
- D. RACEWAY ROUTING TO FINAL LOCATION OF X-RAY SYSTEM VAULT TO BE UNDERGROUND.
- E. PROVIDE 1/2" RACEWAY FOR COMMUNICATIONS BETWEEN EACH AUTOMATIC TRANSFER SWITCH AND GENERATOR START CONTROLS.
- F. PROVIDE 1/2" RACEWAY FROM GENERATOR TO GENERATOR REMOTE ANNUNCIATOR IN ELECTRICAL ROOM 112.

