


D5 LADDER RUNWAY SUPPORT

ANGLE IRON WALL SUPPORT



Jacobs

RUNWAY WIDTH AS INDICATED ON DRAWINGS

- #2 BONDING CONDUCTOR

Campus Standard Details Camden OSD Calhoun County, Arkansas Aerojet Rocketdyne

MMUNICATION ETAILS

SHEET NO T-802

D37545N0

EQUIPMENT FRAME ANCHORING


NTS

- CORNER CLAMP BRACKET

- AUXILIARY FRAMING BAR


LADDER RUNWAY END CLOSING KIT

NTS




D2 LADDER RUNWAY BONDING


D3 LADDER RUNWAY DROP OUT




B5 LADDER RUNWAY WALL SUPPORT KIT



B3 LADDER RUNWAY TEE BONDING B2 LADDER RUNWAY FOOT



RACK BONDING BUSBAR (RBB)



A1 LADDER RUNWAY WALL SUPPORT

STAND-OFF BRACKET TO -MAINTAIN BONDING/ COMMUNICATIONS CABLE SEPARATION **EQUIPMENT RACK** VERTICAL MANAGEMENT - RBB, ONE PER RACK

A5 RACK BONDING BUSBAR (RBC)