


1 ENLARGED MECHANICAL PLAN - OVEN AHU'S
1/4" = 1'-0"



NORTH

GENERAL NOTES

- 1 REFER TO SHEET M-001 FOR MECHANICAL NOTES, ABBREVIATIONS, AND LEGEND SYMBOLS.

KEYED NOTES

- 1 CONNECT THE AIR HANDLING UNIT SUPPLY AND RETURN DUCTWORK TO THE OVEN IN STRICT ACCORDANCE WITH THE OVEN MANUFACTURER AND OWNER'S REQUIREMENTS. CONFIRM THESE REQUIREMENTS PRIOR TO BID AND ROUGH-IN.
- 2 INSTALL THE FAN AS HIGH ON THE WALL AS POSSIBLE.
- 3 PIPE SHALL BE FULL SIZE OF STEAM TRAP DISCHARGE PORT.
- 4 CONDENSATE RECEIVER TANK VENT FULL SIZE OF FACTORY CONNECTION TO TANK.

Project

AEROJET BUILDING 66B
CURE OVEN BUILDING
EAST CAMDEN,
ARKANSAS



Design Phase

CONSTRUCTION DOCUMENTS

Revisions

No.	Date	Description

Stamp



07-31-2024

Notes

1. CROMWELL ARCHITECTS ENGINEERS, INC. ALL RIGHTS RESERVED
2. THIS SHEET DESIGNED FOR COLOR PRINTING. CRITICAL INFORMATION MAY BE LOST WITH BLACK AND WHITE PRINTING.

Project Number

2024-045

Issue Date

07-31-2024

Sheet Title

ENLARGED
MECHANICAL PLAN -
OVEN AHU'S

Sheet Number

M-401