



- # KEYED NOTES
1. MOUNT INSULUM UNIT DIRECTLY ABOVE DOOR ON DOOR HEADER. PROVIDE CONTRACTOR FIELD INSTALLED CONDENSATE PUMP. EXTEND CONDENSATE LINE TO NEAREST JACOBI SINK AND/OR LAVATORY TUB. TERMINATE WITH 2" AIR GAP. (TYPICAL). COORDINATE WITH PLUMBING CONTRACTOR FOR LAVATORY TUB/PIPE CONNECTION.
 2. EXTEND FULL SIZE DUCTWORK DUCT UP TO ROOF AND TERMINATE WITH FACTORY ROOF CURB/CAP.
 3. INSTALL AIR CURTAIN DIRECTLY ABOVE ENTRY DOORWAYS. SEE ARCHITECTURAL DETAILS FOR MORE INFORMATION. (TYPICAL)
 4. INSTALL DUCTWORK ELEVATION WITH THE BOTTOM OF DUCTWORK ALIGNED WITH THE LIGHTING.
- # GENERAL NOTES
- A. ALL WORK SHALL COMPLY WITH ALL APPLICABLE FEDERAL, STATE AND LOCAL CODES, LAWS, ACTS, AND THE AUTHORITIES HAVING JURISDICTION.
 - B. THE COMPLETED INSTALLATION SHALL BE IN ACCORDANCE WITH ALL APPLICABLE INDUSTRY STANDARD OF GOOD PRACTICE AND SAFETY, AND THE MANUFACTURER'S SPECIFIC TEST RECOMMENDATIONS FOR EQUIPMENT AND PRODUCT APPLICATION AND INSTALLATION.
 - C. ALL WORK SHALL BE LOCATED TO PROVIDE ADEQUATE CLEARANCE FOR ARCHITECTURAL DESIGN AND PROPER OPERATION AND SERVICE OF EQUIPMENT.
 - D. MATERIALS EXPOSED WITHIN DUCTS OR PLENUM SHALL HAVE A FLAME-SPREAD INDEX OF NOT MORE THAN 25 AND A SMOKE DEVELOPED RATING OF NOT MORE THAN 50 WHEN TESTED IN ACCORDANCE WITH THE TEST FOR SURFACE BURNING. CHARACTERISTICS OF BALANCE AIR SHALL MEET STANDARD B-1. OTHERWISE, ALL MATERIAL SHALL BE PLENUM RATED.
 - E. FIRE SPRINKLERS AND LIGHTS TAKE PRECEDENCE OVER DIFFUSERS. CONTRACTOR TO VERIFY LOCATIONS WITH ARCHITECT.

- # GENERAL NOTES
- A. ALL WORK SHALL COMPLY WITH ALL APPLICABLE FEDERAL, STATE AND LOCAL CODES, LAWS, ACTS, AND THE AUTHORITIES HAVING JURISDICTION.
 - B. THE COMPLETED INSTALLATION SHALL BE IN ACCORDANCE WITH ALL APPLICABLE INDUSTRY STANDARD OF GOOD PRACTICE AND SAFETY, AND THE MANUFACTURER'S STRICTEST RECOMMENDATIONS FOR EQUIPMENT AND PRODUCT APPLICATION AND INSTALLATION.
 - C. ALL WORK SHALL BE LOCATED TO PROVIDE ADEQUATE CLEARANCE FOR ARCHITECTURAL DESIGN AND PROPER OPERATION AND SERVICE OF EQUIPMENT.
 - D. MATERIALS EXPOSED WITHIN DUCTS OR PLENUM SHALL HAVE A FLAME-SPREAD INDEX OF NOT MORE THAN 25 AND A SMOKE DEVELOPED RATING OF NOT MORE THAN 50 WHEN TESTED IN ACCORDANCE WITH THE TEST FOR SURFACE-BURNING CHARACTERISTICS OF BUILDING MATERIAL UL STANDARD 8-1. OTHERWISE, ALL MATERIAL SHALL BE PLENUM RATED.
 - E. FIRE SPRINKLERS AND LIGHTS TAKE PRECEDENCE OVER DIFFUSERS. CONTRACTOR TO VERIFY LOCATIONS WITH ARCHITECT.