

RFI detail

#298 BBHs 43-46 CONFLICT WITH PIPE AND MULLION



Status	Closed
Created on	Feb 28, 2024 by Brady Gaudette (Crossland Construction Company)
RFI type	Default RFI workflow
Ball in court	Brady Gaudette (Crossland Construction Company)
Answered	Mar 14, 2024 by Anne Worley (Polk Stanley Wilcox Architects)

Question

There is not a way to move BBHs 43 to 46 without clashing with the steel beam. The piping for BBHs 43 to 46 would need to move 10"-12" off of the wall. Please see attached and advise.

Official response

Anne Worley (Polk Stanley Wilcox Architects): Remove BBH 44-46. Ductwork from VAV 4-07 shall be modified in upcoming PR to deliver air from above ceiling at exterior wall.

J. Nelson | HEI

By **Anne Worley** (Polk Stanley Wilcox Architects) - Mar 14, 2024, 1:41 PM CDT

References

Files (2)

- [AWSOM RFI \(BBH 43-46 conflicts\).pdf](#)
- [#298 - BBHs 43-46 CONFLICT WITH PIPE AND MULLION-202402282014_HEI.pdf](#)

Impact

Cost impact -

Schedule impact -

Other attributes

Priority	Normal
Discipline	-
Category	-
Location	-
Location details	-
External id	-
Co-reviewer(s)	

Activities	By	At
<p>Brady Gaudette changed the status from ■ Open Answered to ■ Closed</p> <p>Official response: Anne Worley (Polk Stanley Wilcox Architects): Remove BBH 44-46. Ductwork from VAV 4-07 shall be modified in upcoming PR to deliver air from above ceiling at exterior wall.</p> <p>J. Nelson HEI</p>	Brady Gaudette	Mar 14, 2024, 1:41 PM CDT
<p>Anne Worley changed the status from ■ Open In Review to ■ Open Answered set Ball in court to Brady Gaudette (Crossland Construction Company).</p>	Anne Worley	Mar 14, 2024, 1:20 PM CDT
<p>Anne Worley added a response: Remove BBH 44-46. Ductwork from VAV 4-07 shall be modified in upcoming PR to deliver air from above ceiling at exterior wall. J. Nelson HEI</p>	Anne Worley	Mar 14, 2024, 1:20 PM CDT
<p>Anne Worley added a reference to a file #298 - BBHs 43-46 CONFLICT WITH PIPE AND MULLION-202402282014_HEI.pdf</p>	Anne Worley	Mar 14, 2024, 1:20 PM CDT
<p>Brady Gaudette changed the status from ■ Draft to ■ Open In Review set Ball in court to Anne Worley (Polk Stanley Wilcox Architects).</p>	Brady Gaudette	Feb 28, 2024, 2:11 PM CST
<p>Brady Gaudette added a reference to a file AWSOM RFI (BBH 43-46 conflicts).pdf</p>	Brady Gaudette	Feb 28, 2024, 1:30 PM CST
<p>Brady Gaudette (Crossland Construction Company) created this RFI in ■ Closed status and set Ball in court to Brady Gaudette (Crossland Construction Company).</p>	Brady Gaudette	Feb 28, 2024, 1:30 PM CST