



AIA[®] Document G709[™] – 2018

Proposal Request

PROJECT: *(name and address)*

AWSOM

Bentonville, Arkansas

CONTRACT INFORMATION:

Contract For:

General Construction

Date:

11-29-2021

Architect's Project Number: 993A

Proposal Request Number: 125

Proposal Request Date: 04-21-2025

OWNER: *(name and address)*

AWSOM Lands, LLC

PO Box 2030

Bentonville, AR 72712

ARCHITECT: *(name and address)*

Polk Stanley Wilcox Architects

509 W Spring St., Suite 150

Fayetteville, AR 72701

CONTRACTOR: *(name and address)*

Crossland Construction Company

1800 S. 52nd Street, Suite 410

Rogers, AR 72758

The Owner requests an itemized proposal for changes to the Contract Sum and Contract Time for proposed modifications to the Contract Documents described herein. The Contractor shall submit this proposal within Five (5) days or notify the Architect in writing of the anticipated date of submission.

(Insert a detailed description of the proposed modifications to the Contract Documents and, if applicable, attach or reference specific exhibits.)

Refer to the attached Proposal Request 125 Narrative listing revised drawings with brief description of changes.

THIS IS NOT A CHANGE ORDER, A CONSTRUCTION CHANGE DIRECTIVE, OR A DIRECTION TO PROCEED WITH THE WORK DESCRIBED IN THE PROPOSED MODIFICATIONS.

REQUESTED BY THE ARCHITECT

ARCHITECT *(Signature)*

BY: Mark Herrmann, AIA

(Printed name, title, and license number if required)

PROPOSAL REQUEST 125

Dean's Suite Reception

ISSUED: April 21, 2024

PROJECT: AWSOM
BENTONVILLE, AR

FROM ARCHITECT: POLK STANLEY WILCOX ARCHITECTS
801 SOUTH SPRING ST.
LITTLE ROCK AR 72201

TO CONTRACTOR: CROSSLAND CONSTRUCTION COMPANY, INC

PROPOSAL REQUEST 125 BRIEF

Revised drawings in PR 125 update the electrical and data scope at Dean's Suite Reception.

REVISED DRAWING SHEETS AND SPECIFICATIONS

- 1) **ELECTRICAL**
 - a) Revised Sheet **E204A**, Detail 1, with original issue date 02.24.2023 and revised date 04.18.2025
 - Add double duplex receptacle for TV display in Office Reception 4144. Circuit to receptacle for TV display in office 4142.
- 2) **TECHNOLOGY**
 - a) Revised Sheet **TN104A**, Detail 1, with original issue date 02.24.2023 and revised date 04.18.2025
 - Office Recept 4144 – Add 2D Data for TV display location.
 - L4 Corr C41.6 – Add 2D on North wall adjacent to receptacle.

End of PR 125



GENERAL NOTE:
1. IN COMPLIANCE WITH IRC: PENETRATIONS INTO OR THROUGH INTERIOR EXISTING STAIRWAYS ARE PROHIBITED EXCEPT AS ALLOWED IN 2021 IRC SECTION 1023.5
2. ADDITIONAL ESN CONTROL MODULES ARE REQUIRED FOR CONTROLLED RECEPTACLES. COORDINATE WITH LUTRON TO PROVIDE ALL ESN CONTROL MODULES FOR CONTROLLED RECEPTACLES. LOCATE ESN MODULES FOR CONTROLLED RECEPTACLES IN LOCATIONS SIMILAR TO LIGHTING CONTROL ESN MODULES AND INTEGRATE INTO LUTRON CONTROLS SYSTEM.

ELECTRICAL PLAN NOTES:
E1 INSTALL INDIVIDUAL GFCI-FEED THRU DEVICE TO PROTECT EACH NON-GFI RECEPTACLE AT COUNTER. INSTALL GFCI PROTECTIVE DEVICE AT LOCATION SHOWN ACCESSIBLE FOR RESET.
E23 MECHANICAL THERMOSTAT LOCATION. PROVIDE JUNCTION BOX AND 1/2" CONDUIT TO ABOVE CEILING FOR CONTROL WIRING.
E37 INSTALL RECEPTACLES ACCESSIBLE BELOW COUNTER ON CASEWORK AT CHAIR KNEE SPACE.
E42 INSTALL GFCI FEED-THRU DEVICE ON WALL 12-INCHES BELOW CEILING.
E44 INSTALL JUNCTION BOX FOR LUTRON ROLLER SHADE CONTROL PANEL. LOCATE PANEL ABOVE ACCESSIBLE CEILING LOCATION AND OUT OF PUBLIC VIEW.
E45 INSTALL JUNCTION BOX ABOVE ACCESSIBLE CEILING FOR FUTURE LUTRON ROLLER SHADE CONTROL PANEL.


REVISIONS		
NUMBER	DATE	DESCRIPTION
1	03.10.23	ADDENDUM 1
2	06.09.23	ADDENDUM 2
3	11.11.23	PROVIDE
4	08.29.24	PROVIDE
5	04.18.2025	PROVIDE


POWER - LEVEL 4 PLAN - AREA A
1/8" = 1'-0"

KEY PLAN



NOTE: REFER TO SECURITY AND
TELECOM DRAWINGS FOR ALL DOOR
SECURITY AND DATA DEVICE
LOCATIONS.





TECHNOLOGY PLAN NOTES:
T41 PROVIDE DATA CONNECTION FOR AREA OF REFUGE 2-WAY COMMUNICATION SYSTEM.

801 South Spring Street
Little Rock, AR 72201
501.378.0878 office
509 W. Spring St. Suite 150
Fayetteville, AR 72701
479.444.0073 office
polkstanleywilcox.com

CIVIL
McClelland Consulting Engineers, Inc.
1380 E STEARNS ST
FAVETTEVILLE, AR 72703
P: 479.443.2377

LANDSCAPE
OSD
115 ST. JOHNS PLACE
BROOKLYN, NY 11217
P: 917.553.5588

STRUCTURAL
MartinMartin Consulting Engineers
8008 SOUTHWALK TOWN & VILLAGE, SUITE 27
BENTONVILLE, AR 72712
P: 479.481.0942

MEPP - LOW VOLTAGE
Henderson Engineers
8340 LENEXA DRIVE, STE 300
LENEXA, KS 66214
P: 913.860.8195

SUSTAINABILITY
SOM
224 SOUTH MICHIGAN AVENUE
CHICAGO, IL 60604
P: 312.360.4121

SIGNAGE - WAYFINDING
TWO TWELVE
238 W. 27th ST., SUITE 802
NEW YORK, NY 10001
P: 212.294.6670

FOOD SERVICE
JMC HOSPITALITY
888 SIX PINES DR., SUITE 8210
THE WOODLANDS, TX 77380
P: 800.641.2222

WATER FEATURES
OTL
2150 S. TOWNE CENTER, SUITE 100
ANAHAIM, CA 92806
P: 714.637.4747

IRRIGATION
WC3 DESIGN
11A ROBINSON MANOR BLVD.
WICKESBURG, PA 14136
P: 844.231.7042

PSW Job Number:
993A

Henderson Job Number:
2150002607




AWSOM
Bentonville, AR

Issue Date:
02.24.2023

REVISIONS		
NUMBER	DATE	DESCRIPTION
1	03.10.23	Issued
2	06.09.23	Addendum 2
3	08.23.24	PROVIDE
4	10.07.24	PROVIDE
5	04.18.2025	PROVIDE

Contents:
TECHNOLOGY -
LEVEL 4 PLAN -
AREA A

KEY PLAN



THIS PAGE IS BEST
VIEWED IN COLOR

TN104A