



- 1 SEE EXTERIOR LIGHTING DETAIL FOR LIGHTING POWER AND CONTROL. LIGHTING SHALL ENERGIZE WITH PHOTOCELL/TIME CLOCK FOR DUSK TO DAWN OPERATION. COORDINATE REQUIREMENTS WITH LIGHTING CONTROL SYSTEM.
- 2 MINIMUM 1/2" CONDUIT BELOW GRADE AND ROUTED BACK TO BUILDING.
- 3 VERIFY LOCATION OF THE GENERATOR SET AND TRANSFER SWITCH WITH THE ARCHITECT AND OWNER PRIOR TO CONSTRUCTION. THE CONTRACTOR SHALL INSTALL THE GENERATOR SET ON A 4" THICK REINFORCED CONCRETE PAD. ALL EXTERIOR CONDUIT ROUTED TO AND FROM THE GENERATOR SHALL BE WATER TIGHT.
- 4 GENERATOR SHALL BE CLASSIFIED AS A TYPE 1 CLASS X LEVEL 1 CAPABLE OF SWITCHING LOADS WITHIN 10 SECONDS OF NORMAL POWER FAILURE.



KEY ARCHITECTURE INC.

P.O. BOX 748 FAYETTEVILLE, ARKANSAS 72702
PH: 479.444.6066 FAX: 479.444.1445

FOR PERMIT &
CONSTRUCTION

[illegible]

NEW ARCADE MEDICAL OFFICE BUILDING
2709 Massard Rd
FT. SMITH, AR 72903

ARcare
117 S. 2ND ST.
AUGUSTA, AR 72006

DATE	DRAWN BY
06-15-2026	CH
PROJECT #	CHECKED BY
2517	JT

SHEET
E100
ELECTRICAL SITE PLAN

These Drawings and Specifications are the exclusive property of Key Architecture Inc. and are protected by Copyright. Use or reproduction is prohibited without written consents.



310 W. MAIN ST. SUITE C
RUSSELLVILLE, AR 72801
PHONE (479) 595-8777

WWW.TERRELENG.COM

AR FIRM # 3434