

PLUMBING FIXTURE SCHEDULE									
MARK	DESCRIPTION	MANUF.	MODEL	MOUNTING	PIPING			SPECIFICATION	NOTES
					CW	HW	WASTE		
B-1	ICE MAKER OUTLET BOX	OATEY	38688	WALL	1/2"			WALL MOUNTED, 20 GA. STEEL BOX, 28 GA. STEEL FACE PLATE, 1/4 TURN BRASS BALL VALVE, INTEGRAL WATER HAMMER ARRESTOR.	-
EWG-1A	ADA COMPLIANT ELECTRIC WATER COOLER	OASIS	PG8AC	WALL	1/2"		2"	BRUSHED STAINLESS STEEL, MANUAL OPERATION, MCGUIRE 8872 TRAP, MCGUIRE LFHST07 ANGLE STOP, AND WADE 403 WALL CARRIER.	1,4
FCO-1	FLOOR CLEANOUT	WADE	6000	FLOOR			---	SIZE TO MATCH WASTE LINE. COATED CAST IRON BODY, 6" ROUND NICKEL BRONZE TOP.	-
FD-1	FLOOR DRAIN	WADE	1100-A	FLOOR			2"	COATED CAST IRON BODY, 6" ROUND NICKEL BRONZE TOP. DEEP SEAL P-TRAP, GREEN DRAIN GD TRAP SEAL.	5
GCO-1	GRADE CLEANOUT	WADE	6000-Z	GRADE			---	SIZE TO MATCH WASTE LINE. COATED CAST IRON BODY, 6" ROUND DUCTILE IRON HEAVY DUTY TOP.	-
H-1	FREEZELESS WALL HYDRANT	WOODFORD	67	WALL	3/4"			BRASS VALVE BODY. CHROME FINISH. LOOSE KEY OPERATION.	-
L-1A	ADA COMPLIANT LAVATORY	KOHLER	K-2084	WALL	1/2"	1/2"	2"	20" x 18", WHITE VITREOUS CHINA. CONTACTLESS OPERATION. KOHLER K-7514 BATTERY POWERED SENSOR FAUCET. MCGUIRE 8872 TRAP, MCGUIRE LFH175 ANGLE STOPS AND RISERS, MCGUIRE HD155A GRID DRAIN. WADE 520 WALL CARRIER, TRUBRO LAVGUARD2 INSULATED DRAIN AND SUPPLY COVERS.	1,2,4
L-2A	ADA COMPLIANT LAVATORY	KOHLER	K-2196-4	COUNTER	1/2"	1/2"	2"	20" x 18", WHITE VITREOUS CHINA. CONTACTLESS OPERATION. KOHLER K-7514 BATTERY POWERED SENSOR FAUCET. MCGUIRE 8872 TRAP, MCGUIRE LFH175 ANGLE STOPS AND RISERS, MCGUIRE HD155A GRID DRAIN. TRUBRO LAVGUARD2 INSULATED DRAIN AND SUPPLY COVERS.	1-3
S-1	SINGLE COMPARTMENT SINK	ELKAY	LR2022	COUNTER	1/2"	1/2"	2"	19.5" x 22" x 7.5", SINGLE COMPARTMENT, STAINLESS STEEL. CENTER DRAIN LOCATION. GOOSE NECK FAUCET WITH LEVER HANDLES. DRAIN WITH STRAINER, ANGLE STOPS, AND SUPPLY RISERS.	2,3
S-2	DOUBLE COMPARTMENT SINK	ELKAY	CR3321	COUNTER	1/2"	1/2"	2"	33" x 21" x 7". DOUBLE COMPARTMENT, STAINLESS STEEL. CENTER DRAIN LOCATIONS. GOOSE NECK FAUCET WITH LEVER HANDLES, DRAINS WITH STRAINERS, ANGLE STOPS, AND SUPPLY RISERS.	2,3
SS-1	SERVICE SINK	FIAT	MSB2424	FLOOR	1/2"	1/2"	3"	24" x 24" x 10". MOLDED STONE. MANUAL OPERATION, FIAT 8304A FAUCET, FIAT 889CC MOP HANGER, FIAT8322A HOSE AND HOSE BRACKET, FIAT MSG STAINLESS STEEL WALL GUARDS.	6
T-1	TOILET	KOHLER	K-96053	FLOOR	1"		3"	WHITE VITREOUS CHINA. CONTACTLESS OPERATION. TOP SPUD, KOHLER K-10956-SV BATTERY POWERED SENSOR FLUSH VALVE. INTEGRAL TRAP. KOHLER K-4731-GC SEAT.	-
T-1A	ADA COMPLIANT TOILET	KOHLER	K-96057-B	FLOOR	1"		3"	WHITE VITREOUS CHINA. CONTACTLESS OPERATION. TOP SPUD, KOHLER K-10956-SV BATTERY POWERED SENSOR FLUSH VALVE. INTEGRAL TRAP. KOHLER K-4731-GC SEAT.	1
U-1A	ADA COMPLIANT URINAL	KOHLER	K-4991-ET	WALL	3/4"		2"	WHITE VITREOUS CHINA. CONTACTLESS OPERATION. TOP SPUD, KOHLER K-10UD00G20 BATTERY POWERED SENSOR FLUSH VALVE. INTEGRAL TRAP. WADE 402 WALL CARRIER.	1,4
WCO-1	WALL CLEANOUT	WADE	8590	WALL				SIZE TO MATCH WASTE LINE. ABS PLASTIC. WADE 8304 6" STAINLESS STEEL CLEANOUT COVER.	-

- PLUMBING FIXTURE SCHEDULE NOTES:**
1. FIXTURE SHALL CONFORM TO THE AMERICANS WITH DISABILITIES ACT AND ANSI A117.1, LATEST ADOPTED EDITION.
 2. PROVIDE THERMOSTATIC MIXING VALVE (TMV), THE OUTPUT OF THE TMV SHALL BE SET TO 110°F.
 3. COORDINATE INSTALLATION WITH MILLWORK.
 4. PROVIDE WALL CARRIERS.
 5. PROVIDE UL LISTED AND APPROVED TRAP GUARD OR TRAP PRIMER DEVICE.
 6. CONTINUOUS SEALANT AROUND BASIN AT WALL AND FLOOR. IF LEVELING IS REQUIRED, USE NON-SHRINK GROUT.

TANKLESS GAS WATER HEATER SCHEDULE									
MARK	MANUF.	MODEL	HEATING		UEF	ELECTRICAL			NOTES
			INPUT	OUTPUT		VOLTAGE	PHASE	WATTAGE	
WH-1	NAVLEN	NPE-240A2	199,000 Btu/h	189,000 Btu/h	0.95	120 V	1	200 W	1-6
WH-2	NAVLEN	NPE-240A2	199,000 Btu/h	189,000 Btu/h	0.95	120 V	1	200 W	1-6

- TANKLESS GAS WATER HEATER SCHEDULE NOTES:**
1. PROVIDE VACUUM RELIEF VALVE AND APPROVED TEMPERATURE AND PRESSURE (T&P) RELIEF VALVE TO DISCHARGE IN ACCORDANCE WITH APPLICABLE CODES AND LOCAL ORDINANCES.
 2. PROVIDE ASME APPROVED EXPANSION TANK (AMTROL OR APPROVED EQUAL), SIZE PER MANUFACTURER RECOMMENDATIONS.
 3. ROUTE CONDENSATE PIPING TO OUTSIDE OF BUILDING, SUMP PIT, OR TO STORM DRAIN. COORDINATE CONDENSATE PIPING TERMINATION AT EXTERIOR OF BUILDING WITH ARCHITECT.
 4. INTEGRAL RECIRCULATION PUMP.
 5. DUAL STAINLESS STEEL HEAT EXCHANGERS.
 6. COMFORTFLOW INTERNAL BUFFER.



310 W. MAIN ST. SUITE C
RUSSELLVILLE, AR 72801
PHONE (479) 595-8177

WWW.TERRELLENG.COM

AR FIRM # 3434



KEY ARCHITECTURE INC.

P.O. BOX 748 FAYETTEVILLE, ARKANSAS 72702
PH: 479.444.6066 FAX: 479.444.1445

FOR PERMIT & CONSTRUCTION

Revision Schedule

Rev. #	Date	Description
--------	------	-------------

NEW Arcare MEDICAL OFFICE BUILDING

2709 Massard Rd
FT. SMITH, AR 72903

Arcare

117 S. 2ND ST.
AUGUSTA, AR 72006

DATE	DRAWN BY
06-15-2026	CO
PROJECT #	CHECKED BY
2517	JT

SHEET

P601

PLUMBING SCHEDULES

These Drawings and Specifications are the exclusive property of Key Architecture Inc. and are protected by Copyright. Use or reproduction is prohibited without written consents.