


ELECTRICAL SCHEDULE													
ITEM NUMBER	QTY	DESCRIPTION	VOLTS	PHASE	AMPS	MCA	HP	KW	CONN PLUG	HEIGHT A.F.F.	CONN TYPE	REMARKS	
2.2	2	LED LIGHT	120 V	1							J-BOX	NEW LED LIGHT BY E.C. SEE ELECTRICAL DRAWINGS FOR SCOPE OF WORK.	
3.2	1	LED LIGHT	120 V	1							J-BOX	NEW LED LIGHT BY E.C. SEE ELECTRICAL DRAWINGS FOR SCOPE OF WORK.	
8	1	ICE MAKER, CUBE STYLE	208 V	1	13.20 A					60"	J-BOX	3-WIRE WITH NEUTRAL	
8.1	1	REMOTE CONDENSER SERIES	115 V	1	2.60 A					124"	J-BOX	E.C. TO STUB-UP AS REQUIRED, SEE NOTE W2.	
21	1	WAREWASHER, SINGLE TANK RACK CONVEYOR	208 V	1	82.40 A	125 A	2.25	15.0 kW		70"	J-BOX	BY OTHERS; E.C. TO VERIFY ELECTRICAL REQUIREMENTS AND COORDINATE DISCONNECT LOCATION	
22	1	EXHAUST HOOD	120 V	1	6.00 A					70"	J-BOX	BY OTHERS; E.C. TO VERIFY ELECTRICAL REQUIREMENTS	
31	2	INDUCTION RANGE, COUNTERTOP	120 V	1	15.00 A			1.8 kW	NEMA 5-15P	48"	DR		
31.1	1	EGG MACHINE	120 V	1	10.00 A			1.2 kW		48"	J-BOX	BY OTHERS; E.C. TO VERIFY ELECTRICAL REQUIREMENTS	
32	1	EXHAUST HOOD	120 V	1	6.00 A					78"	J-BOX	BY OTHERS; E.C. TO VERIFY ELECTRICAL REQUIREMENTS	
33A	1	COMBI-OVEN STEAMER	120 V	1	7.50 A					48"	J-BOX	SEE NOTE F3	
33B	1	COMBI-OVEN STEAMER	120 V	1	7.50 A					24"	J-BOX	SEE NOTE F3	
34	1	REFRIGERATED BASE	120 V	1	1.70 A		1/6		NEMA 5-15P	14"	DR	SEE NOTE F1	
39	2	REFRIGERATED PREP TABLE	120 V	1	2.00 A		1/10		NEMA 5-15P	14"	DR	SEE NOTE F1	
41	1	REFRIGERATOR, REACH-IN	120 V	1	3.00 A		1/4		NEMA 5-15P	14"	DR		
44	1	REFRIGERATED PREP TABLE	120 V	1	4.50 A		1/2		NEMA 5-15P	14"	DR		
46	1	DRAWER WARMER	120 V	1	7.50 A			0.9 kW	NEMA 5-15P	14"	DR		
47	1	THREE WELL HOT HOLDING UNIT	208 V	1	10.00 A		-	1.8 kW	NEMA 6-15P	14"	SR		
49	2	REFRIGERATED PREP TABLE	120 V	1	5.40 A		1/3		NEMA 5-15P	14"	DR		
52	1	MICROWAVE OVEN	208 V	1	14.40 A				NEMA 6-20	56"	SR		
57	1	SLICER, ELECTRIC	120 V	1	3.00 A				NEMA 5-15P	48"	DR		
59	1	20 QUART MIXER	115 V	1	10.00 A		1/2	1.2 kW	NEMA 5-15P	48"	DR		
65	2	BEVERAGE/SODA DISPENSER	120 V	1	7.80 A		1/3		NEMA 5-15P	48"	DR	BY OTHERS; E.C. TO VERIFY ELECTRICAL REQUIREMENTS	
66	2	SYRUP WARMER/DISPENSER	120 V	1	2.90 A			0.3 kW	NEMA 5-15P	48"	DR		
71	1	REFRIGERATED PREP TABLE	120 V	1	5.40 A		1/3		NEMA 5-15P	14"	DR		
73	2	MICROWAVE OVEN	208 V	1	13.60 A				NEMA 6-15P	14"	SR		
75	1	REFRIGERATOR, UNDERCOUNTER	120 V	1	2.00 A		1/10		NEMA 5-15P	48"	DR		
77	3	POP-UP TOASTER	120 V	1	15.00 A			1.8 kW	NEMA 5-15P	48"	DR		
78	1	CONVEYOR TOASTER	208 V	1	23.10 A			4.8 kW	NEMA 6-30P	48"	SR		
80	1	COFFEE GRINDER	120 V	1	8.00 A				NEMA 5-15P	48"	DR	BY OTHERS; E.C. TO VERIFY ELECTRICAL REQUIREMENTS	
81	1	TEA BREWER	120 V	1	13.80 A					48"	DR	BY OTHERS; E.C. TO VERIFY ELECTRICAL REQUIREMENTS	
82	1	COFFEE MAKER, AUTOMATIC	220 V	1	34.00 A					48"	SR	BY OTHERS; E.C. TO VERIFY ELECTRICAL REQUIREMENTS	
85	1	PULPER	120 V	1	15.00 A					42"	DR	BY OTHERS; E.C. TO VERIFY ELECTRICAL REQUIREMENTS	
86	1	JUICER	120 V	1	15.00 A					42"	DR	BY OTHERS; E.C. TO VERIFY ELECTRICAL REQUIREMENTS	
87	1	FROZEN DRINK MACHINE	120 V	1	15.00 A		0.6		NEMA 5-15P	42"	DR	BY OTHERS; E.C. TO VERIFY ELECTRICAL REQUIREMENTS	
88	1	BACK BAR COOLER	120 V	1	7.00 A		1/4		NEMA 5-15P	14"	DR		
88.1	1	BEER DISPENSER	120 V	1	1.40 A		1/10		NEMA 5-15P	14"	DR		
92	1	ESPRESSO MACHINE	208 V	1	30.00 A				NEMA L60-30P	42"	SR	BY OTHERS; E.C. TO VERIFY ELECTRICAL REQUIREMENTS	
98	1	GLASS WASHER	120 V	1	16.00 A					14"	J-BOX	BY OTHERS; E.C. TO VERIFY ELECTRICAL REQUIREMENTS	
100	1	BAG-N-BOX	120 V	1	20.00 A				NEMA 5-20P	12"	CORD & PLUG	BY OTHERS; E.C. TO VERIFY ELECTRICAL REQUIREMENTS	



THIS DRAWING IS THE PROPERTY OF FORD HOTEL SUPPLY COMPANY AND IS NOT TO BE USED IN WHOLE OR IN PART WITHOUT THE WRITTEN PERMISSION OF FORD HOTEL SUPPLY.

THIS PLAN IS MADE FROM AVAILABLE INFORMATION. MEASUREMENTS MUST BE VERIFIED ON THE JOB. PLUMBING, ELECTRICAL, REFRIGERATION AND VENT OUTLETS HAVE BEEN LOCATED AS ACCURATELY AS POSSIBLE. WE ACCEPT NO RESPONSIBILITY FOR ERRORS IN MEASUREMENTS, OR DIMENSIONS, OR FOR WORK DONE BY CONTRACTORS AND WILL NOT STAND ANY EXPENSE FOR CHANGES MADE NECESSARY BY LOCAL BUILDING CODES, OR ORDINANCES, OR BY CHANGES AND SUBSTITUTIONS IN EQUIPMENT SHOWN ON THIS PLAN.

REVISIONS			
	ISSUED FOR PERMIT		4.20.2026

Ford Equipment and Contracting Co.

2204 N. BROADWAY
ST. LOUIS, MO 63102
PH: (314) 231-8400
FAX: (314) 231-8426

FOR REFERENCE ONLY



SHEET TITLE
ELECTRICAL ROUGH-IN
SCHEDULE

HOMEGROWN -
FAYETTEVILLE, AR

DATE:
4.20.2026
DRAWN BY:
SES
SCALE:

DRAWING NO.

FS-2.1