

KEYNOTES:

1

INCOMING DOMESTIC WATER SERVICE, REFER TO CIVIL ENGINEERING PLAN FOR LOCATION. ANTICIPATED PEAK DEMAND: 64 GPM

2

DOMESTIC WATER SERVICE UP THRU SLAB WITH MAIN ENGINEERING PLAN FOR LOCATION. ANTICIPATED PEAK DEMAND: 64 GPM

3

GAS SERVICE AND METER PER GAS UTILITY COMPANY REGULATE TO 7 W.C. FIRMING SIZED FOR MAXIMUM 0.5" W.C. PRESSURE DROP PER 20' OF GAS PIPING. ANTICIPATED DEMAND: 698 MBH @ 175

PRIGMENGINEERING

104 N EAST AVENUE
FAYETTEVILLE, AR 72701
479.877.3188 | WWW.PRIGM.COM
#25078

CERTIFICATE OF AUTHORIZATION

PRIGMENGINEERING, PLLC
No. 3588
ARKANSAS

1 SUPPLY ENLARGED PLAN
1/4" = 1'-0"

STATE OF ARKANSAS
LICENSED PROFESSIONAL ENGINEER
No. 14788
PATRICK MOORE

05/08/2026

DEMXXARCHITECTURE

104 N EAST AVENUE
FAYETTEVILLE, ARKANSAS 72701 | 479.966.4871

© 2025 DEMXX ARCHITECTURE

1

SUPPLY ENLARGED PLANS

P4.0

BID SET
05/08/2026 25078