

## SECTION 10 44 00

### FIRE EXTINGUISHERS & CABINETS

#### PART 1 GENERAL

##### 1.1 SUMMARY

- A. Work under this heading consists of furnishing all labor, materials, equipment and services necessary to install fire extinguisher and cabinets as shown or called out on drawings.

##### 1.2 SUBMITTALS

- A. Comply with requirements of Section 01 33 00.

#### PART 2 PRODUCTS

##### 2.1 MATERIALS

- A. Furnish where called for on drawings, semi-recessed, enameled steel case with "Larsen-Loc" door latching mechanism, solid door, with red fire handle plate, Larsen 2409-6R, J.L. Industries 1017, or approved alternate. Where fire rated cabinets are called for, provide FS-2409-6R by Larsen, J.L. Industries, or approved equal. Verify semi-recessed cabinet will fit in provided wall thickness. Break-glass doors will be acceptable only if approved company has no equal to "Larsen-Loc".
- B. Furnish multi-purpose dry chemical extinguisher, Larsen MP10, J.L. Industries Cosmic 10E, or approved equal in each fire extinguisher cabinet.
- C. Provide extinguishers with wall mounted brackets where called for on drawings.

#### PART 3 EXECUTION

##### 3.1 INSTALLATION:

- A. Accurately locate all items, install level, plumb, and true. See Plans for required locations. Rigidly attach to the supporting surfaces in the manner recommended by the manufacturer. Install cabinet as required to provide 48" from finished floor to extinguisher handle.

END OF SECTION

10 44 00-1