

**SC JOHNSON AR - STE 300
RENOVATION**

903 N. 47TH ST. STE 300
ROGERS, AR 72756



01/07/2026

DELTA	ISSUE	DESCRIPTION	DATE
-------	-------	-------------	------



NEW YORK
100 BROADWAY 12th FLOOR
NEW YORK CITY, NY 10005
TEL 212-682-6909

©2025 INTERIOR ARCHITECTS, P.C., A NEW YORK PROFESSIONAL SERVICES CORPORATION.
ALL DRAWINGS AND WRITTEN MATERIALS HEREIN CONSTITUTE THE ORIGINAL AND UNPUBLISHED WORK
OF THE ARCHITECT, AND THE SAME MAY NOT BE REPRODUCED, USED, OR DISCLOSED WITHOUT THE
WRITTEN CONSENT OF THE ARCHITECT.

Owner Approval
05SCJIS.0037.000
Job No. Scale

**ELECTRICAL SCHEDULES
E3.1**

HSA Engineering
501 / 327 / 5757 office
515 Locust Avenue
Conway, Arkansas 72034
HSAConsultants.com

Panel Name: H3A																			
Amp Rating: 225 A																			
Mains: MLC																			
MGB Rating: 1 A																			
Volts/Phase/Wire 120/208 Wye / 3 / 4																			
Manufacturer: EXISTING																			
Panel Type: EXISTING																			
Mounting: SURFACE																			
Remarks: EXISTING																			
Fault Rating: EXISTING																			
Fed From: ELECTRICAL ROOM 3006																			
Location: ELECTRICAL ROOM 3006																			
Circuit Description	COND. SIZE	WIRE SIZE	GRD. SIZE	# OF Wires	Poles	TRIP	CKT	A	B	C	CKT	TRIP	Poles	# OF Wires	GRD. SIZE	WIRE SIZE	COND. SIZE	Circuit Description	
EXISTING	--	--	--	--	--	--	1	20	3		2	20	1	3	12	12	3/4	RECEPTACLES OPEN OFFICE 3025	
EXISTING	--	--	--	--	--	--	1	20	3		4	20	1	3	12	12	3/4	RECEPTACLES OPEN OFFICE 3025	
EXISTING	--	--	--	--	--	--	1	20	3		6	20	1	3	12	12	3/4	RECEPTACLES OPEN OFFICE 3025	
EXISTING	--	--	--	--	--	--	1	20	7		8	20	1	3	12	12	3/4	RECEPTACLES OPEN OFFICE 3025	
EXISTING	--	--	--	--	--	--	1	20	9		10	20	1	3	12	12	3/4	RECEPTACLES OPEN OFFICE 3025	
EXISTING	--	--	--	--	--	--	1	20	11		12	20	1	3	12	12	3/4	RECEPTACLES OPEN OFFICE 3025	
EXISTING	--	--	--	--	--	--	1	20	13		14	20	1	3	12	12	3/4	RECEPTACLES OPEN OFFICE 3025	
EXISTING	--	--	--	--	--	--	1	20	15		16	20	1	3	12	12	3/4	RECEPTACLES OPEN OFFICE 3025	
EXISTING	--	--	--	--	--	--	1	20	17		18	20	1	3	12	12	3/4	COPIER COPY 3041	
EXISTING	--	--	--	--	--	--	1	20	19		20	20	1	3	12	12	3/4	RECEPTACLES CORRIDOR 3026	
EXISTING	--	--	--	--	--	--	1	20	21		22	20	1	3	12	12	3/4	RECEPTACLES OPEN OFFICE 3025	
EXISTING	--	--	--	--	--	--	1	20	23		24	20	1	3	12	12	3/4	FIB AND MB MED CONF. 3021	
Space	--	--	--	--	--	--	1	--	25		26	20	1	3	12	12	3/4	RECEPTACLES MED CONF. 3021	
Space	--	--	--	--	--	--	1	--	27		28	20	1	3	12	12	3/4	COPIER COPY 3024	
Space	--	--	--	--	--	--	1	--	29		30	20	1	3	12	12	3/4	RECEPTACLES CORRIDOR 3026	
Space	--	--	--	--	--	--	1	--	31		32	20	1	3	10	10	3/4	UNDERCABINET LIGHTING	
Space	--	--	--	--	--	--	1	--	33		34	20	1	--	--	--	--	Spare	
Space	--	--	--	--	--	--	1	--	35		36	20	1	--	--	--	--	Spare	
Space	--	--	--	--	--	--	1	--	37		38	20	1	--	--	--	--	Spare	
Space	--	--	--	--	--	--	1	--	39		40	20	1	--	--	--	--	Spare	
EXISTING TRANSF.	--	--	--	--	--	--	2	50	39		42	20	1	--	--	--	--	Spare	
									41										
Total Load:								2820 VA	1191 VA	1788 VA									
Total Amps:								11 A	4 A	7 A									
Load Classification	Connected Load			Demand Factor	Estimated Demand	Panel Totals													
Lighting	127 VA			125.00%	127 VA	Total Conn. Load: 29821 VA													
Receptacle	11400 VA			85.86%	10790 VA	Total Est. Demand: 24184 VA													
HVAC	0 VA			0.00%	0 VA	Total Conn. Current: 83 A													
Motor	0 VA			0.00%	0 VA	Total Est. Demand Current: 81 A													
Other	18300 VA			100.00%	18300 VA														
Kitchen	0 VA			0.00%	0 VA														
Notes:																			

Panel Name: L3A																			
Amp Rating: 225 A																			
Mains: MCB																			
MGB Rating: 225 A																			
Volts/Phase/Wire 120/208 Wye / 3 / 4																			
Manufacturer: EXISTING																			
Panel Type: EXISTING																			
Mounting: SURFACE																			
Remarks: EXISTING																			
Fault Rating: EXISTING																			
Fed From: ELECTRICAL ROOM 3006																			
Location: ELECTRICAL ROOM 3006																			
Circuit Description	COND. SIZE	WIRE SIZE	GRD. SIZE	# OF Wires	Poles	TRIP	CKT	A	B	C	CKT	TRIP	Poles	# OF Wires	GRD. SIZE	WIRE SIZE	COND. SIZE	Circuit Description	
RECEPTACLES OPEN OFFICE 3032	3/4	12	12	3	1	20	1	600	900		2	20	1	3	12	12	3/4	RECEPTACLES OPEN OFFICE 3032	
RECEPTACLES OPEN OFFICE 3032	3/4	12	12	3	1	20	3				4	20	1	3	12	12	3/4	RECEPTACLES OPEN OFFICE 3032	
RECEPTACLES OPEN OFFICE 3032	3/4	12	12	3	1	20	5				6	20	1	3	12	12	3/4	RECEPTACLES OPEN OFFICE 3032	
RECEPTACLES OPEN OFFICE 3032	3/4	12	12	3	1	20	7	900	1200		8	20	1	3	12	12	3/4	RECEPTACLES OPEN OFFICE 3032	
RECEPTACLES OPEN OFFICE 3032	3/4	12	12	3	1	20	9		900	900	10	20	1	3	12	12	3/4	RECEPTACLES OPEN OFFICE 3032	
RECEPTACLES OPEN OFFICE 3032	3/4	12	12	3	1	20	11			600	900	12	20	1	3	12	12	3/4	RECEPTACLES OPEN OFFICE 3032
RECEPTACLES OPEN OFFICE 3032	3/4	12	12	3	1	20	13	900	900		14	20	1	3	12	12	3/4	RECEPTACLES OPEN OFFICE 3032	
RECEPTACLES OPEN OFFICE 3032	3/4	12	12	3	1	20	15			600	900	16	20	1	3	12	12	3/4	RECEPTACLES OPEN OFFICE 3032
RECEPTACLES OPEN OFFICE 3032	3/4	12	12	3	1	20	17			1200	1500	18	20	1	3	12	12	3/4	COPIER COPY 3041
RECEPTACLES OPEN OFFICE 3032	3/4	12	12	3	1	20	19	900	120		20	20	1	3	12	12	3/4	RECEPTACLES CORRIDOR 3026	
RECEPTACLES OPEN OFFICE 3032	3/4	12	12	3	1	20	21			900	120	22	20	1	3	12	12	3/4	RECEPTACLES OPEN OFFICE 3032
RECEPTACLES OPEN OFFICE 3032	3/4	12	12	3	1	20	23			540	360	24	20	1	3	12	12	3/4	FIB AND MB MED CONF. 3021
FIB AND MB SMALL CONF. 3021	3/4	12	12	3	1	20	25	900	120		26	20	1	3	12	12	3/4	RECEPTACLES MED CONF. 3021	
RECEPTACLES SMALL CONF. 3021	3/4	12	12	3	1	20	27			540	1800	28	20	1	3	12	12	3/4	COPIER COPY 3024
RECEPTACLE FRAMERY CORR. 3026	3/4	12	12	3	1	20	29			900	540	30	20	1	3	12	12	3/4	RECEPTACLES CORRIDOR 3026
RECEPTACLE FRAMERY CORR. 3026	3/4	12	12	3	1	20	31	540	127		32	20	1	3	10	10	3/4	UNDERCABINET LIGHTING	
RECEPTACLES FOCUS 3040	3/4	12	12	3	1	20	33			540	0	34	20	1	--	--	--	Spare	
RECEPTACLES OFFICE 3025 & 3032	3/4	10	10	3	1	20	35			120	0	36	20	1	--	--	--	Spare	
RECEPTACLES FOCUS 3025 & 3022	3/4	12	12	3	1	20	37	360	0		38	20	1	--	--	--	--	Spare	
RECEPTACLES PUBLIC CORRIDOR...	3/4	12	12	3	1	20	39			360	0	40	20	1	--	--	--	Spare	
RECEPTACLES COPY 3024	3/4	12	12	3	1	20	41			540	0	42	20	1	--	--	--	Spare	
RECEPTACLES STORAGE 3033	3/4	12	12	3	1	20	43			540	0	44	20	1	--	--	--	Spare	
								9667 VA	10260 VA	9900 VA									
Total Amps:								81 A	86 A	83 A									
Load Classification	Connected Load			Demand Factor	Estimated Demand	Panel Totals													
Lighting	127 VA			125.00%	127 VA	Total Conn. Load: 29821 VA													
Receptacle	11400 VA			85.86%	10790 VA	Total Est. Demand: 24184 VA													
HVAC	0 VA			0.00%	0 VA	Total Conn. Current: 83 A													
Motor	0 VA			0.00%	0 VA	Total Est. Demand Current: 81 A													
Other	18300 VA			100.00%	18300 VA														
Kitchen	0 VA			0.00%	0 VA														
Notes:																			

Panel Name: L3A3																			
Amp Rating: 225 A																			
Mains: MLC																			
MGB Rating: 1 A																			
Volts/Phase/Wire 120/208 Wye / 3 / 4																			
Manufacturer: EXISTING																			
Panel Type: EXISTING																			
Mounting: SURFACE																			
Remarks: EXISTING																			
Fault Rating: EXISTING																			
Fed From: ELECTRICAL ROOM 3006																			
Location: ELECTRICAL ROOM 3006																			
Circuit Description	COND. SIZE	WIRE SIZE	GRD. SIZE	# OF Wires	Poles	TRIP	CKT	A	B	C	CKT	TRIP	Poles	# OF Wires	GRD. SIZE	WIRE SIZE	COND. SIZE	Circuit Description	
REFRIG	3/4	12	12	3	1	20	1	1200	180		2	20	1	3	12	12	3/4	REC	
REFRIG	3/4	12	12	3	1	20	3		1200	180	4	20	1	3	12	12	3/4	Receptacle	
REC, MB1	3/4	12	12	3	1	20	5			360	1500	6	20	1	3	12	12	3/4	DISHWASHER
MICROWAVE	3/4	12	12	3	1	20	7	1800	2800		8	20	2	4	10	10	3/4	COFFEE BREWER	
WATER DISPENSOR	3/4	12	12	3	1	20	9			600	2800	10	--	--	--	--	--	--	
MICROWAVE	3/4	12	12	3	1	20	11			1800	180	12	20	1	3	12	12	3/4	Receptacle
ICE MACHINE	3/4	12	12	3	1	20	13	1200	2800		14	30	2	4	10	10	3/4	COFFEE BREWER	
Spare	--	--	--	--	--	--	1	20	15		16	--	--	--	--	--	--	--	
Spare	--	--	--	--	--	--	1	20	17		18	20	1	--	--	--	--	Spare	
Spare	--	--	--	--	--	--	1	20	19		20	20	1	--	--	--	--	Spare	
Spare	--	--	--	--	--	--	1	20	21		22	60	2	4	8	6	1	BNH	
Spare	--	--	--	--	--	--	1	20	23		24	--	--	--	--	--	--	--	
Spare	--	--	--	--	--	--	1	20											