



GENERAL NOTES:

- A. SCHEMATIC TO ILLUSTRATE WIRING REQUIREMENTS FOR CONTROL PANEL. REFER TO IO LIST FOR ASSIGNED IO.

KEY NOTES: (X)

- 1. WIRE NUMBER IS COMPRISED OF 24 (24 VDC) + CB NUMBER. IN THIS CASE THE 3RD CB PROVIDES POWER SO WIRE NUMBER IS 243.
- 2. WIRE NUMBER IS SLOT (S) NUMBER, POINT (DIN) NUMBER
- 3. FIELD TO VERIFY IF FLOWMETERS HAVE DRY CONTACTS FOR FLOW TOTALIZER SIGNAL



FINAL CONSTRUCTION DOCUMENTS

A/E FIRM PRIME: KENNETH HAHN ARCHITECTS, INC. OMAHA, NE. SUBCONTRACTOR: ALVINE ENGINEERING OMAHA, NE. HDR DENVER, CO.	DESIGNED: B. CASSITY	SUB SHEET NO. Y4-03	TITLE OF SHEET TYPICAL DI WIRING	DRAWING NO. _____
	DRAWN BY: N. LYNCH	TECH. REVIEW: _____	BUCKSTAFF BATHHOUSE HVAC HOT SPRINGS NATIONAL PARK HOT SPRINGS, AK	PMIS/PKG NO. 177425
			SHEET 55 OF 60	