




- SHEET NOTES:**
- ROUTING OF TERMINAL EQUIPMENT, DUCTWORK AND PIPING SHALL BE VERY CAREFULLY COORDINATED WITH EXISTING CONDITIONS, PRESERVATION ZONES AND HISTORIC NATURE OF BUILDING TO CONFORM WITH THE SECRETARY OF THE INTERIOR'S REHABILITATION REQUIREMENTS AND PRESERVATION BRIEFS RELATED TO MEP DESIGN AND INSTALLATION.
  - VENTILATION AIR FOR SPACES SERVED BY FAN COIL UNITS WILL BE PROVIDED BY DOAS UNIT(S) MOUNTED ON ROOF. DOAS UNIT AND ASSOCIATED DUCTWORK FURNISHED BY FUTURE TENANT.

- KEYNOTES: #**
- VERTICAL WALL MOUNTED, 4-PIPE, EXPOSED FAN COIL UNIT.
  - 36"x12" FLOOR RETURN OPENINGS UNDER EXISTING BENCHES. COORDINATE W/C.O.
  - 12"x12" EXHAUST DUCT UP TO ROOFTOP MOUNTED EXHAUST FAN.
  - VERTICAL DUCTED, CONCEALED, WALL MOUNTED FAN COIL UNIT.
  - 4-PIPE VERTICAL BLOWER COIL UNIT.
  - MOUNT BOTTOM OF FAN COIL UNIT ON STAND SO BOTTOM OF UNIT IS AT LEAST 2" ABOVE BASE OF ABOVE ADJACENT CURBS.
  - 3/4" HWS & HWR DOWN IN EXISTING WALL CHASE.

**1**  
M1.3  
THIRD FLOOR MECHANICAL PLAN  
1/8" = 1'-0"



10.27.2023

A/E FIRMS PRIME/ARCH: <b>STRATA ARCHITECTURE</b> 1703 OAK STREET, SUITE 100 KANSAS CITY, MO T: 816.474.0900 MEP/ENG: <b>IMEG CORP.</b> 1400 BALTIMORE STREET, SUITE 300 KANSAS CITY, MO T: 816.842.8437	DESIGNED: SGB	SUB SHEET NO. <b>01</b> <b>M1.3</b>	TITLE OF SHEET <b>MAURICE BATHHOUSE</b> <b>THIRD FLOOR VENTILATION</b> <b>PLAN</b> REHABILITATE BATHHOUSES HOT SPRINGS NATIONAL PARK	DRAWING NO. <b>626</b> <b>180065</b>
	CADD: WMM			PMIS/PKG NO. 318674
	TECH. REVIEW: SCB			SHEET 144 OF 286
	DATE: 10.27.2023			

10/27/2023 1:14:11 PM