

WILLIAM J CLINTON  
PRESIDENTIAL  
CENTER

LITTLE ROCK, ARKANSAS

Architect  
POLSHEK PARTNERSHIP LLP  
320 West 13th Street  
New York, New York 10014  
212.607.7171

Coordinating Architects  
POLK STANLEY YEARY ARCHITECTS, Ltd  
700 South Schiller Street  
Little Rock, Arkansas 72201  
501.378.0878

WITSELL EVANS RASCO  
801 West Third Street  
Little Rock, Arkansas 72201  
501.374.5300

WOODS CARADINE ARCHITECTS  
2200 South Main Street  
Little Rock, Arkansas 72206  
501.374.4080

Landscape Architects  
HARGREAVES ASSOCIATES  
118 Magazine Street  
Cambridge, Massachusetts 02138  
617.661.0070

LANDSCAPE ARCHITECTURE, Inc.  
2300 Cottondale Lane Suite 202  
Little Rock, Arkansas 72202  
501.374.5610

Structural Engineer  
LESUE E. ROBERTSON ASSOC. RLLP  
30 Broad Street 47th Floor  
New York, New York 10004  
212.753.9300


MEP Engineers  
FLACK + KURTZ Inc  
475 Fifth Avenue  
New York, New York 10017  
212.532.9600

CROMWELL ARCHITECTS ENGINEERS  
101 South Spring Street  
Little Rock, Arkansas 72201  
501.372.2900

Curtilwall Consultant  
R. A. HEINTGES ARCHITECTS  
128 Fifth Avenue, 9th Floor  
New York, New York 10011  
212.652.2068



100% Construction Documents	09/27/02
90% Progress Printing	08/20/02
100% Design Development	03/01/02
Issue	Date



Job No: POLSHEK & PARTNERS ARCH. 9906  
CROMWELL AE 99-114

Scale: N T S

Date: SEPTEMBER 27, 2002

Title: ELECTRICAL  
PANELBOARD  
SCHEDULES

Sheet No:

E503

FOR OFFICIAL USE ONLY

PANEL	DL5B1	TYPE	XP16	LOCATION	S-02	MOUNT	SURFACE
MAIN	MLD	BUS		VOLTS	208Y/120	PHASE	3
4	WIRE						
INTERRUPTING RATING							
CIR NUM	CIR POLE	CIR BKR	OUTLET	REMARKS	VOLT-AMPERES		
NUM	AT	TYPE	LTS REC MISC		L-1	L-2	L-3
1	3	20		ZONE 514	400		
2	1	20		ZONE 548		100	
3	1	20		ZONE 543			100
4	1	20		ZONE 551	200		
5	1	20		ZONE 541		300	
6	1	20		ZONE 520			700
7	1	20		ZONE 520	700		
8	1	20		ZONE 519		700	
9	1	20		ZONE 519			600
10	1	20		ZONE 519	700		
11	1	20		ZONE 533		450	
12	1	20		ZONE 530			600
13	1	20		ZONE 534	600		
14	1	20		ZONE 528		200	
15	1	20		ZONE 547			200
16							
17							
18							
19							
20							
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							
31							
32							
33							
34							
35							
36							
37							
38							
39							
40							
41							
42							
PHASE TOTAL					2600	1750	2200
TOTAL CONNECTED					6550V A		

PANEL	EH0B1	TYPE	S042	LOCATION	MEP1	MOUNT	SURFACE
MAIN	MLD	BUS	165	VOLTS	480Y/277	PHASE	3
4	WIRE						
INTERRUPTING RATING							
CIR NUM	CIR POLE	CIR BKR	OUTLET	REMARKS	VOLT-AMPERES		
NUM	AT	TYPE	LTS REC MISC		L-1	L-2	L-3
1	3	20			2934		
2	3	25		AH-B-5	3733		
3				CP-10		2934	
4						3733	
5							2934
6							3733
7	3	25		CP-11	3733		
8	3	25		CP-12	3733		
9						3733	
10						3733	
11							3733
12							3733
13	3	25		CP-13	3733		
14	3	15		CP-14	3733		
15						3733	
16						3733	
17							3733
18							3733
19	3	15		CP-15	3733		
20	3	150	ST	ELEVATOR F5	19933		
21						3733	
22						19933	
23							3733
24							19933
25							
26							
27							
28							
29							
30							
31							
32							
33							
34							
35							
36							
37							
38							
39							
40							
41							
42							
PHASE TOTAL					45265	45265	45265
TOTAL CONNECTED					135795V A		

PANEL	EH0C1	TYPE	S042	LOCATION	MEP2	MOUNT	SURFACE
MAIN	MLD	BUS	145	VOLTS	480Y/277	PHASE	3
4	WIRE						
INTERRUPTING RATING							
CIR NUM	CIR POLE	CIR BKR	OUTLET	REMARKS	VOLT-AMPERES		
NUM	AT	TYPE	LTS REC MISC		L-1	L-2	L-3
1	3	60		AH-B-1	7167		
2	3	60		AH-B-3	7167		
3						7167	
4						7167	
5							7167
6							
7	3	20					
8	3	60		AH-B-2	7167		
9							7167
10							7167
11							
12							
13	3	20		DU-B-3	2167		7167
14	3	20		DU-B-2	2167		
15							2167
16							2167
17							
18							
19	3	20		H-B-1	3000		
20	3	30		H-B-2	6000		
21						3000	
22						6000	
23							3000
24							6000
25	3	30		H-B-3	6000		
26							6000
27							
28							
29							6000
30							
31							
32							
33							
34							
35							
36							
37							
38							
39							
40							
41							
42							
PHASE TOTAL					40835	40835	40835
TOTAL CONNECTED					122505V A		

PANEL	EH0D1	TYPE	S042	LOCATION	MEP4	MOUNT	SURFACE
MAIN	MLD	BUS	480	VOLTS	480Y/277	PHASE	3
4	WIRE						
INTERRUPTING RATING							
CIR NUM	CIR POLE	CIR BKR	OUTLET	REMARKS	VOLT-AMPERES		
NUM	AT	TYPE	LTS REC MISC		L-1	L-2	L-3
1	3	20		JOCKEY PUMP	900		
2	3	590	ADJ	C-1	5567		
3						500	
4						5568	
5							500
6							5568
7	3	300		PP1	56333		
8	3	80		PP2	11633		
9						56333	
10						11633	
11							56333
12							11633
13	3	50		CT-1	7167		
14	1	20		HEAT TAPE	1600		
15						7167	
16							7167
17							
18							
19	3	225	ST	ELEVATOR F3 ESTIMATE	34533		
20	3	125	ST	ELEVATOR S4 ESTIMATE	15933		
21						34533	
22						15933	
23							34533
24							15933
25							
26							
27							
28							
29							
30							
31							
32							
33							
34							
35							
36							
37							
38							