

WILLIAM J CLINTON
PRESIDENTIAL
CENTER

LITTLE ROCK, ARKANSAS

Architect
POLK SHEK PARTNERSHIP LLP
320 West 13th Street
New York, New York 10014
212.507.7171

Coordinating Architects
POLK STANLEY YEARY ARCHITECTS Ltd
700 South Schiller Street
Little Rock, Arkansas 72201
501.378.0878

WITSELL EVANS RASCO
901 West Third Street
Little Rock, Arkansas 72201
501.374.5300

WOODS CAROLINE ARCHITECTS
2200 South Main Street
Little Rock, Arkansas 72206
501.374.4060

Landscape Architects
HARGREAVES ASSOCIATES
118 Magazano Street
Cambridge, Massachusetts 02139
617.661.0070

LANDSCAPE ARCHITECTURE, Inc.
2300 Cottondale Lane Suite 202
Little Rock, Arkansas 72202
501.374.5510

Structural Engineer
LESLIE E. ROBERTSON ASSOC. P.L.P.
30 Broad Street 4th Floor
New York, New York 10004
212.750.9000


MEP Engineers
FLACK + KURTZ Inc
475 Fifth Avenue
New York, New York 10017
212.532.9600

CROMWELL ARCHITECTS ENGINEERS
101 South Spring Street
Little Rock, Arkansas 72201
501.372.2900

Curranwell Consultant
R A HEINTGES ARCHITECTS
126 Fifth Avenue 9th Floor
New York, New York 10011
212.652.2966



100% Construction Documents 09/27/02
90% Progress Printing 08/20/02
100% Design Development 03/01/02
Issue Date



Job No POLSHEK & PARTNERS ARCH 9908
CROMWELL AE 99-114

Scale N T S

Date SEPTEMBER 27, 2002

Title
ELECTRICAL
PANEL
SCHEDULES

Sheet No

E508

FOR OFFICIAL USE ONLY

PANEL	HSB1	TYPE	SQ42	LOCATION	5-02	MOUNT	SURFACE
MAIN	MCB	BUS	25	VOLTS	480Y/277	PHASE	3
4 WIRE INTERRUPTING RATING							
CIR NUM	POLE	A/T	TYPE	OUTLET	REMARKS	VOLT-AMPERES	
				LTS REC MISC		L-1	L-2 L-3
1	3	20			EF-5-1	942	
2	3	45			AH-5-2	5567	
3							942
4							5567
5							942
6							5667
7							
8							
9							
10							
11							
12							
13							
14							
15							
16							
17							
18							
19							
20							
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							
31							
32							
33							
34							
35							
36							
37							
38							
39							
40							
41							
42							
PHASE TOTAL						6509	6509 6609
TOTAL CONNECTED						19627VA	

PANEL	L0B1	TYPE	SQ42	LOCATION	B-10	MOUNT	SURFACE
MAIN	MCB	BUS		VOLTS	208Y/120	PHASE	3
4 WIRE INTERRUPTING RATING							
CIR NUM	POLE	A/T	TYPE	OUTLET	REMARKS	VOLT-AMPERES	
				LTS REC MISC		L-1	L-2 L-3
1	1	20			CAFÉ TERRACE	720	
2	1	20			CAFÉ	720	
3	1	20			CAFÉ TERRACE		900
4	1	20			STORAGE, CAFÉ	720	
5	1	20			CAFÉ, CORRIDOR		900
6							
7	1	20			CDMM	180	
8	1	20			EWC	180	
9	1	20			CDMM		180
10	1	20			TOILETS		1080
11	1	20			CDMM		180
12	1	20			CURR' ELEC ELEV		1080
13	1	20			SPARE		
14	3	50			WELDER	4800	
15	1	20			MECH	720	
16	-	50			WELDER	4800	
17	1	20			MECH		900
18	-	50			WELDER		4800
19	1	20			PUMP RM	1080	
20	1	20			CORR	360	
21	1	20			B-21		900
22	1	20			GIFT SHOP MGR	720	
23	1	20			B-21A B-22		1080
24	1	20			ELEV MACHINE, PIT, TOILET		1080
25	1	20			TOILET	1080	
26	1	20			MEP	720	
27	1	20			TOILET		1080
28	1	20			MEP		900
29	1	20			ELEV, JAN, STG		1080
30	1	20			MAINT OFF, GIFT SHOP		900
31							
32	1	20			CORRIDOR	900	
33							
34	1	20			CUSTODIAL	720	
35							
36							
37							
38							
39							
40							
41							
42							
PHASE TOTAL						10740	12720 12000
TOTAL CONNECTED						35460VA	

PANEL	L0B2	TYPE	SQ42	LOCATION	B-10	MOUNT	SURFACE
MAIN	MCB	BUS	50	VOLTS	208Y/120	PHASE	3
4 WIRE INTERRUPTING RATING							
CIR NUM	POLE	A/T	TYPE	OUTLET	REMARKS	VOLT-AMPERES	
				LTS REC MISC		L-1	L-2 L-3
1	1	20			EF-B1 B2	260	
2							1656
3	1	30			BCU-B-5		
4							80
5	1	20			FCU-B-1		
6							
7							
8							
9							
10							
11	1				FCU-B-2		80
12							
13	1	20			FCU-B3 B4	300	
14	2	20			HAND DRYER	1144	
15	1	20			BCU-B-3		1176
16	-						1144
17	1	20			FCU-B-5		100
18	2	20			HAND DRYER		1144
19	2	20			HAND DRYER	1144	
20	-						1144
21	-						
22	2	20			HAND DRYER		1144
23							
24							
25							
26							
27							
28							
29							
30							
31							
32							
33							
34							
35							
36							
37							
38							
39							
40							
41							
42							
PHASE TOTAL						3992	6264 2548
TOTAL CONNECTED						12804VA	

PANEL	L0D1	TYPE	SQ42	LOCATION	MEP5	MOUNT	SURFACE
MAIN	MCB	BUS		VOLTS	208Y/120	PHASE	3
4 WIRE INTERRUPTING RATING							
CIR NUM	POLE	A/T	TYPE	OUTLET	REMARKS	VOLT-AMPERES	
				LTS REC MISC		L-1	L-2 L-3
1	1	20			DDC STG	1080	
2	1	20			DPC STG	1080	
3	1	20			CLASS STG		1080
4	1	20			DDC STG		1080
5	1	20			CLASS DDC STG		1080
6	1	20			DDC STG	720	1080
7	1	20			NARA COMPUTER	360	
8	1	20			NARA COMPUTER		720
9	1	20			NARA COMPUTER		360
10	1	20			NARA COMPUTER		360
11	1	20			NARA COMPUTER		360
12	1	20			DDC PROCESSING		540
13	1	20			DDC PROCESSING	1080	
14	1	20			CORRIDOR		540
15	1	20			DDC PROCESSING		700
16	1	20			EWC		540
17	1	20			DDC PROCESSING		900
18	1	20			TOILET, ELEC		
19	1	20			CLASS DDC WCRM	540	
20	1	20			CLASS DDC WCRM	720	
21	1	20			CLASS DDC WCRM		720
22	1	20			DDC STG		720
23	1	20			CLASS DDC WCRM		720
24							
25	1	20			CDMM	200	
26	1	20			ELEV, MECH	720	
27	1	20			CDMM	200	
28	1	20			MECH	720	
29	1	20			CDMM		200
30	1	20			MECH, FP		900
31	1	20			MEP	1080	
32							
33	1	20			MEP, CORRIDOR		1080
34							
35	1	20			ELEV, EXT		900
36							
37							
38							
3							