

**WILLIAM J CLINTON
PRESIDENTIAL
CENTER**

LITTLE ROCK, ARKANSAS

Architect
POLSHEK PARTNERSHIP LLP
320 West 13th Street
New York, New York 10014
212 857 7171

Coordinating Architects
POLK STANLEY YEARY ARCHITECTS Ltd
700 South Schiller Street
Little Rock, Arkansas 72201
501 378 0878

WITSELL EVANS RASCO
801 West Third Street
Little Rock, Arkansas 72201
501 374 5300

WOODS CARAIGNE ARCHITECTS
2200 South Main Street
Little Rock, Arkansas 72206
501 374 4060

Landscape Architects
HARGREAVES ASSOCIATES
118 Magazine Street
Cambridge, Massachusetts 02139
617 861 0070


LANDSCAPE ARCHITECTURE, Inc.
2300 Collondale Lane Suite 202
Little Rock, Arkansas 72202
501 374 5610

Structural Engineer
LESLIE E. ROBERTSON ASSOC. RLP
30 Broad Street 47th Floor
New York, New York 10004
212 750 9000


MEP Engineers
FLACK + KURTZ Inc
475 Fifth Avenue
New York, New York 10017
212 532 9600

CROMMELL ARCHITECTS ENGINEERS
101 South Spring Street
Little Rock, Arkansas 72201
501 372 2300

Curtainwall Consultant
R. A. HEINTGES ARCHITECTS
126 Fifth Avenue, 9th Floor
New York, New York 10011
212 652 2365



100% Construction Documents 09/27/02
90% Progress Printing 08/30/02
100% Design Development 03/01/02
Issue Date



Job No: POLSHEK & PARTNERS ARCH 9908
CROMMELL AE 99-114
Scale: N T S
Date: SEPTEMBER 27, 2002

**ELECTRICAL
PANELBOARD
SCHEDULES**

Sheet No: **E511**

FOR OFFICIAL USE ONLY

PANEL	L2D1	TYPE	SQ42	LOCATION	2-28	MDUNT	SURFACE
MAIN	MCB	BUS	80	VOLTS	208Y/120	PHASE	3
4 WIRE INTERRUPTING RATING							
CIR NUM	POLE	AT	TYPE	OUTLET	REMARKS	VOLT-AMPERES	
				LTS REC MISC		L-1	L-2 L-3
1	1	20		4	RESEARCHER RM	720	
2	1	20		5	RESEARCHER RM	900	
3	1	20		6	RESEARCHER RM	1080	
4	1	20		6	RESEARCHER RM	1080	
5	1	20		4	RESEARCHER DRIENT		720
6	1	20		4	RESEARCHER RM		720
7	1	20		6	CONFERENCE	1080	
8	1	20		2	KITCHEN	1200	
9	1	20		2	CORR		180
10	1	20		1	KITCHEN	1200	
11	1	20		1	EWC		180
12	1	20		1	KITCHEN		1200
13	1	20		4	LUNCH RM	720	
14	1	20		6	RESEARCH LOUNGE LOCKERS	1080	
15	1	20		4	LUNCH RM		720
16	1	20		1	VAV CTRL		200
17	1	20		6	LUNCH RM, TOILET		1080
18	1	30		1	EF-2-1	1200	1656
19	1	20		2	PROJECTOR	360	
20	1	20		2	CONFERENCE		
21	1	20		1	SCREEN		1200
22	1	20		2	CONFERENCE		360
23	1	20		1	SHADE		1440
24	1	20		1	HAND DRYER	1144	
25	2	20					
26						1144	
27							
28							
29	2	20		1	HAND DRYER		1144
30							
31						1144	
32							
33							
34							
35							
36							
37							
38							
39							
40							
41							
42							
PHASE TOTAL						9548	6804 8500
TOTAL CONNECTED						24852VA	

PANEL	L3D1	TYPE	SQ42	LOCATION	3-31	MDUNT	SURFACE
MAIN	MCB	BUS	85	VOLTS	208Y/120	PHASE	3
4 WIRE INTERRUPTING RATING							
CIR NUM	POLE	AT	TYPE	OUTLET	REMARKS	VOLT-AMPERES	
				LTS REC MISC		L-1	L-2 L-3
1	1	20		1	COPY/PRINT	1200	
2	1	20		6	OPEN OFFICE	1080	
3	1	20		1	COPY/PRINT		1200
4	1	20		6	OPEN OFFICE		1080
5	1	20		1	COPY/PRINT		1200
6	1	20		6	OPEN OFFICE		1080
7	1	20		6	OPEN OFFICE	1080	
8	1	20		4	OPEN OFFICE	720	
9	1	20		6	OPEN OFFICE		1080
10	1	20		1	COPY/PRINT		1200
11	1	20		6	OPEN OFFICE		1080
12	1	20		4	OPEN OFFICE		720
13	1	20		4	OPEN OFFICE	720	
14	1	20		5	OFFICE	900	
15	1	20		4	OPEN OFFICE		720
16	1	20		5	WRK RM		900
17	1	20		5	TOILET CORR		900
18	1	20		1	COPY/PRINT		1200
19	1	20		3	OFFICE	540	
20	1	20		5	OFFICE	900	
21	1	20		4	CORR		720
22	1	20		6	OFFICE		1080
23	1	20		1	EWC		700
24	1	20		6	OFFICE		1080
25	1	20		5	OFFICE	900	
26							
27	1			1	VAV CTRL		200
28							
29	1	20		1	AT EF-3-1,2		180
30	2	20		1	HAND DRYER		1144
31	2	20		1	HAND DRYER		1144
32						1144	
33							1144
34							
35							
36							
37							
38							
39							
40							
41							
42							
PHASE TOTAL						10328	9324 9284
TOTAL CONNECTED						28936VA	

PANEL	L3K1	TYPE	SQ42	LOCATION	3-14 KIT	MDUNT	SURFACE
MAIN	MCB	BUS	70	VOLTS	208Y/120	PHASE	3
4 WIRE INTERRUPTING RATING							
CIR NUM	POLE	AT	TYPE	OUTLET	REMARKS	VOLT-AMPERES	
				LTS REC MISC		L-1	L-2 L-3
1	1	20		1	MOBILE WARM CAB	1500	
2	1	20		1	IC REFRIG	600	
3	1	20		1	MOBILE WARM CAB		1500
4	2	40		3	COFFEE		3000
5	1	20		3	CONV		540
6	-	40		1	COFFEE		3000
7	1	20		1	ICED TEA	1800	
8	1	20		1	CONV DVEN	720	
9	1	20		1	COFFEE		1270
10	1	20		1	CONV DVEN		720
11	2	20		1	ICED TEA		1115
12	1	20		1	CONV		180
13	-	20		1	CONV DVEN		1115
14	1	20		1	FREEZER	1200	
15	1	20		3	CONV		540
16	1	20		1	REFRIG		1200
17	1	20		1	HOOD		400
18							
19							
20							
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							
31							
32							
33							
34							
35							
36							
37							
38							
39							
40							
41							
42							
PHASE TOTAL						6935	8230 5235
TOTAL CONNECTED						20400VA	

PANEL	L4B1	TYPE	SQ42	LOCATION	4-13 A/V ROOM	MDUNT	SURFACE
MAIN	MCB	BUS	90	VOLTS	208Y/120	PHASE	3
4 WIRE INTERRUPTING RATING							
CIR NUM	POLE	AT	TYPE	OUTLET	REMARKS	VOLT-AMPERES	
				LTS REC MISC		L-1	L-2 L-3
1	1	20		1	EXHIBIT PIER	180	
2	1	20		4	TOILET CORR	720	
3	1	20		1	EXHIBIT PIER		180
4	1	20		1	EXHIBIT PIER		180
5	1	20		1	EXHIBIT PIER		180
6	1	20		4	TEMP EXHIBITION GALLERY	720	
7	1	20		4	A/V ROOM	720	
8	1	20		4	LOBBY		720
9	1	20		4	A/V ROOM		720
10	1	20		4	LOBBY		720
11	1	20		2	LOBBY		360
12	1	20		1	EWC	700	
13	1	20		4	GREEN ROOM	720	
14	1	20		6	TOILET, ELEV LOBBY		1080
15	1	20		4	TOILET		720
16	1	20		4	TOILET		720
17	1	20		1	GREEN ROOM		1200
18	1	20		1	FCU-4-4	320	
19	2	20		1	A/V EQ COORD LOCATION	1664	
20	1	20		1	EF-4-1 ESTIMATE		1920
21						1664	
22							
23							
24	2			1	PROJECTOR		1200
25						1144	
26							1200
27		20		1	HAND DRYER		1144
28							
29	2			1	HAND DRYER		1144
30	2			1	HAND DRYER		1144
31						11	