

WILLIAM J CLINTON  
PRESIDENTIAL  
CENTER

LITTLE ROCK, ARKANSAS

Architect  
POLSHEK PARTNERSHIP LLP  
320 West 13th Street  
New York, New York 10014  
212.807.7171

Coordinating Architects  
POLK STANLEY YEARY ARCHITECTS, Ltd  
700 South Schaller Street  
Little Rock, Arkansas 72201  
501.378.0878

WITSELL EVANS RASCO  
801 West Third Street  
Little Rock, Arkansas 72201  
501.374.5300

WOODS CAROLINE ARCHITECTS  
2200 South Main Street  
Little Rock, Arkansas 72206  
501.374.4060

Landscape Architects  
HARGREAVES ASSOCIATES  
118 Magazine Street  
Cambridge, Massachusetts 02139  
617.861.0070

LANDSCAPE ARCHITECTURE, Inc  
2300 Cottondale Lane Suite 202  
Little Rock, Arkansas 72202  
501.374.5610

Structural Engineer  
LESLIE E. ROBERTSON ASSOC. RLP  
30 Broad Street 4th Floor  
New York, New York 10004  
212.750.9000


MEP Engineers  
FLACK + KURTZ Inc.  
475 Fifth Avenue  
New York, New York 10017  
212.532.9600

CROMMELL ARCHITECTS ENGINEERS  
101 South Spring Street  
Little Rock, Arkansas 72201  
501.372.2900

Curtainwall Consultant  
R. A. HEINTGES ARCHITECTS  
128 Fifth Avenue 9th Floor  
New York, New York 10011  
212.652.2965



100% Construction Documents 09/27/02  
90% Progress Printing 08/30/02  
100% Design Development 03/01/02  
Issue Date



Job No. POLSHEK & PARTNERS ARCH. 9908  
CROMMELL AE 99-114

Scale: N T S  
Date: SEPTEMBER 27, 2002

ELECTRICAL  
PANELBOARD  
SCHEDULES

Sheet No. **E513**

FOR OFFICIAL USE ONLY

PANEL	SH2D1	TYPE	XP20	LOCATION	2-28	MOUNT	SURFACE
MAIN	MLD	BUS		VOLTS	480Y/277	PHASE	3
4 WIRE INTERRUPTING RATING							
CIR NUM	CIR BKR	OUTLET	REMARKS		VOLT-AMPERES		
NUM	POLE	A T	TYPE	LTS REC MISC	L-1	L-2	L-3
1	1	20		6	ZONE 215	384	
2	1	20		10	ZONE 205		384
3	1	20		6	ZONE 212		384
4	1	20		6	ZONE 213	384	
5	1	20		6	ZONE 215		384
6	1	20		6	ZONE 214		384
7	1	20		2	ZONE 223	76	
8	1	20		1	ZONE 230		64
9	1	20		12	ZONE 220		456
10	1	20		3	ZONE 225	320	
11	1	20		6	ZONE 221		252
12	1	20		3	ZONE 226		320
13	1	20		4	ZONE 216	256	
14	1	20		12	ZONE 219		768
15	1	20		2	ZONE 218		64
16	1	20		2	ZONE 231	128	
17	1	20		19	ZONE 206		608
18							
19							
20							
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							
31							
32							
33							
34							
35							
36							
37							
38							
39							
40							
41							
42							
PHASE TOTAL					1548	2396	1608
TOTAL CONNECTED					5552V A		

PANEL	SH3D1	TYPE	XP24	LOCATION	3-31	MOUNT	SURFACE
MAIN	MLD	BUS		VOLTS	480Y/277	PHASE	3
4 WIRE INTERRUPTING RATING							
CIR NUM	CIR BKR	OUTLET	REMARKS		VOLT-AMPERES		
NUM	POLE	A T	TYPE	LTS REC MISC	L-1	L-2	L-3
1	1	20		1	ZONE 366	32	
2	1	20		1	ZONE 368		32
3	1	20		1	ZONE 365		32
4	1	20		1	ZONE 367	32	
5	1	20		1	ZONE 364		32
6	1	20		1	ZONE 367		32
7	1	20		1	ZONE 369	32	
8	1	20		15	ZONE 354		960
9	1	20		1	ZONE 370		32
10	1	20		7	ZONE 356	224	
11	1	20		1	ZONE 371		32
12	1	20		15	ZONE 355		960
13	1	20		1	ZONE 360	32	
14	1	20		1	ZONE 363		32
15	1	20		1	ZONE 359		32
16	1	20		1	ZONE 362	32	
17	1	20		1	ZONE 358		32
18	1	20		1	ZONE 361		32
19	1	20		3	ZONE 350	192	
20	1	20		6	ZONE 333		192
21	1	20		3	ZONE 347		160
22	1	20		4	ZONE 332	256	
23	1	20		6	ZONE 349		384
24							
25							
26							
27							
28							
29							
30							
31							
32							
33							
34							
35							
36							
37							
38							
39							
40							
41							
42							
PHASE TOTAL					832	1696	1280
TOTAL CONNECTED					3888V A		

PANEL	SH3D2	TYPE	XP12	LOCATION	3-31	MOUNT	SURFACE
MAIN	MLD	BUS		VOLTS	480Y/277	PHASE	3
4 WIRE INTERRUPTING RATING							
CIR NUM	CIR BKR	OUTLET	REMARKS		VOLT-AMPERES		
NUM	POLE	A T	TYPE	LTS REC MISC	L-1	L-2	L-3
1	1	20		2	ZONE 343		128
2	1	20		4	ZONE 346		256
3	1	20		2	ZONE 342		128
4	1	20		4	ZONE 345		256
5	1	20		2	ZONE 341		128
6	1	20		2	ZONE 344		128
7	1	20		2	ZONE 370		128
8	1	20		26	ZONE 331 331		650
9	1	20		7	ZONE 352 352		352
10	1	20		22	ZONE 331		550
11	1	20		7	ZONE 351 351		352
12	1	20		22	ZONE 331		550
13							
14							
15							
16							
17							
18							
19							
20							
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							
31							
32							
33							
34							
35							
36							
37							
38							
39							
40							
41							
42							
PHASE TOTAL					1062	1386	1158
TOTAL CONNECTED					3606V A		

PANEL	SH4B1	TYPE	XP16	LOCATION	4-13 A/V ROOM	MOUNT	SURFACE
MAIN	MLD	BUS	10	VOLTS	480Y/277	PHASE	3
4 WIRE INTERRUPTING RATING 14,000A							
CIR NUM	CIR BKR	OUTLET	REMARKS		VOLT-AMPERES		
NUM	POLE	A T	TYPE	LTS REC MISC	L-1	L-2	L-3
1	1	20		13	ZONE 455	169	
2	1	20		36	ZONE 442 442		900
3	1	20		6	ZONE 411		600
4	1	20		6	ZONE 412	600	
5	1	20		24	ZONE 437		768
6	1	20		19	ZONE 429 429		608
7	1	20		11	ZONE 431 431	352	
8	1	20		8	ZONE 432 432		480
9	1	20		7	ZONE 433 433		352
10	1	20		6	ZONE 434	192	
11	1	20		7	ZONE 438		245
12							
13							
14							
15							
16							
17							
18							
19							
20							
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							
31							
32							
33							
34							
35							
36							
37							
38							
39							