

**POLK
STANLEY
YEARY
ARCHITECTS, LTD.**

700 SOUTH SCHILLER
LITTLE ROCK, AR 72201
501.378-6878
FAX 372-7629

21 W. MOUNTAIN, SUITE 227
FAYETTEVILLE, AR 72701
479-444-0473

CONSULTANTS:

OWNER'S PROJECT ADVISOR:
MOSES TUCKER REAL ESTATE, INC.

CIVIL ENGINEER:
MCLELLAND ENGINEERS

LANDSCAPE ARCHITECT:
LARSON BURNS SMITH

STRUCTURAL ENGINEER:
CROMWELL ENGINEERS INC.

MECH., ELEC., PLUMB. ENGINEER:
CROMWELL ENGINEERS INC.

SUSTAINABLE CONSULTANT:
BNIM / ELEMENTS

GLOBAL VILLAGE CONSULTANT
CAMBRIDGE SEVEN ASSOCIATES

INTERIOR DESIGNER:
POLK STANLEY YEARY

GENERAL CONTRACTOR:
CDI

GENERAL NOTES:

NOTES:

ISSUE DATE:
DECEMBER 15, 2003
CORE/SHELL
PACKAGE #5

REVISIONS:

#	DATE	DESCRIPTION
1	1/16/04	ADDENDUM #1
2	4/07/04	PACKAGE 5 - ADDM. 05
3	7/01/04	PACKAGE 7, 100% ROLLUP
4	10/12/04	ASI #20
5	11/29/04	ASI #27

**HEIFER
INTERNATIONAL
CENTER
OFFICE BUILDING**

LITTLE ROCK, ARKANSAS

PSY PROJECT NUMBER:
431C

CONTENTS:
FIRST FLOOR LIGHTING
PLAN - WEST END
SHEET NUMBER:

E101b

KEYED NOTES:

- ◇ DAYLIGHT SENSOR / OCCUPANCY SENSOR.
- ◇ PROVIDE QUARTZ RESTRIKE IN FIXTURES.
- ◇ DAYLIGHT SENSOR.
- ◇ OCCUPANCY SENSOR "a" SHALL CONTROL LIGHTS DIMMED USING DAYLIGHT SENSORS "a" and "b". (SIMILAR THROUGHOUT LIGHTING PLANS.)
- ◇ OCCUPANCY SENSOR. WHEN OCCUPANCY IS DETECTED, WALL MOUNTED SWITCHES SHALL CONTROL LIGHTS. WHEN OCCUPANCY SENSOR DOES NOT DETECT OCCUPANCY, LIGHTS SHALL BE OFF, REGARDLESS OF WALL POSITION. (SIMILAR THROUGHOUT LIGHTING PLANS.)
- ◇ OCCUPANCY SENSOR SHALL HAVE "OFF" AND "AUTO" SETTINGS. (SIMILAR THROUGHOUT LIGHTING PLANS.)

1 FIRST FLOOR LIGHTING PLAN - WEST END
SCALE: 1/8" = 1'-0"



NORTH



12/15/03