

PANELBOARD SCHEDULE _____CE-1_____										LOCATION: _____ELEC. RM A209_____		C/B RATING: _____k.A.I.C._____			
VOLT/PH/W: 120/208V, 3PH, 4W		MANS: 70A MCB			MTG. SURFACE			TYPE: BOLT-ON							
USE/AND OR AREA SERVED	C/B	#A	#B	#C	CIRCUIT NO.	#A	#B	#C	C/B	USE/AND OR AREA SERVED					
SPACE	40	-	-	-	1	2	-	-	20/1	RECEPTACLES-RM A135					
					3	4	-	-	20/1	SPARE					
					5	6	-	-	20/1	SPARE					
SPACE	20/1	-	-	-	7	8	-	-	20/1	RECEPTACLES-RM A139					
SPACE	20/1	-	-	-	9	10	-	-	20/1	SPARE					
SPACE	20/1	-	-	-	11	12	-	-	20/1	SPARE					
SPACE	20/1	-	-	-	13	14	-	-	20/1	RECEPTACLES-RM A261					
SPACE	20/1	-	-	-	15	16	-	-	20/1	SPARE					
SPACE	20/1	-	-	-	17	18	-	-	20/1	SPARE					
SPACE	20/1	-	-	-	19	20	-	-	20/1	SPARE					
SPACE	20/1	-	-	-	21	22	-	-	20/1	SPARE					
SPACE	20/1	-	-	-	23	24	-	-	20/1	SPARE					
SPACE	20/1	-	-	-	25	26	-	-	20/1	SPARE					
SPACE	20/1	-	-	-	27	28	-	-	20/1	SPARE					
SPACE	-	-	-	-	29	30	-	-	20/1	SPARE					
SPACE	-	-	-	-	31	32	-	-	20/1	SPARE					
SPACE	-	-	-	-	33	34	-	-	20/1	SPARE					
SPACE	-	-	-	-	35	36	-	-	20	EXISTING LOAD					
SPACE	-	-	-	-	37	38	-	-	2						
SPACE	-	-	-	-	39	40	-	-	20	EXISTING LOAD					
SPACE	-	-	-	-	41	42	-	-	2						
TOTAL PHASE "A"		-	-	-	-	-	-	-	-						
TOTAL PHASE "B"		-	-	-	-	-	-	-	-						
TOTAL PHASE "C"		-	-	-	-	-	-	-	-						
TOTAL CONNECTED LOAD:		-	-	-	-	-	-	-	-	TOTAL CONNECTED LOAD: (AMPS) _____					
		-	-	-	-	-	-	-	-	TOTAL DEMAND LOAD: (AMPS) _____					

FED FROM PANEL "CE3" (BREAKERS 19,21,23) IN ELEC. RM B117

PANELBOARD SCHEDULE _____CE3_____										LOCATION: _____RM B117_____		C/B RATING: _____k.A.I.C._____			
VOLT/PH/W: 120/208V, 3PH, 4W		MANS: 125A MCB			MTG. SURFACE			TYPE: BOLT-ON							
USE/AND OR AREA SERVED	C/B	#A	#B	#C	CIRCUIT NO.	#A	#B	#C	C/B	USE/AND OR AREA SERVED					
EXISTING LOAD	20/1	-	-	-	1	2	-	-	20/1	RECEPTACLES-RM B123					
EXISTING LOAD	20/1	-	-	-	3	4	-	-	15/1	DENTAL CHAIR-RM B240					
DENTAL CHAIR-RM B242	15/1	-	-	-	5	6	-	-	20/1	RECEPTACLES-RM B250 PHONEBOARD					
RECEPTACLES-RM B250 PHONEBOARD	15/1	-	-	-	7	8	-	-	20/1	EXISTING LOAD					
EXISTING LOAD	20/1	-	-	-	9	10	-	-	20/1	EXISTING LOAD					
EXISTING LOAD	20/1	-	-	-	11	12	-	-	20/1	EXISTING LOAD					
EXISTING LOAD	20/1	-	-	-	13	14	-	-	15/1	DENTAL CHAIR-RM B222					
DENTAL CHAIR-RM B207	15/1	-	-	-	15	16	-	-	15/1	DENTAL CHAIR-RM B225					
DENTAL CHAIR-RM B209	15/1	-	-	-	17	18	-	-	15/1	DENTAL CHAIR-RM B219					
PANEL "CE1"	60	-	-	-	19	20	-	-	20/1	RECEPTACLES-RM B127A					
					21	22	-	-	20/1	RECEPTACLES-RM B127A					
					23	24	-	-	20/1	EXISTING LOAD					
PANEL "CE6"	50	-	-	-	25	26	-	-	20/1	EXISTING LOAD					
					27	28	-	-	20/1	EXISTING LOAD					
					29	30	-	-	20/1	EXISTING LOAD					
SPACE	20/1	-	-	-	31	32	-	-	-	SPACE					
SPACE	20/1	-	-	-	33	34	-	-	-	SPACE					
SPACE	20/1	-	-	-	35	36	-	-	-	SPACE					
SPACE	-	-	-	-	37	38	-	-	-	SPACE					
SPACE	-	-	-	-	39	40	-	-	-	SPACE					
SPACE	-	-	-	-	41	42	-	-	-	SPACE					
TOTAL PHASE "A"		-	-	-	-	-	-	-	-						
TOTAL PHASE "B"		-	-	-	-	-	-	-	-						
TOTAL PHASE "C"		-	-	-	-	-	-	-	-						
TOTAL CONNECTED LOAD:		-	-	-	-	-	-	-	-	TOTAL CONNECTED LOAD: (AMPS) _____					
		-	-	-	-	-	-	-	-	TOTAL DEMAND LOAD: (AMPS) _____					

FED FROM SWBD "DP-3" (BREAKER 6) IN ELEC. RM B128

PANELBOARD SCHEDULE _____CE6_____										LOCATION: _____RM B162A_____		C/B RATING: _____k.A.I.C._____			
VOLT/PH/W: 120/208V, 3PH, 4W		MANS: 50A MCB			MTG. SURFACE			TYPE: BOLT-ON							
USE/AND OR AREA SERVED	C/B	#A	#B	#C	CIRCUIT NO.	#A	#B	#C	C/B	USE/AND OR AREA SERVED					
DENTAL CHAIR-RM B150	15/1	-	-	-	1	2	-	-	15/1	DENTAL CHAIR-RM B195					
DENTAL CHAIR-RM B153	15/1	-	-	-	3	4	-	-	15/1	EXISTING LOAD					
DENTAL CHAIR-RM B155	15/1	-	-	-	5	6	-	-	20/1	DENTAL CHAIR-RM B192					
EXISTING LOAD	20/1	-	-	-	7	8	-	-	20/1	EXISTING LOAD					
EXISTING LOAD	20/1	-	-	-	9	10	-	-	20/1	EXISTING LOAD					
EXISTING LOAD	20/1	-	-	-	11	12	-	-	-	SPACE					
FIRE ALARM EQUIPMENT-RM B162A	20/1	-	-	-	13	14	-	-	-	SPACE					
EXISTING LOAD	20/1	-	-	-	15	16	-	-	-	SPACE					
EXISTING LOAD	20/1	-	-	-	17	18	-	-	-	SPACE					
SPACE	-	-	-	-	19	20	-	-	-	SPACE					
SPACE	-	-	-	-	21	22	-	-	-	SPACE					
EXISTING LOAD	20/1	-	-	-	23	24	-	-	-	SPACE					
SPACE	-	-	-	-	25	26	-	-	-	SPACE					
SPACE	-	-	-	-	27	28	-	-	-	SPACE					
SPACE	-	-	-	-	29	30	-	-	-	SPACE					
SPACE	-	-	-	-	31	32	-	-	-	SPACE					
SPACE	-	-	-	-	33	34	-	-	-	SPACE					
SPACE	-	-	-	-	35	36	-	-	-	SPACE					
SPACE	-	-	-	-	37	38	-	-	-	SPACE					
SPACE	-	-	-	-	39	40	-	-	-	SPACE					
SPACE	-	-	-	-	41	42	-	-	-	SPACE					
TOTAL PHASE "A"		-	-	-	-	-	-	-	-						
TOTAL PHASE "B"		-	-	-	-	-	-	-	-						
TOTAL PHASE "C"		-	-	-	-	-	-	-	-						
TOTAL CONNECTED LOAD:		-	-	-	-	-	-	-	-	TOTAL CONNECTED LOAD: (AMPS) _____					
		-	-	-	-	-	-	-	-	TOTAL DEMAND LOAD: (AMPS) _____					

FED FROM PANEL "CE3" (BREAKERS 25,27,29) IN ELEC. RM B117

PANELBOARD SCHEDULE _____DP-MECH_____										LOCATION: _____ELEC. RM F142B_____		_____k.A.I.C._____	
VOLT/PH/W: 277/480V, 3PH, 4W		MANS: 200A MLO				MTG. UNISTRUT				TYPE: BOLT-ON			
USE/AND OR AREA SERVED	C/B	#A	#B	#C	CIRCUIT NO.	#A	#B	#C	C/B	USE/AND OR AREA SERVED			
VFD-3	50	-	-	-	1	2	-	-	50	VFD-4			
	3	-	-	-	3	4	-	-	-				
		-	-	-	5	6	-	-	-				
VFD-1	30	-	-	-	7	8	-	-	30	VFD-2			
	3	-	-	-	9	10	-	-	-				
		-	-	-	11	12	-	-	-				
EF	15	-	-	-	13	14	-	-	50	COOLING TOWER			
	3	-	-	-	15	16	-	-	-				
		-	-	-	17	18	-	-	-				
SPACE	-	-	-	-	19	20	-	-	-	SPACE			
SPACE	-	-	-	-	21	22	-	-	-	SPACE			
SPACE	-	-	-	-	23	24	-	-	-	SPACE			
SPACE	-	-	-	-	25	26	-	-	-	SPACE			
SPACE	-	-	-	-	27	28	-	-	-	SPACE			
SPACE	-	-	-	-	29	30	-	-	-	SPACE			
SPACE	-	-	-	-	31	32	-	-	-	SPACE			
SPACE	-	-	-	-	33	34	-	-	-	SPACE			
SPACE	-	-	-	-	35	36	-	-	-	SPACE			
SPACE	-	-	-	-	37	38	-	-	-	SPACE			
SPACE	-	-	-	-	39	40	-	-	-	SPACE			
SPACE	-	-	-	-	41	42	-	-	-	SPACE			
TOTAL PHASE "A"	-	-	-	-	-	-	-	-	-	TOTAL CONNECTED LOAD: (AMPS) _____			
TOTAL PHASE "B"	-	-	-	-	-	-	-	-	-	TOTAL DEMAND LOAD: (AMPS) _____			
TOTAL PHASE "C"	-	-	-	-	-	-	-	-	-	_____			
TOTAL CONNECTED LOAD:	-	-	-	-	-	-	-	-	-	_____			