

PANELBOARD SCHEDULE										FE8		LOCATION: RM C131		K.A.C.I.
VOLT/PH/W: 120/208V, 3PH, 4W		MANS: 70A MCB				MTG. SURFACE				TYPE: Bolt-On				
USE/AND OR AREA SERVED	C/B	ØA	ØB	ØC	DROUT NO.	ØA	ØB	ØC	C/B	USE/AND OR AREA SERVED				
# PLUG STRIP-RM C154	20/1	-	-	-	1	2	-	-	20/1	EXISTING LOAD				
# RECEPTACLE-RM C154	20/1	-	-	-	3	4	-	-	20/1	EXISTING LOAD				
S.E. PLUG STRIP-RM C154	20/1	-	-	-	5	6	-	-	20/1	EXISTING LOAD				
S. RECEPTACLE-RM C153	30/1	-	-	-	7	8	-	-	30	EXISTING LOAD				
UNDER COUNTER RECEPTACLE-RM C153	30/1	-	-	-	9	10	-	-	2	EXISTING LOAD				
EXISTING LOAD	20/1	-	-	-	11	12	-	-	20/1	EXISTING LOAD				
EXISTING LOAD	20	-	-	-	13	14	-	-	20/1	EXISTING LOAD				
	2	-	-	-	15	16	-	-	20/1	EXISTING LOAD				
ULTRA LOW REFRIGERATOR-RM C149	20/1	-	-	-	17	18	-	-	2	EXISTING LOAD				
REFRIGERATOR 3946-RM C149	20/1	-	-	-	19	20	-	-	20/1	EXISTING LOAD				
REFRIGERATOR 3946-RM C149	20/1	-	-	-	21	22	-	-	20/1	EXISTING LOAD				
REFRIGERATOR 3946-RM C149	20/1	-	-	-	23	24	-	-	20	EXISTING LOAD				
REFRIGERATOR 3947-RM C149	20/1	-	-	-	25	26	-	-	2	EXISTING LOAD				
REFRIGERATOR 3947-RM C149	20/1	-	-	-	27	28	-	-	20/1	EXISTING LOAD				
SHIPPING ISLAND S. RECEPTACLE-RM C135	20/1	-	-	-	29	30	-	-	20/1	EXISTING LOAD				
SHIPPING ISLAND S. RECEPTACLE-RM C135	20/1	-	-	-	31	32	-	-	20/1	EXISTING LOAD				
	60	-	-	-	33	34	-	-	20/1	EXISTING LOAD				
		-	-	-	35	36	-	-	20/1	EXISTING LOAD				
	3	-	-	-	37	38	-	-	20/1	EXISTING LOAD				
EXISTING LOAD	20/1	-	-	-	39	40	-	-	20/1	EXISTING LOAD				
EXISTING LOAD	20/1	-	-	-	41	42	-	-	20/1	EXISTING LOAD				
TOTAL PHASE "A"														
TOTAL PHASE "B"														
TOTAL PHASE "C"														
TOTAL CONNECTED LOAD:														
TOTAL CONNECTED LOAD: (AMPS)														
TOTAL DEMAND LOAD: (AMPS)														

FED FROM SWBD "DP-4" (BREAKER 25) IN ELEC. RM F103

PANELBOARD SCHEDULE										FS-1		INCINERATOR BLDG		K.A.I.C.	
VOLT/PH/W: 120/208V, 3PH, 4W		MAINS: 100A MCB				MTG. SURFACE				TYPE: BQ1-ON					
USE/AND OR AREA SERVED	C/B	øA	øB	øC	CIRCUIT NO.	øA	øB	øC	C/B	USE/AND OR AREA SERVED					
SPACE	-	-	-	-	1	2	-	-	-	-	SPACE				
SPACE	-	-	-	-	3	4	-	-	-	-	SPACE				
SPACE	-	-	-	-	5	6	-	-	-	-	SPACE				
EXISTING LOAD	20/1	-	-	-	7	8	-	-	-	20/1	EXISTING LOAD				
SPARE	100	-	-	-	9	10	-	-	-	20/1	EXISTING LOAD				
	2	-	-	-	11	12	-	-	-	20/1	EXISTING LOAD				
EXISTING LOAD	20/1	-	-	-	13	14	-	-	-	20/1	EXISTING LOAD				
EXISTING LOAD	20/1	-	-	-	15	16	-	-	-	20	EXISTING LOAD				
SPACE	-	-	-	-	17	18	-	-	-	2					
SPACE	-	-	-	-	19	20	-	-	-	-	SPACE				
SPACE	-	-	-	-	21	22	-	-	-	-	SPACE				
SPACE	-	-	-	-	23	24	-	-	-	-	SPACE				
SPACE	-	-	-	-	25	26	-	-	-	-	SPACE				
SPACE	-	-	-	-	27	28	-	-	-	-	SPACE				
SPACE	-	-	-	-	29	30	-	-	-	-	SPACE				
SPACE	-	-	-	-	31	32	-	-	-	-	SPACE				
SPACE	-	-	-	-	33	34	-	-	-	-	SPACE				
SPACE	-	-	-	-	35	36	-	-	-	-	SPACE				
SPACE	-	-	-	-	37	38	-	-	-	-	SPACE				
SPACE	-	-	-	-	39	40	-	-	-	-	SPACE				
SPACE	-	-	-	-	41	42	-	-	-	-	SPACE				
TOTAL PHASE "A"	-	-	-	-	-	-	-	-	-	-					
TOTAL PHASE "B"	-	-	-	-	-	-	-	-	-	-					
TOTAL PHASE "C"	-	-	-	-	-	-	-	-	-	-					
TOTAL CONNECTED LOAD:	-	-	-	-	-	-	-	-	-	-	TOTAL CONNECTED LOAD: (AMPS)	-	-	-	-
	-	-	-	-	-	-	-	-	-	-	TOTAL DEMAND LOAD: (AMPS)	-	-	-	-

FED FROM PANEL "LSE-3" (BREAKERS 35,37,39) IN ELEC. RM F146

PANELBOARD SCHEDULE										LOCATION: RM F109		K.A.I.C.	
G										C/B RATING: --			
WOLT/PH/N: 120/208V, 3PH, 4W		MAINS: 150A MLO				MTG. RECESSED				TYPE: BQLT-ON			
USE/AND OR AREA SERVED		C/B	ΦA	ΦB	ΦC	CIRCUIT NO.	ΦA	ΦB	ΦC	C/B	USE/AND OR AREA SERVED		
EXISTING LOAD		20/1	--	--	--	1	2	--	--	20/1	EXISTING LOAD		
EXISTING LOAD		20/1	--	--	--	3	4	--	--	20/1	EXISTING LOAD		
EXISTING LOAD		20/1	--	--	--	5	6	--	--	20/1	EXISTING LOAD		
EXISTING LOAD		20/1	--	--	--	7	8	--	--	20/1	EXISTING LOAD		
EXISTING LOAD		20/1	--	--	--	9	10	--	--	20/1	EXISTING LOAD		
EXISTING LOAD		20/1	--	--	--	11	12	--	--	20/1	EXISTING LOAD		
EXISTING LOAD		20/1	--	--	--	13	14	--	--	20/1	EXISTING LOAD		
EXISTING LOAD		20/1	--	--	--	15	16	--	--	20/1	EXISTING LOAD		
EXISTING LOAD		20/1	--	--	--	17	18	--	--	20/1	EXISTING LOAD		
EXISTING LOAD		20/1	--	--	--	19	20	--	--	20/1	SPARE		
EXISTING LOAD		20/1	--	--	--	21	22	--	--	20/1	SPARE		
EXISTING LOAD		20/1	--	--	--	23	24	--	--	20/1	EXISTING LOAD		
SPARE		20/1	--	--	--	25	26	--	--	20/1	SPARE		
SPARE		20/1	--	--	--	27	28	--	--	20/1	SPARE		
EXISTING LOAD		20/1	--	--	--	29	30	--	--	20/1	SPARE		
SPACE		--	--	--	--	31	32	--	--	20/1	SPARE		
SPARE		20	--	--	--	33	34	--	--	20/1	SPARE		
		2	--	--	--	35	36	--	--	20/1	SPARE		
SPARE		20	--	--	--	37	38	--	--	30	SPARE		
		--	--	--	--	39	40	--	--	--			
		3	--	--	--	41	42	--	--	3			
TOTAL PHASE "A"		--	--	--	--	--	--	--	--				
TOTAL PHASE "B"		--	--	--	--	--	--	--	--				
TOTAL PHASE "C"		--	--	--	--	--	--	--	--				
TOTAL CONNECTED LOAD:		--	--	--	--	--	--	--	--	TOTAL CONNECTED LOAD: (AMPS)		--	
		--	--	--	--	--	--	--	--	TOTAL DEMAND LOAD: (AMPS)		--	

FED FROM SWBD "DP-4" (BREAKER 32) IN ELEC. RM F103

PANELBOARD SCHEDULE										HA-1		ELEC. RM A209		K.A.I.C.		
VOLT./PH./W. 120/208V, 3PH, 4W					MAINS: 70A MCB			MTG. SURFACE			C/B RATINGS: -				TYPE: BOLT-ON	
USE/AND OR AREA SERVED	C/B	øA	øB	øC	CIRCUIT NO.	øA	øB	øC	C/B	USE/AND OR AREA SERVED						
SPACE	-	-	-	-	1	2	-	-	-	SPACE						
SPACE	-	-	-	-	3	4	-	-	-	SPACE						
SPACE	-	-	-	-	5	6	-	-	-	SPACE						
EXISTING LOAD	20/1	-	-	-	7	8	-	-	20/1	EXISTING LOAD						
EXISTING LOAD	20/1	-	-	-	9	10	-	-	20/1	EXISTING LOAD						
EXISTING LOAD	20/1	-	-	-	11	12	-	-	20/1	EXISTING LOAD						
EXISTING LOAD	20/1	-	-	-	13	14	-	-	20/1	EXISTING LOAD						
EXISTING LOAD	20/1	-	-	-	15	16	-	-	20/1	EXISTING LOAD						
EXISTING LOAD	20/1	-	-	-	17	18	-	-	20/1	EXISTING LOAD						
EXISTING LOAD	20/1	-	-	-	19	20	-	-	20/1	EXISTING LOAD						
EXISTING LOAD	20/1	-	-	-	21	22	-	-	20/1	EXISTING LOAD						
EXISTING LOAD	20/1	-	-	-	23	24	-	-	20/1	EXISTING LOAD						
EXISTING LOAD	20/1	-	-	-	25	26	-	-	20/2	EXISTING LOAD						
SPACE	-	-	-	-	27	28	-	-	-							
SPACE	-	-	-	-	29	30	-	-	-	SPACE						
SPACE	-	-	-	-	31	32	-	-	-	SPACE						
SPACE	-	-	-	-	33	34	-	-	-	SPACE						
SPACE	-	-	-	-	35	36	-	-	-	SPACE						
SPACE	-	-	-	-	37	38	-	-	-	SPACE						
SPACE	-	-	-	-	39	40	-	-	-	SPACE						
SPACE	-	-	-	-	41	42	-	-	-	SPACE						
TOTAL PHASE "A"	-	-	-	-	-	-	-	-	-	TOTAL PHASE "B"						
TOTAL PHASE "B"	-	-	-	-	-	-	-	-	-	TOTAL PHASE "C"						
TOTAL PHASE "C"	-	-	-	-	-	-	-	-	-	TOTAL CONNECTED LOAD: (AMPS)	-					
TOTAL CONNECTED LOAD:	-	-	-	-	-	-	-	-	-	TOTAL DEMAND LOAD: (AMPS)	-					

FED FROM SWBD "DP-2" (BREAKER 10) IN ELEC. RM B128

PANELBOARD SCHEDULE										HB		LOCATION: ELEC. RM B227		K.A.I.C.	
VOLT/PH/W: 277/480V, 3PH, 4W		MANS: 100A MLO					MTG: RECESSED			TYPE: BOLT-ON					
USE /AND OR AREA SERVED		C/B	ΦA	ΦB	ΦC	CIRCUIT NO.	ΦA	ΦB	ΦC	C/B	USE /AND OR AREA SERVED				
EXISTING LOAD		20/1	—	—	—	1	2	—	—	20/1	EXISTING LOAD				
EXISTING LOAD		20/1	—	—	—	3	4	—	—	20/1	EXISTING LOAD				
SPARE		20/1	—	—	—	5	6	—	—	20/1	EXISTING LOAD				
SPARE		20/1	—	—	—	7	8	—	—	20/1	EXISTING LOAD				
SPARE		20/1	—	—	—	9	10	—	—	20/1	EXISTING LOAD				
EXISTING LOAD		20/1	—	—	—	11	12	—	—	20/1	EXISTING LOAD				
SPARE		20/1	—	—	—	13	14	—	—	20/1	SPARE				
SPARE		20/1	—	—	—	15	16	—	—	20/1	SPARE				
SPARE		20/1	—	—	—	17	18	—	—	20/1	SPARE				
SPARE		20/1	—	—	—	19	20	—	—	—	SPACE				
SPACE		—	—	—	—	21	22	—	—	—	SPACE				
SPACE		—	—	—	—	23	24	—	—	—	SPACE				
SPACE		—	—	—	—	25	26	—	—	—	SPACE				
SPACE		—	—	—	—	27	28	—	—	—	SPACE				
SPACE		—	—	—	—	29	30	—	—	—	SPACE				
TOTAL PHASE "A" —															
TOTAL PHASE "B" —															
TOTAL PHASE "C" —															
TOTAL CONNECTED LOAD: (AMPS) —															
TOTAL DEMAND LOAD: (AMPS) —															

FED FROM PANEL "HC" (BREAKERS 2,4,6) IN ELEC. RM B117

PANELBOARD SCHEDULE										HC	LOCATION: RM B117		K.A.I.C.
											C/B RATING: -		
VOLT/PH/W: 277/480V, 3PH, 4W		MAINS: 125A MCB					MTG. SURFACE			TYPE: BOLT-ON			
USE/AND OR AREA SERVED	C/B	ΦA	ΦB	ΦC	CIRCUIT NO.	ΦA	ΦB	ΦC	C/B	USE/AND OR AREA SERVED			
EXISTING LOAD	20/1	-	-	-	1	2	-	-	70	PANEL "B"			
EXISTING LOAD	20/1	-	-	-	3	4	-	-	-				
EXISTING LOAD	20/1	-	-	-	5	6	-	-	3				
EXISTING LOAD	20/1	-	-	-	7	8	-	-	100				
EXISTING LOAD	20/1	-	-	-	9	10	-	-	-	SPARE			
EXISTING LOAD	20/1	-	-	-	11	12	-	-	3				
SPACE	-	-	-	-	13	14	-	-	-	SPACE			
SPACE	-	-	-	-	15	16	-	-	-				
SPACE	-	-	-	-	17	18	-	-	-				
SPACE	-	-	-	-	19	20	-	-	-				
SPACE	-	-	-	-	21	22	-	-	-				
SPACE	-	-	-	-	23	24	-	-	-				
SPACE	-	-	-	-	25	26	-	-	-				
SPACE	-	-	-	-	27	28	-	-	-				
SPACE	-	-	-	-	29	30	-	-	-				
SPACE	-	-	-	-	31	32	-	-	-				
SPACE	-	-	-	-	33	34	-	-	-				
SPACE	-	-	-	-	35	36	-	-	-				
SPACE	-	-	-	-	37	38	-	-	-				
SPACE	-	-	-	-	39	40	-	-	-				
SPACE	-	-	-	-	41	42	-	-	-				
TOTAL PHASE "A"		-		-		-		-		TOTAL CONNECTED LOAD: (AMPS) -			
TOTAL PHASE "B"		-		-		-		-					
TOTAL PHASE "C"		-		-		-		-					
TOTAL CONNECTED LOAD:		-		-		-		-		TOTAL DEMAND LOAD: (AMPS) -			

PANELBOARD SCHEDULE										HD		LOCATION: RM B16A		C/B RATING: —		k.A.I.C.	
VOLT/PH/W: 277/480, 3PH, 4W		MANG: 200A MLO					MTG. SURFACE					TYPE: BOLT-ON					
USE/AND OR AREA SERVED		C/B	ΦA	ΦB	ΦC	ORCUT NO	1	2	—	ΦA	ΦB	ΦC	C/B	USE/AND OR AREA SERVED			
LIGHTS-RMS B163, B194-96, B207		20/1	—	—	—	3	4	—	—	—	—	—	20/1	SPARE			
LIGHTS-RMS B157,58,62A,64,66, B189-91		20/1	—	—	—	5	6	—	—	—	—	—	20/1	SPARE			
SPARE		20/1	—	—	—	5	6	—	—	—	—	—	20/1	SPARE			
LIGHTS-RMS B169, 170		20/1	—	—	—	7	8	—	—	—	—	—	20/1	SPARE			
LIGHTS-RMS B140,145,148,167A, B230,231,246		20/1	—	—	—	9	10	—	—	—	—	40	3	WASHER-RM B205			
LIGHTS- RM B147		20/1	—	—	—	11	12	—	—	—	—	—					
EXTERIOR LIGHTS-WEST WALL		20/1	—	—	—	13	14	—	—	—	—	—	3	STERS-STERILIZER #1 DIPC-RM B198			
STERS STERILIZER #2-RM B198		50	—	—	—	15	16	—	—	—	—	50					
		3	—	—	—	19	20	—	—	—	—	—	3				
SPARE		20/1	—	—	—	21	22	—	—	—	—	—	20/1	SPARE			
SPARE		20/1	—	—	—	23	24	—	—	—	—	—	20/1	SPARE			
SPACE		—	—	—	—	25	26	—	—	—	—	—	—	SPACE			
SPACE		—	—	—	—	27	28	—	—	—	—	—	—	SPACE			
SPACE		—	—	—	—	29	30	—	—	—	—	—	—	SPACE			
TOTAL PHASE "A"		—		—		—		—		—		—					
TOTAL PHASE "B"		—		—		—		—		—		—					
TOTAL PHASE "C"		—		—		—		—		—		—					
TOTAL CONNECTED LOAD:		—		—		—		—		—		—		TOTAL CONNECTED LOAD: (AMPS) —			
		—		—		—		—		—		—		TOTAL DEMAND LOAD: (AMPS) —			

FED FROM SWBD DP-2 (BREAKER 6) IN ELEC. RM B128

PANELBOARD SCHEDULE										HG			LOCATION: RM G191			C/B RATING: -		K.A.I.C.	
VOLT/PH/NO: 277/480V, 3PH, 4W		MANS: 100A MLO					MTG: RECESSED					TYPE: BOLT-ON							
USE/AND OR AREA SERVED		C/B	ØA	ØB	ØC	CIRCUIT NO	ØA	ØB	ØC	C/B	USE/AND OR AREA SERVED								
LTS-RMS 173 THRU 177		20/1	-	-	-	1 2	-	-	-	20/1	LTS-CORRIDORS A & D								
LTS-RMS 182 THRU 187		20/1	-	-	-	3 4	-	-	-	20/1	LTS-CORRIDORS B & C								
LTS-RMS 190, 191, 192		20/1	-	-	-	5 6	-	-	-	20/1	DUCT HEATER								
SPACE		20/1	-	-	-	7 8	-	-	-	20/1	SPACE								
SPACE		20/1	-	-	-	9 10	-	-	-	20/1	SPACE								
SPACE		20/1	-	-	-	11 12	-	-	-	20/1	SPACE								
SPACE		20/1	-	-	-	13 14	-	-	-	20/1	SPACE								
SPACE		20/1	-	-	-	15 16	-	-	-	20/1	SPACE								
SPACE		20/1	-	-	-	17 18	-	-	-	20/1	SPACE								
SPACE		20/1	-	-	-	19 20	-	-	-	20/1	SPACE								
SPACE		20/1	-	-	-	21 22	-	-	-	20/1	SPACE								
SPACE		20/1	-	-	-	23 24	-	-	-	20/1	SPACE								
SPACE		20/1	-	-	-	25 26	-	-	-	20/1	SPACE								
EXISTING LOAD		30	-	-	-	27 28	-	-	-	20/1	SPACE								
		2	-	-	-	29 30	-	-	-	20/1	SPACE								
EXISTING LOAD		30	-	-	-	31 32	-	-	-	30	EXISTING LOAD								
		2	-	-	-	33 34	-	-	-	2									
SPACE		-	-	-	-	35 36	-	-	-	-	SPACE								
SPACE		-	-	-	-	37 38	-	-	-	-	SPACE								
SPACE		-	-	-	-	39 40	-	-	-	-	SPACE								
SPACE		-	-	-	-	41 42	-	-	-	-	SPACE								
TOTAL PHASE "A"		-	-	-	-	-	-	-	-	-	-								
TOTAL PHASE "B"		-	-	-	-	-	-	-	-	-	-								
TOTAL PHASE "C"		-	-	-	-	-	-	-	-	-	-								
TOTAL CONNECTED LOAD:		-	-	-	-	-	-	-	-	-	TOTAL CONNECTED LOAD: (AMPS) -								
		-	-	-	-	-	-	-	-	-	TOTAL DEMAND LOAD: (AMPS) -								

FED FROM MSB SECTION 1 (BREAKER 18) IN MAIN SWGR RM F147

PANELBOARD SCHEDULE										K		LOCATION: RM F142B C/B RATING: -		K.A.I.C.	
VOLT/PH/W: 120/208V, 3PH, 4W		MAINS: 100A MCB					MTC: SURFACE			TYPE: BOLT-ON					
USE/AND OR AREA SERVED	C/B	ØA	ØB	ØC	CIRCUIT NO.	ØA	ØB	ØC	C/B	USE/AND OR AREA SERVED					
EXISTING LOAD	20/1	-	-	-	1	2	-	-	20/1	EXISTING LOAD					
EXISTING LOAD	20/1	-	-	-	3	4	-	-	20/1	EXISTING LOAD					
EXISTING LOAD	20/1	-	-	-	5	6	-	-	20/1	EXISTING LOAD					
SPARE	20/1	-	-	-	7	8	-	-	20/1	EXISTING LOAD					
EXISTING LOAD	20/1	-	-	-	9	10	-	-	20/1	EXISTING LOAD					
SPARE	20/1	-	-	-	11	12	-	-	20/1	SPARE					
SPARE	20/1	-	-	-	13	14	-	-	20/1	EXISTING LOAD					
EXISTING LOAD	20/1	-	-	-	15	16	-	-	20/1	EXISTING LOAD					
SPARE	20/1	-	-	-	17	18	-	-	20/1	EXISTING LOAD					
EXISTING LOAD	20/1	-	-	-	19	20	-	-	20/1	SPARE					
					21	22	-	-	50						
EXISTING LOAD	20/1	-	-	-	23	24	-	-	3	EXISTING LOAD					
SPARE	20/1	-	-	-	25	26	-	-	30/2	EXISTING LOAD					
EXISTING LOAD	20/1	-	-	-	27	28	-	-							
EXISTING LOAD	20/1	-	-	-	29	30	-	-	2						
EXISTING LOAD	20/1	-	-	-	31	32	-	-	20/1	EXISTING LOAD					
EXISTING LOAD	20/1	-	-	-	33	34	-	-	20/1	SPARE					
SPARE	20/1	-	-	-	35	36	-	-	20/1	EXISTING LOAD					
EXISTING LOAD	20/1	-	-	-	37	38	-	-	20/1	EXISTING LOAD					
					39	40	-	-	20/1						
SPARE	20/1	-	-	-	41	42	-	-	20/1	EXISTING LOAD					
TOTAL PHASE "A"	-	-	-	-	-	-	-	-	-	-					
TOTAL PHASE "B"	-	-	-	-	-	-	-	-	-	-					
TOTAL PHASE "C"	-	-	-	-	-	-	-	-	-	-					
TOTAL CONNECTED LOAD:	-	-	-	-	-	-	-	-	-	TOTAL CONNECTED LOAD: (AMPS)					
	-	-	-	-	-	-	-	-	-	TOTAL DEMAND LOAD: (AMPS)					

PANEL KEY		
EE8	HA-1	HD
ES-1	HB	HG
G	HC	K
—	—	—

NOTICE: THIS IS THE PERSONAL PROPERTY OF KROESCHELL ENGINEERING CO. (NOTE 1)
AND ALL USE IS FORBIDDEN EXCEPT UPON WRITTEN CONSENT.