

PANELBOARD SCHEDULE _____ KP										LOCATION: _____ RM F133	C/B RATING: _____ k.A.I.C.
VOLT/PH/W: 120/208V, 3PH, 4W	MANS: 225A MLO			MTG: RECESSED			TYPE: BOLT-ON				
USE/AND OR AREA SERVED	C/B	#A	#B	#C	CIRCUIT NO.	#A	#B	#C	C/B	USE/AND OR AREA SERVED	
SPARE	20/1	—	—	—	1 2	—	—	—	20/1	EXISTING LOAD	
SPARE	20/1	—	—	—	3 4	—	—	—	20/1	EXISTING LOAD	
SPARE	20/1	—	—	—	5 6	—	—	—	20/1	SPARE	
SPARE	20/1	—	—	—	7 8	—	—	—	20/1	SPARE	
SPARE	20/1	—	—	—	9 10	—	—	—	20/1	SPARE	
SPARE	20/1	—	—	—	11 12	—	—	—	20/1	SPARE	
SPARE	20/1	—	—	—	13 14	—	—	—	20/1	SPARE	
SPARE	20/1	—	—	—	15 16	—	—	—	20/1	SPARE	
SPARE	20/1	—	—	—	17 18	—	—	—	20/1	SPARE	
SPARE	20/1	—	—	—	19 20	—	—	—	20/1	SPARE	
SPARE	20/1	—	—	—	21 22	—	—	—	20/1	SPARE	
SPARE	20/1	—	—	—	23 24	—	—	—	20/1	SPARE	
SPARE	20/1	—	—	—	25 26	—	—	—	20/1	SPARE	
SPARE	20/1	—	—	—	27 28	—	—	—	60	SPARE	
SPARE	20/1	—	—	—	29 30	—	—	—	20/1		
SPARE	20/1	—	—	—	31 32	—	—	—	3	SPARE	
SPARE	30	—	—	—	33 34	—	—	—	60		
SPARE	2	—	—	—	35 36	—	—	—	—	SPARE	
	100	—	—	—	37 38	—	—	—	3		
PANEL "SC"		—	—	—	39 40	—	—	—	80	EXISTING LOAD	
	3	—	—	—	41 42	—	—	—	2		
TOTAL PHASE "A"	—	—	—	—	—	—	—	—	—		
TOTAL PHASE "B"	—	—	—	—	—	—	—	—	—		
TOTAL PHASE "C"	—	—	—	—	—	—	—	—	—		
TOTAL CONNECTED LOAD:	—	—	—	—	—	—	—	—	—	TOTAL CONNECTED LOAD: (AMPS)	—
	—	—	—	—	—	—	—	—	—	TOTAL DEMAND LOAD: (AMPS)	—

FED FROM SWBD "DP-1" (BREAKER 14) IN MAIN SWGR RM F147

PANELBOARD SCHEDULE _____ LA										LOCATION: _____ ELEC. RM A209	C/B RATING: _____ k.A.I.C.
VOLT/PH/W: 120/208V, 3PH, 4W	MANS: 100A MCB			MTG: SURFACE			TYPE: BOLT-ON				
USE/AND OR AREA SERVED	C/B	#A	#B	#C	CIRCUIT NO.	#A	#B	#C	C/B	USE/AND OR AREA SERVED	
RECEPTACLES-RM A110	20/1	—	—	—	1 2	—	—	—	20/1	RECEPTACLES-RM A110	
RECEPTACLES-RMS A104, 109A, 110	20/1	—	—	—	3 4	—	—	—	20/1	RECEPTACLES-RM A110	
RECEPTACLES-RM A151	20/1	—	—	—	5 6	—	—	—	20/1	RECEPTACLES-RMS A104, 110	
RECEPTACLES-RMS A109C, 109D, 111	20/1	—	—	—	7 8	—	—	—	20/1	RECEPTACLES-RM A104	
POWER POLE RECEPTACLES-RM A104	20/1	—	—	—	9 10	—	—	—	20/1	RECEPTACLES-RM A104	
EXISTING LOAD	20/1	—	—	—	11 12	—	—	—	20/1	RECEPTACLES-RMS A117, 118	
EXISTING LOAD	20/1	—	—	—	13 14	—	—	—	20/1	RECEPTACLES-RMS A113, 120, 199	
RECEPTACLES-RMS A126, 127, 128	20/1	—	—	—	15 16	—	—	—	20/1	RECEPTACLES-RM A132	
RECEPTACLES-RMS A129, 131	20/1	—	—	—	17 18	—	—	—	20/1	RECEPTACLES-RM A133	
RECEPTACLES-RM A124	20/1	—	—	—	19 20	—	—	—	30/1	RECEPTACLES-RM A133	
RECEPTACLES-RMS A205, 206	20/1	—	—	—	21 22	—	—	—	20/1	RECEPTACLES-RM A207	
TWIST-LOCK RECEPTACLES-RM A210	30/1	—	—	—	23 24	—	—	—	20/1	RECEPTACLES-RMS A122, 123	
TWIST-LOCK RECEPTACLES-RM A210	20/1	—	—	—	25 26	—	—	—	20/1	RECEPTACLE-RM A209	
RECEPTACLES-RM A240	20/1	—	—	—	27 28	—	—	—	20/1	RECEPTACLE-WOMENS TOILET A121	
RECEPTACLES-RMS A109A, 109B, 126	20/1	—	—	—	29 30	—	—	—	30/1	RECEPTACLES-RMS A100, 103	
RECEPTACLES-MENS TOILET A238	20/1	—	—	—	31 32	—	—	—	20/1	LFS-UNIT A2	
LIGHTS-PED ENTRANCE	20/1	—	—	—	33 34	—	—	—	20/1	LIGHTS, RECEPTACLES-ELEVATOR PIT	
V-BOX RM A119	20/1	—	—	—	35 36	—	—	—	20/1	WC-RM A103	
EXISTING LOAD	20/1	—	—	—	37 38	—	—	—	20/1	REFRIGERATOR-IMMUNIZATION RM A124	
EXISTING LOAD	20/1	—	—	—	39 40	—	—	—	20/1	EXISTING LOAD	
SPARE	20/1	—	—	—	41 42	—	—	—	30/1	FA PANEL-RM A209	
TOTAL PHASE "A"	—	—	—	—	—	—	—	—	—		
TOTAL PHASE "B"	—	—	—	—	—	—	—	—	—		
TOTAL PHASE "C"	—	—	—	—	—	—	—	—	—		
TOTAL CONNECTED LOAD:	—	—	—	—	—	—	—	—	—	TOTAL CONNECTED LOAD: (AMPS)	—
	—	—	—	—	—	—	—	—	—	TOTAL DEMAND LOAD: (AMPS)	—

FED FROM SWBD "DP-3" (BREAKER 13) IN ELEC. RM B128

PANELBOARD SCHEDULE _____ LB										LOCATION: _____ ELEC. RM A209	C/B RATING: _____ k.A.I.C.
VOLT/PH/W: 120/208V, 3PH, 4W	MANS: 125A MCB			MTG: SURFACE			TYPE: BOLT-ON				
USE/AND OR AREA SERVED	C/B	#A	#B	#C	CIRCUIT NO.	#A	#B	#C	C/B	USE/AND OR AREA SERVED	
RECEPTACLES-RMS A198,203,207, CORRIDOR	20/1	—	—	—	1 2	—	—	—	20/1	RECEPTACLES-RMS A201, 202	
RECEPTACLES-RMS A136,142,153, CORRIDOR	20/1	—	—	—	3 4	—	—	—	20/1	RECEPTACLES-RMS A137, 138	
RECEPTACLES-RMS A140,143, CORRIDOR	20/1	—	—	—	5 6	—	—	—	20/1	LIGHTS EXIT, OUTSIDE SOUTH ENTRANCE	
RECEPTACLES-RM A143, CORR. WATER COOLER	20/1	—	—	—	7 8	—	—	—	20/1	RECEPTACLES-SOUTH ENTRANCE	
RECEPTACLES-RMS A151, 152	20/1	—	—	—	9 10	—	—	—	20/1	RECEPTACLES-RMS A163, 164	
RECEPTACLES-RMS A165, 166	20/1	—	—	—	11 12	—	—	—	20/1	RECEPTACLES-RMS A167, 168	
RECEPTACLES-RMS A177, 178	20/1	—	—	—	13 14	—	—	—	20/1	RECEPTACLES-RMS A180,182,A176 CORRIDOR	
RECEPTACLES-RM A187	20/1	—	—	—	15 16	—	—	—	20/1	RECEPTACLES-RM A194	
RECEPTACLES-WAITING RM A196	20/1	—	—	—	17 18	—	—	—	20/1	RECEPTACLES-RMS A184,192,195,CORRIDOR	
RECEPTACLES-RMS A184, 191, CORRIDOR	20/1	—	—	—	19 20	—	—	—	20/1	RECEPTACLES-RM A173	
RECEPTACLES-RMS A171, 172	20/1	—	—	—	21 22	—	—	—	20/1	RECEPTACLES-RM A152	
EXISTING LOAD	20/1	—	—	—	23 24	—	—	—	20/1	RECEPTACLES-RMS A151,152	
EXISTING LOAD	20/1	—	—	—	25 26	—	—	—	20/1	LED SIGN-ENTRANCE	
EXISTING LOAD	20/1	—	—	—	27 28	—	—	—	20/1	LED SIGN-SOUTH ENTRANCE	
EXHAUST FAN 10	20/1	—	—	—	29 30	—	—	—	20/1	REFRIGERATOR-RM A187	
RIGHT TREADMILL-RM A140	20	—	—	—	31 32	—	—	—	20/1	LED SIGN-SOUTH ENTRANCE	
	2	—	—	—	33 34	—	—	—	20/1	EXISTING LOAD	
	80	—	—	—	35 36	—	—	—	20/1	AUTO DOORS-SOUTH ENTRANCE	
LEFT TREADMILL-RM A140	2	—	—	—	37 38	—	—	—	20/1	RECEPTACLES-RMS A150, A151	
EXISTING LOAD	30/1	—	—	—	39 40	—	—	—	20/1	EXISTING LOAD	
EXISTING LOAD	20/1	—	—	—	41 42	—	—	—	20/1	EXISTING LOAD	
TOTAL PHASE "A"	—	—	—	—	—	—	—	—	—		
TOTAL PHASE "B"	—	—	—	—	—	—	—	—	—		
TOTAL PHASE "C"	—	—	—	—	—	—	—	—	—		
TOTAL CONNECTED LOAD:	—	—	—	—	—	—	—	—	—	TOTAL CONNECTED LOAD: (AMPS)	—
	—	—	—	—	—	—	—	—	—	TOTAL DEMAND LOAD: (AMPS)	—

FED FROM SWBD "DP-3" (BREAKER 12) IN ELEC. RM B128

PANELBOARD SCHEDULE _____ LC										LOCATION: _____ ELEC. RM A209	C/B RATING: _____ k.A.I.C.
VOLT/PH/W: 120/208V, 3PH, 4W	MANS: 100A MCB			MTG: SURFACE			TYPE: BOLT-ON				
USE/AND OR AREA SERVED	C/B	#A	#B	#C	CIRCUIT NO.	#A	#B	#C	C/B	USE/AND OR AREA SERVED	
RECEPTACLES-RM A241	20/1	—	—	—	1 2	—	—	—	20/1	RECEPTACLES-RMS A242, 243, 252	
RECEPTACLES-RMS A253, 254	20/1	—	—	—	3 4	—	—	—	20/1	RECEPTACLES-RMS A255, 256	
RECEPTACLES-RMS A263, 264	20/1	—	—	—	5 6	—	—	—	20/1	RECEPTACLES-RMS A263, 264	
RECEPTACLES-RM A265	20/1	—	—	—	7 8	—	—	—	20/1	RECEPTACLES-RMS A266, 266A	
RECEPTACLES-RM A266A	20/1	—	—	—	9 10	—	—	—	20/1	RECEPTACLES-RM A244	
WATER COOLER-CORRIDOR A260	20/1	—	—	—	11 12	—	—	—	20/1	RECEPTACLES-RM A242	
RECEPTACLES-RMS A247, 248	20/1	—	—	—	13 14	—	—	—	20/1	RECEPTACLES-RMS A250, 251	
RECEPTACLES-RM A210	20/1	—	—	—	15 16	—	—	—	20/1	RECEPTACLES-RMS A210, 212	
RECEPTACLES-RM A214	20/1	—	—	—	17 18	—	—	—	20/1	RECEPTACLES-RMS A223, 224	
RECEPTACLES-RMS A226, 227, 228	20/1	—	—	—	19 20	—	—	—	20/1	RECEPTACLES-RMS A231, 232	
RECEPTACLES-CORRIDOR A230	20/1	—	—	—	21 22	—	—	—	20/1	EXISTING LOAD	
RECEPTACLES-RM A235	20/1	—	—	—	23 24	—	—	—	20/1	EXISTING LOAD	
RECEPTACLES-RMS A217, 219	20/1	—	—	—	25 26	—	—	—	20/1	RECEPTACLES-RMS A216, 217	
REFRIGERATOR-RM A250	20/1	—	—	—	27 28	—	—	—	20/1	EXISTING LOAD	
RECEPTACLES-RM A100	20/1	—	—	—	29 30	—	—	—	20/1	UNDER COUNTER RECEPTACLES-RM A244	
RECEPTACLES-RM A100	20/1	—	—	—	31 32	—	—	—	30	AC UNIT-RM A210	
SPACE	—	—	—	—	33 34	—	—	—	2		
SPACE	—	—	—	—	35 36	—	—	—	20/1	RECEPTACLES-RM A198	
SPACE	—	—	—	—	37 38	—	—	—	20/1	RECEPTACLES-COMM. RM A210	
SPACE	—	—	—	—	39 40	—	—	—	20/1	RECEPTACLES-COMM. RM A210	
SPACE	—	—	—	—	41 42	—	—	—	—	SPACE	
TOTAL PHASE "A"	—	—	—	—	—	—	—	—	—		
TOTAL PHASE "B"	—	—	—	—	—	—	—	—	—		
TOTAL PHASE "C"	—	—	—	—	—	—	—	—	—		
TOTAL CONNECTED LOAD:	—	—	—	—	—	—	—	—	—	TOTAL CONNECTED LOAD: (AMPS)	—
	—	—	—	—	—	—	—	—	—	TOTAL DEMAND LOAD: (AMPS)	—

FED FROM SWBD "DP-3" (BREAKER 8) IN ELEC. RM B128

PANELBOARD SCHEDULE										LD		LOCATION: CORRIDOR B227		C/B RATING: _____		k.A.I.C.			
VOLT/PH/W: 120/208V, 3PH, 4W		MANS: 125A MLO						MTG: RECESSED						TYPE: BOLT-ON					
USE/AND OR AREA SERVED		C/B	#A	#B	#C	CIRCUIT NO.	#A	#B	#C	C/B	USE/AND OR AREA SERVED								
RECEPTACLES-RM B249		20/1	—	—	—	1 2	—	—	—	20/1	RECEPTACLES-RMS B246, B247								
RECEPTACLES-RMS B246, B248		20/1	—	—	—	3 4	—	—	—	20/1	RECEPTACLES-RMS B243, B244								
RECEPTACLES-RMS B231, B233, B234		20/1	—	—	—	5 6	—	—	—	20/1	RECEPTACLES-RMS B235, B236								
RECEPTACLES-RM B235		20/1	—	—	—	7 8	—	—	—	20/1	RECEPTACLES-RMS B233, B237								
RECEPTACLES-RM B239		20/1	—	—	—	9 10	—	—	—	15/1	DENTAL CHAIR-RM B239								
RECEPTACLES-RM B240		20/1	—	—	—	11 12	—	—	—	15/1	LIFE SKILLS DRESS' SYSTEM								
RECEPTACLES-RM B241		20/1	—	—	—	13 14	—	—	—	15/1	DENTAL CHAIR-RM B241								
RECEPTACLES-RM B242		20/1	—	—	—	15 16	—	—	—	20/1	AIR COMP. MONITOR WATER PURIFIER								
DENTAL CHAIR-RM B243		15/1	—	—	—	17 18	—	—	—	20/1	RECEPTACLES-WAITING RM B102								
RECEPTACLES-RM B245 TOILET		20/1	—	—	—	19 20	—	—	—	20/1	EXISTING LOAD								
RECEPTACLES-RMS B100, B251		20/1	—	—	—	21 22	—	—	—	20/1	RECEPTACLES-RMS B100, B134								
RECEPTACLES-TV RM B100		20/1	—	—	—	23 24	—	—	—	20/1	WATER COOLER-RM B100								
RECEPTACLES-RECEPTION B224		20/1	—	—	—	25 26	—	—	—	20/1	RECEPTACLES-RMS B111, B113								
RECEPTACLES-RMS B112, B114		20/1	—	—	—	27 28	—	—	—	20/1	RECEPTACLES-RMS B109, B111								
RECEPTACLES-RMS B104, B106, B108		20/1	—	—	—	29 30	—	—	—	20/1	RECEPTACLES-RM B103								
RECEPTACLES-RMS B104, B106		20/1	—	—	—	31 32	—	—	—	20/1	RECEPTACLES-RMS B105, B107								
EXHAUST FAN (EF-1)		15/1	—	—	—	33 34	—	—	—	20/1	RECEPTACLES-RMS B110, B112								
X-RAY WALL UNIT-RM B240		20/1	—	—	—	35 36	—	—	—	20/1	RECEPTACLES-RM								
UNDER COUNTER RECEPTACLES-RM B229		20/1	—	—	—	37 38	—	—	—	20/1	EXISTING LOAD								
UNDER COUNTER RECEPTACLES-RM B229		20/1	—	—	—	39 40	—	—	—	20/1	EXISTING LOAD								
EXISTING LOAD		20/1	—	—	—	41 42	—	—	—	20/1	EXISTING LOAD								
TOTAL PHASE "A"		—		—		—		—		TOTAL CONNECTED LOAD: (AMPS)		—		—					
TOTAL PHASE "B"		—		—		—		—		TOTAL CONNECTED LOAD: (AMPS)		—		—					
TOTAL PHASE "C"		—		—		—		—		TOTAL CONNECTED LOAD: (AMPS)		—		—					
TOTAL CONNECTED LOAD:		—		—		—		—		TOTAL CONNECTED LOAD: (AMPS)		—		—					