

PANELBOARD SCHEDULE _____ LH										LOCATION: _____	C/B RATING: _____	K.A.I.C.
VOLT/PH/W/	120/208V, 3PH, 4W	MANS: 200A MLO			MTG: RECESSED			TYPE: BOLT-ON				
USE/AND OR AREA SERVED	C/B	#A	#B	#C	CIRCUIT NO.	#A	#B	#C	C/B	USE/AND OR AREA SERVED		
X-RAY WALL UNIT-RM B219	15/1	-	-	-	1 2	-	-	-	20/1	X-RAY WALL UNIT-RM B223		
X-RAY WALL UNIT-RM B208	15/1	-	-	-	3 4	-	-	-	15/1	X-RAY WALL UNIT-RM B222		
DENTAL CHAIR-RM B223	15/1	-	-	-	5 6	-	-	-	15/1	RECEPTACLES-RM B223		
X-RAY WALL UNIT-RM B207	15/1	-	-	-	7 8	-	-	-	15/1	RECEPTACLES-RM B222		
RECEPTACLES-RM B221	20/1	-	-	-	9 10	-	-	-	20/1	DENTAL CHAIR-RM B221		
RECEPTACLES-CORRIDOR B210	20/1	-	-	-	11 12	-	-	-	20/1	RECEPTACLES-RM B209		
DENTAL CHAIR-RM B208	20/1	-	-	-	13 14	-	-	-	20/1	RECEPTACLES-RM B208		
RECEPTACLES-RM B207	20/1	-	-	-	15 16	-	-	-	20/1	X-RAY WALL UNIT-RM B221		
EXISTING LOAD	20/1	-	-	-	17 18	-	-	-	20/1	COUNTER RECEPTACLES-DPC RM B198		
RECEPTACLES-WORK AREA B201	20/1	-	-	-	19 20	-	-	-	20/1	RECEPTACLES-CORRIDOR		
DENTAL CHAIR-RM B211	20/1	-	-	-	21 22	-	-	-	20/1	EXISTING LOAD		
RECEPTACLES-RMS B214, B219	20/1	-	-	-	23 24	-	-	-	20/1	RECEPTACLES-WORK AREA B215		
RECEPTACLES-RM B225	20/1	-	-	-	25 26	-	-	-	20/1	EXISTING LOAD		
RECEPTACLES-WORK AREA B224	20/1	-	-	-	27 28	-	-	-	20/1	RECEPTACLES-RMS B214, B214, B226		
RECEPTACLES-RM B216	20/1	-	-	-	29 30	-	-	-	20/1	RECEPTACLES-RMS B199, B200, B202		
EXISTING LOAD	20/1	-	-	-	31 32	-	-	-	20/1	RECEPTACLES-RM B167A		
EXHAUST FAN (EF-7)	20/1	-	-	-	33 34	-	-	-	20/1	RECEPTACLES-WORK AREA B215		
EXHAUST FAN (EF-8)	20/1	-	-	-	35 36	-	-	-	20/1	RECEPTACLES-WORK AREA B215		
RECEPTACLES-WORK AREA B201	20/1	-	-	-	37 38	-	-	-	100	PANEL "LJ"		
RECEPTACLES-WORK AREA B201	20/1	-	-	-	39 40	-	-	-	20/1			
EXISTING LOAD	20/1	-	-	-	41 42	-	-	-	3			
TOTAL PHASE "A"	-	-	-	-	-	-	-	-	-	TOTAL CONNECTED LOAD: (AMPS)	-	-
TOTAL PHASE "B"	-	-	-	-	-	-	-	-	-	TOTAL DEMAND LOAD: (AMPS)	-	-
TOTAL PHASE "C"	-	-	-	-	-	-	-	-	-			
TOTAL CONNECTED LOAD:	-	-	-	-	-	-	-	-	-			

FED FROM SWBD "DP-3" (BREAKER 14) IN RM B128

PANELBOARD SCHEDULE _____ LJ										LOCATION: _____	C/B RATING: _____	K.A.I.C.
VOLT/PH/W/	120/208V, 3PH, 4W	MANS: 125A MLO			MTG: RECESSED			TYPE: BOLT-ON				
USE/AND OR AREA SERVED	C/B	#A	#B	#C	CIRCUIT NO.	#A	#B	#C	C/B	USE/AND OR AREA SERVED		
X-RAY WALL UNIT-RM B182	20/1	-	-	-	1 2	-	-	-	20	AIR CONDITIONER-COMM. RM		
SPARE	20/1	-	-	-	3 4	-	-	-	2			
RECEPTACLES-RM B229	20/1	-	-	-	5 6	-	-	-	15/1	EXISTING LOAD		
RECEPTACLES-RMS B180, B184	20/1	-	-	-	7 8	-	-	-	20/1	EXISTING LOAD		
EXISTING LOAD	20/1	-	-	-	9 10	-	-	-	20/1	RECEPTACLES-RM B183		
RECEPTACLES-RMS B181, B183	20/1	-	-	-	11 12	-	-	-	20/1	SPARE		
RECEPTACLES-RM B182	20/1	-	-	-	13 14	-	-	-	15/1	DENTAL CHAIR-RM B183		
SPARE	15/1	-	-	-	15 16	-	-	-	20/1	RECEPTACLES-RM B177		
SPARE	15/1	-	-	-	17 18	-	-	-	20/1	RECEPTACLES-RM B167		
SPARE	20/1	-	-	-	19 20	-	-	-	20/1	SPARE		
RECEPTACLES-RMS B171, B178	20/1	-	-	-	21 22	-	-	-	20/1	X-RAY WALL UNIT-RM B184		
SPARE	20/1	-	-	-	23 24	-	-	-	20/1	X-RAY WALL UNIT-RM B182		
AHU-4	20	-	-	-	25 26	-	-	-	20	AHU-5		
SPARE	20/1	-	-	-	27 28	-	-	-	2			
RECEPTACLES-RMS B107, B110	20/1	-	-	-	29 30	-	-	-	20/1	RECEPTACLES-RM B183		
RECEPTACLES-RMS B112, B114, B130	20/1	-	-	-	31 32	-	-	-	20/1	PHONEBOARD RECEPTACLES-RM B250		
RECEPTACLES-RM B198	20/1	-	-	-	33 34	-	-	-	20/1	EXISTING LOAD		
RECEPTACLES-RM B198	20/1	-	-	-	35 36	-	-	-	20/1	PHONEBOARD RECEPTACLES-RM B250		
SPACE	-	-	-	-	37 38	-	-	-	20	AIR CONDITIONING UNIT-ELEVATOR EQUIP. RM		
SPACE	-	-	-	-	39 40	-	-	-	2			
SPACE	-	-	-	-	41 42	-	-	-	15/1	EXISTING LOAD		
TOTAL PHASE "A"	-	-	-	-	-	-	-	-	-	TOTAL CONNECTED LOAD: (AMPS)	-	-
TOTAL PHASE "B"	-	-	-	-	-	-	-	-	-	TOTAL DEMAND LOAD: (AMPS)	-	-
TOTAL PHASE "C"	-	-	-	-	-	-	-	-	-			
TOTAL CONNECTED LOAD:	-	-	-	-	-	-	-	-	-			

FED FROM PANEL "LH" (BREAKERS 38,40,42) IN CORRIDOR B227

PANELBOARD SCHEDULE _____ LM										LOCATION: _____	C/B RATING: _____	K.A.I.C.
VOLT/PH/W/	120/208V, 3PH, 4W	MANS: 100A MLO			MTG: SURFACE			TYPE: BOLT-ON				
USE/AND OR AREA SERVED	C/B	#A	#B	#C	CIRCUIT NO.	#A	#B	#C	C/B	USE/AND OR AREA SERVED		
EXISTING LOAD	30	-	-	-	1 2	-	-	-	-	SPACE		
	2	-	-	-	3 4	-	-	-	-	SPACE		
EXISTING LOAD	30	-	-	-	5 6	-	-	-	-	SPACE		
	2	-	-	-	7 8	-	-	-	-	SPACE		
EXISTING LOAD	30	-	-	-	9 10	-	-	-	-	SPACE		
	2	-	-	-	11 12	-	-	-	-	SPACE		
SURGE PROTECTION DEVICE	60	-	-	-	13 14	-	-	-	20/1	EXISTING LOAD		
	3	-	-	-	15 16	-	-	-	20/1	EXISTING LOAD		
		-	-	-	17 18	-	-	-	-	SPACE		
EXISTING LOAD	20/1	-	-	-	19 20	-	-	-	20/1	EXISTING LOAD		
EXISTING LOAD	20/1	-	-	-	21 22	-	-	-	20/1	EXISTING LOAD		
EXISTING LOAD	20/1	-	-	-	23 24	-	-	-	20/1	EXISTING LOAD		
EXISTING LOAD	20/1	-	-	-	25 26	-	-	-	20/1	EXISTING LOAD		
EXISTING LOAD	20/1	-	-	-	27 28	-	-	-	20/1	EXISTING LOAD		
EXISTING LOAD	20/1	-	-	-	29 30	-	-	-	20/1	EXISTING LOAD		
EXISTING LOAD	20/1	-	-	-	31 32	-	-	-	20/1	EXISTING LOAD		
EXISTING LOAD	20/1	-	-	-	33 34	-	-	-	20/1	EXISTING LOAD		
EXISTING LOAD	20/1	-	-	-	35 36	-	-	-	20/1	EXISTING LOAD		
EXISTING LOAD	20/1	-	-	-	37 38	-	-	-	20/1	EXISTING LOAD		
EXISTING LOAD	20/1	-	-	-	39 40	-	-	-	20/1	EXISTING LOAD		
EXISTING LOAD	20/1	-	-	-	41 42	-	-	-	20/1	EXISTING LOAD		
TOTAL PHASE "A"	-	-	-	-	-	-	-	-	-	TOTAL CONNECTED LOAD: (AMPS)	-	-
TOTAL PHASE "B"	-	-	-	-	-	-	-	-	-	TOTAL DEMAND LOAD: (AMPS)	-	-
TOTAL PHASE "C"	-	-	-	-	-	-	-	-	-			
TOTAL CONNECTED LOAD:	-	-	-	-	-	-	-	-	-			

FED FROM SWBD "DP-4" (BREAKER 29) IN RM F103

PANELBOARD SCHEDULE _____ LP										LOCATION: _____	C/B RATING: _____	K.A.I.C.
VOLT/PH/W/	120/208V, 3PH, 4W	MANS: 150A MLO			MTG: RECESSED			TYPE: BOLT-ON				
USE/AND OR AREA SERVED	C/B	#A	#B	#C	CIRCUIT NO.	#A	#B	#C	C/B	USE/AND OR AREA SERVED		
LIGHTING	20/1	-	-	-	1 2	-	-	-	20/1	RECEPTACLES-RM B209		
LIGHTING	20/1	-	-	-	3 4	-	-	-	20/1	LIGHTING		
LIGHTING	20/1	-	-	-	5 6	-	-	-	20/1	LIGHTING		
LIGHTING	20/1	-	-	-	7 8	-	-	-	20/1	LIGHTING		
LIGHTING	20/1	-	-	-	9 10	-	-	-	20/1	LIGHTING		
LIGHTING-COMPUTER RM P3	20/1	-	-	-	11 12	-	-	-	20/1	LIGHTING-OUTSIDE OF CONFERENCE RM		
SPARE	20/1	-	-	-	13 14	-	-	-	20/1	CONVENIENCE RECEPT-RM F112 CREDENTIALS		
LIGHTING-RM F115 CHIEF OF SERVICES	20/1	-	-	-	15 16	-	-	-	20/1	CONVENIENCE RECEPT-RM F241 RM OC		
CONVENIENCE RECEPTACLES-RM F242	20/1	-	-	-	17 18	-	-	-	20/1	CONVENIENCE RECEPT-RMO MAIN OFFICE		
CONVENIENCE RECEPTACLES-CORRIDOR	20/1	-	-	-	19 20	-	-	-	20/1	CONVENIENCE RECEPTACLES-VULT RM		
CONV. RECEPT-RM F235 MDOS COMMANDER	20/1	-	-	-	21 22	-	-	-	20/1	CONV. RECEPT-RMS F236,37 MDOS SEC/ADMIN		
CONVENIENCE RECEPTACLES-RMO-40-22	20/1	-	-	-	23 24	-	-	-	20/1	CONV. RECEPTACLES-M-3 COMPUTER RM P3		
CONVENIENCE RECEPTACLES-VULT RM	20/1	-	-	-	25 26	-	-	-	20	EXISTING LOAD		
LIGHTING-CONFERENCE RM	20/1	-	-	-	27 28	-	-	-	2			
EXISTING LOAD	20	-	-	-	29 30	-	-	-	20/1	SPARE		
EXISTING LOAD	2	-	-	-	31 32	-	-	-	30	NETSAVERS UPS-COMPUTER RM P3		
EXISTING LOAD	20/1	-	-	-	33 34	-	-	-	2			
SPACE	-	-	-	-	35 36	-	-	-	30	NETSAVERS UPS-COMPUTER RM P3		
SPACE	-	-	-	-	37 38	-	-	-	2			
SPACE	-	-	-	-	39 40	-	-	-	-	SPACE		
SPACE	-	-	-	-	41 42	-	-	-	-	SPACE		
TOTAL PHASE "A"	-	-	-	-	-	-	-	-	-	TOTAL CONNECTED LOAD: (AMPS)	-	-
TOTAL PHASE "B"	-	-	-	-	-	-	-	-	-	TOTAL DEMAND LOAD: (AMPS)	-	-
TOTAL PHASE "C"	-	-	-	-	-	-	-	-	-			
TOTAL CONNECTED LOAD:	-	-	-	-	-	-	-	-	-			

FED FROM SWBD "DP-1" (BREAKER 17) IN MAIN SWGR RM F147

PANELBOARD SCHEDULE										LR			LOCATION: RM 0191	C/B RATING: _____	K.A.I.C.
VOLT/PH/W: 120/208V, 3PH, 4W		MANS: 150A MLO					MTG: RECESSED			TYPE: BOLT-ON					
USE/AND OR AREA SERVED	C/B	#A	#B	#C	CIRCUIT NO.	#A	#B	#C	C/B	USE/AND OR AREA SERVED					
RECEPTACLES-RM 172 SHIRT	20/1	-	-	-	1 2	-	-	-	20/1	RECEPTACLES-RM 187 MDSS/CC					
RECEPTACLES-RM 173 SGT	20/1	-	-	-	3 4	-	-	-	20/1	RECEPTACLES-RM 187 SGT					
RECEPTACLES-RM 174 AMDS/CC	20/1	-	-	-	5 6	-	-	-	20/1	RECEPTACLES-RM 185 GRP SUPPORT					
RECEPTACLES-RM 175 SEC.	20/1	-	-	-	7 8	-	-	-	20/1	RECEPTACLES-RM 185 GRP SEC.					
RECEPTACLES-RM 175 SEC.	20/1	-	-	-	9 10	-	-	-	20/1	RECEPTACLES-RM 183 MDG/MDMR					
RECEPTACLES-RM 171	20/1	-	-	-	11 12	-	-	-	20/1	RECEPTACLES-RM 181 MDSS/SEC					
RECEPTACLES-CORRIDORS A, C, D	20/1	-	-	-	13 14	-	-	-	20/1	RECEPTACLES-RM 190 3 ADMIN. TECH.					
RECEPTACLES-RM 191 DISTRA/COPY	20/1	-	-	-	15 16	-	-	-	20/1	RECEPTACLES-RM 190 3 ADMIN. TECH.					
RECEPTACLES-RM 191 DISTRA/COPY	20/1	-	-	-	17 18	-	-	-	20/1	RECEPTACLES-RM 190 3 ADMIN. TECH.					
RECEPTACLES-RM 191 DISTRA/COPY	20/1	-	-	-	19 20	-	-	-	20/1	RECEPTACLES-RM 190 3 ADMIN. TECH.					
RECEPTACLES-RM 191 DISTRA/COPY	20/1	-	-	-	21 22	-	-	-	20/1	RECEPTACLES-RM 190 3 ADMIN. TECH.					
RECEPTACLES-CONFERENCE RM 192	20/1	-	-	-	23 24	-	-	-	20/1	GR RECEPTACLE-RM 177 STAFF TOILET					
RECEPTACLES-CONFERENCE RM 192	20/1	-	-	-	25 26	-	-	-	20/1	REFRIGERATOR-RM 181					
PROJECTOR	20/1	-	-	-	27 28	-	-	-	20/1	GR RECEPTACLE-RM 181 COFFEE BAR					
RECEPTACLES-RM 192	20/1	-	-	-	29 30	-	-	-	20/1	GR RECEPTACLE-RM 182 COMM. TOILET					
SECURITY PANEL	20/1	-	-	-	31 32	-	-	-	20/1	RECEPTACLES-RM 192 3 ADMIN. TECH.					
SECURITY PANEL-RM 183	20/1	-	-	-	33 34	-	-	-	20/1	HAV 2, 3, 4					
EXISTING LOAD	20	-	-	-	35 36	-	-	-	20/1	HAV 1, 5, 6					
	2	-	-	-	37 38	-	-	-	50	EXISTING LOAD					
EXISTING LOAD	30	-	-	-	39 40	-	-	-	40						
	2	-	-	-	41 42	-	-	-	20/1	EXISTING LOAD					
TOTAL PHASE "A" _____															
TOTAL PHASE "B" _____															
TOTAL PHASE "C" _____															
TOTAL CONNECTED LOAD: _____															TOTAL CONNECTED LOAD: (AMPS) _____
_____															TOTAL DEMAND LOAD: (AMPS) _____