

EQUIPMENT SCHEDULE

TAG	DESCRIPTION	MOTO R, HP	LOAD, A	VA	VOLTS	PH	OCPD SIZE	BRANCH CIRCUIT CONDUCTORS	DISCONNECT	SPECIFIC NOTES
B-1	BOILER		0.4	50	120	1	0		TOGGLE	
B-2	BOILER		0.4	50	120	1	0		TOGGLE	
BP-1	IN-LINE CENTRIFUGAL PUMP	4	13.6	4909	208	3	35		60A/NF/3P/NEMA 3R	
BP-2	IN-LINE CENTRIFUGAL PUMP	4	13.6	0	120	3	0		60A/NF/3P/NEMA 3R	
CH-1	CHILLER		313	112993	208	3	400		400A/NF/3P/NEMA 3R	
CHWP-1	IN-LINE CENTRIFUGAL PUMP	3	10.6	3827	208	3	0		30A/NF/3P/NEMA 3R	
CHWP-2	IN-LINE CENTRIFUGAL PUMP	3	10.6	3827	208	3	0		30A/NF/3P/NEMA 3R	
DCP-1	CIRCULATING PUMP	1/8	2.9	348	120	1	0		TOGGLE	
DOAS-1	DEDICATED OUTSIDE AIR UNIT		96	34656	208	3	125		200A/NF/3P/NEMA 1	
EF-1	BATHROOM EXHAUST FAN		0	0	<varies >	1	0		TOGGLE	
EF-2	INLINE FAN		0	0	230	1	0		TOGGLE	
EF-3	INLINE FAN		0	0	230	1	0		TOGGLE	
FCU-A-L	FAN COIL UNIT	.25	1.4	291	208	1	15		30A/15F/2P/NEMA 1	
FCU-A-R	FAN COIL UNIT	.25	1.4	291	208	1	15		30A/15F/2P/NEMA 1	
FCU-B-L	FAN COIL UNIT	.25	2.5	520	208	1	15		30A/15F/2P/NEMA 1	
FCU-C-L	FAN COIL UNIT	.25	1.4	291	208	1	15		30A/15F/2P/NEMA 1	
FCU-C-R	FAN COIL UNIT	.25	1.4	291	208	1	15		30A/15F/2P/NEMA 1	
FCU-D-R	FAN COIL UNIT	.25	2.5	520	208	1	15		30A/15F/2P/NEMA 1	
FCU-E-R	FAN COIL UNIT	.25	2.5	520	208	1	15		30A/15F/2P/NEMA 1	

		AIR MOBILITY COMMAND 19TH CIVIL ENGINEER SQUADRON LITTLE ROCK, ARKANSAS		ELECTRICAL SCHEDULES		APPROVED CHIEF ENGINEER APPROVED CIVIL ENGINEER		REV # DATE	DESCRIPTION	APP'D
DATE: JULY 2026 DESIGNED BY: JLS DRAWN BY: MUC BUILDING NO.: PROJECT NO.: SHEET REF.:		1 OF XX		DETAILS (1)		APPROVED CHIEF ENGINEER APPROVED CIVIL ENGINEER		REV # DATE	DESCRIPTION	APP'D