Quality People. Building Solutions.

Comfort Systems USA (Arkansas), Inc.
P.O. Box 16620
LittleRock, AR 72231
Phone 501-834-3320
Fax 501-834-5416

Date: 8/21/2025
Return Request: 9/4/2025
Project: Hot Springs National Park – Rehabilitate Bathhouses – Libbey Bathhouse
Supplier: Fluid Solutions, Inc.
Manufacturer: Mason Industries
Submittal: Seismic Requirements for Equipment and Supports
Submittal Number: 230550.001
Spec Section: 230550, 2.1 through 2.7
Drawing # and Installation Location: M1.1

ARCHITECT
Quinn Evans Architects
219-1/2 N. Main Street
Ann Arbor, Michigan 48104
(734)663-5888

GENERAL CONTRACTOR
Tepa, LLC
2345 Grand Blvd, Suite 700
Kansas City, Missouri 64108
(816)708-1110

ENGINEER
IMEG Corp.
1600 Baltimore Street, Suite 300
Kansas City, Missouri 64108
(816)842-8437

MECHANICAL SUBCONTRACTOR
Comfort Systems USA (Arkansas), Inc.
9924 Landers Road
North Little Rock, Arkansas 72117
(501)834-3320

Comments:

Per specification section 230550, 1.7, B., the following criteria are applicable to this project; 1. Risk Category III, and 2. Seismic Importance Factor: IE = 1.25 Seismic Design Category: B. This tells us that seismic bracing will not be required for the Libbey Bathhouse project.

CSUSA PROJECT NO.
25-7065
joe@comfortar.com