

1

2

3

4

5

6

SHEET NOTES

1. REFER TO DM001 FOR PROCESS GENERAL NOTES AND DESIGN CRITERIA.
2. REFER TO DM002 FOR PROCESS ABBREVIATIONS AND LEGENDS.

POND3500 Parkway Lane
Suite 500
Peachtree Corners
Georgia 30092

Copyright © 2024 by Pond & Company. All rights reserved. No copying or duplication of these documents is allowed without the expressed written agreement of Pond & Company.

EOR/AOR SEAL

COA SEAL

CLIENT INFORMATION

Vantive

PROJECT NAME

**VANTIVE
TUBING
CLEAN ROOM**1900 AR-201
MOUNTAIN HOME,
ARKANSAS 72653

KEYNOTES

1. MODIFY EXISTING HOIST WITH BOTTOM END AND UPPER END HARD STOP. STOPPER MECHANISM THROW TO MATCH FLEXIBLE DUCT LENGTH (APPROX 30"). STOPPER MECHANISM TO COMMUNICATE WITH WALL MOUNTED CONTROLS BOX ON FLOOR LEVEL.
2. NEW HOIST WITH BOTTOM END AND UPPER END HARD STOP. STOPPER MECHANISM THROW TO MATCH FLEXIBLE DUCT LENGTH (APPROX 30"). STOPPER MECHANISM TO COMMUNICATE WITH WALL MOUNTED CONTROLS BOX ON FLOOR LEVEL. REFER TO DM-651 FOR HOIST DETAILS.
3. RE-BALANCE AIRFLOW EQUALLY ACROSS ALL HEPA FILTERS SO THAT THE ROOM MEETS THE PRE-CONSTRUCTION POSITIVE PRESSURE, WITH MINIMUM 0.02" W.G. OR 5 PA TO THE WAREHOUSE. EXHAUST AIRFLOW FOR THE ENTIRE ROOM WILL GO THROUGH (4) EXHAUST FUME HOODS FOR A TOTAL OF 5200 CFM OR 1325 CFM PER FUME HOOD.

DRAWING ISSUE

04/24/2026
01/23/2026
07/23/2025
10/03/2025
DATEISSUED FOR BID, EQ BID
CLARIFICATIONS
ISSUED FOR APPROVAL
ISSUED FOR PERMIT
ISSUED FOR ESTIMATE
DESCRIPTION


D C A MARK

DESIGNED BY: JC
DRAWN BY: JS
CHECKED BY: JC
SUBMITTED BY: CL
DATE: 04/24/2026
PROJECT #: 1241011

SHEET TITLE

**DUCT - OVERALL
FLOOR PLAN -
ROOM 510**

SHEET NUMBER

DM400ORIGINAL SHEET SIZE:
30" X 42"

KEY PLAN

0 4' 8' 12'
SCALE: 3/16" = 1'-0"

PLAN NORTH

TILE # 7

ISSUED FOR BID

A1 DUCT - OVERALL FLOOR PLAN - ROOM 510

SCALE: 3/16" = 1'-0"