

HVAC GENERAL NOTES

- . ALL LIGHTER SOLID LINES REPRESENT PIPING, DUCTWORK, EQUIPMENT, ETC. TO REMAIN.
- 2. ALL DARKER SOLID LINES REPRESENT NEW PIPING, DUCTWORK, EQUIPMENT, ETC.
- FIELD VERIFY EXACT SIZE AND LOCATION OF ALL EXISTING ITEMS SHOWN ON THIS PLAN THAT ARE TO BE CONNECTED TO.

HVAC KEYED NOTES

1	EXISTING AIR DEVICE TO REMAIN. SET AIRFLOW RATE TO 365 CFM.
2	EXISTING AIR DEVICE TO REMAIN. SET AIRFLOW RATE TO 580 CFM.
3	EXISTING AIR DEVICE TO REMAIN. SET AIRFLOW RATE TO 405 CFM.
4	EXISTING AIR DEVICE TO REMAIN. SET AIRFLOW RATE TO 275 CFM.
5	EXISTING AIR DEVICE TO REMAIN. SET AIRFLOW RATE TO 225 CFM.
5)	EXISTING AIR DEVICE TO REMAIN. SET AIRFLOW RATE TO 440 CFM.
	EXISTING AIR DEVICE TO REMAIN. SET AIRFLOW RATE TO 435 CFM.
8	EXISTING AIR DEVICE TO REMAIN. SET AIRFLOW RATE TO 290 CFM.
9	EXISTING AIR DEVICE TO REMAIN. SET AIRFLOW RATE TO 380 CFM.
0	EXISTING AIR DEVICE TO REMAIN. SET AIRFLOW RATE TO 535 CFM.
1	EXISTING AIR DEVICE TO REMAIN. SET AIRFLOW RATE TO 230 CFM.
2	EXISTING AIR DEVICE TO REMAIN. SET AIRFLOW RATE TO 515 CFM.
3	SET OSA AIRFLOW RATE TO 80 CFM. PROVIDE AUTOMATIC BALANCING DAMPER EQUAL TO GREENHECK ABD.
4	SET OSA AIRFLOW RATE TO 90 CFM. PROVIDE AUTOMATIC BALANCING DAMPER EQUAL TO GREENHECK ABD.
5	SET OSA AIRFLOW RATE TO 25 CFM. PROVIDE AUTOMATIC BALANCING DAMPER EQUAL TO GREENHECK ABD.
6	SET OSA AIRFLOW RATE TO 30 CFM. PROVIDE AUTOMATIC BALANCING DAMPER EQUAL TO GREENHECK ABD.
7	SET OSA AIRFLOW RATE TO 100 CFM. PROVIDE AUTOMATIC BALANCING DAMPER EQUAL TO GREENHECK ABD.
8	SET OSA AIRFLOW RATE TO 55 CFM. PROVIDE AUTOMATIC BALANCING DAMPER EQUAL TO GREENHECK ABD.
9	SET OSA AIRFLOW RATE TO 60 CFM. PROVIDE AUTOMATIC BALANCING DAMPER EQUAL TO GREENHECK ABD.
	SET OSA AIRFLOW RATE TO 50 CFM. PROVIDE AUTOMATIC BALANCING DAMPER EQUAL TO GREENHECK ABD.
1	SET OSA AIRFLOW RATE TO 115 CFM. PROVIDE AUTOMATIC BALANCING DAMPER EQUAL TO GREENHECK ABD.
2	14"/12" OSA SUPPLY DUCTWORK DOWN THROUGH FLOOR. SAW CUT FLOOR AS REQUIRED AND PROVIDE FIRE DAMPER AT FLOOR LEVEL. SEE M100 AND M104 FOR CONTINUATION.
3	12"/10" OSA SUPPLY DUCTWORK DOWN THROUGH FLOOR. SAW CUT FLOOR AS REQUIRED AND PROVIDE FIRE DAMPER AT FLOOR LEVEL. SEE M100 AND M104 FOR CONTINUATION.
$\overline{\Lambda}$	

(24) 14"/12" EXHAUST DUCTWORK DOWN THROUGH FLOOR. SAW CUT FLOOR AS REQUIRED AND PROVIDE FIRE DAMPER AT FLOOR LEVEL. SEE M100 AND M104 FOR CONTINUATION.

8"ø EXHAUST DUCTWORK DOWN THROUGH FLOOR. SAW CUT FLOOR AS REQUIRED AND PROVIDE FIRE DAMPER AT FLOOR LEVEL. SEE M100 AND M104 FOR CONTINUATION.



USE THO FOR: OUR⁻ **ATIONS** C RENOV N 0 Z C MECHANIC 0 1 IGHE/ 4 R C

B

()

Ш

ſ

 $\mathbf{\mathbf{X}}$

Commission Number 2309D

M102

Date: November 11, 2024

S

-

ر ۲

B

• –

Ч

 \mathbf{O}

Г

В

 $\mathbf{\Gamma}$

Ш

rkansas

Ο

0

esb

Č

20

aX

100 East Huntington Ave. Suite D P.O. Box 1655 870-932-0571

OND FLOOR PLAN - HVAC

l S