



LIGHTING FIXTURE SCHEDULE						
FIXTURE DESIGNATION	VOLTS	WATTS	MANUFACTURER AND MODEL	QTY	TYPE	REMARKS
A	120	67	HOLOPHANE EVT4 800LM FST MD MVOLT GZ10 40K 80CRI	4	LED	MOUNT ON UPPER DECK SUPPORT STRUCTURE.
P	120	42	LITHONIA DSXF1 LED P2 40K FL MVOLT 1S PE UVV DNAXD	1	LED	TENON SLIPFIT ON 2" RAC CONDUIT ATTACHED TO HANDRAIL OF UPPER DECK.




DETAIL
1
1/8" = 1'-0"

SECTION
2
3/16" = 1'-0"


SECTION
3
3/16" = 1'-0"

KEYED NOTES

- 1 REMOVE EXISTING POLE LIGHT AND SALVAGE TO OWNER.
- 2 EXTEND EXISTING LIGHTING CIRCUIT FROM EXISTING JUNCTION BOX TO TYPE A FIXTURES MOUNTED TO THE BOTTOM OF NEW PLATFORM.
- 3 EXTEND LIGHTING CIRCUIT FROM KEYED NOTE 2 TYPE A FIXTURES TO TYPE P FLOOD LIGHTING FIXTURE MOUNTED TO THE TOP OF 8' LENGTH, 2" RAC CONDUIT SECURED TO THE HANDRAIL ON THE NEW PROPOSED PLATFORM.



DATE	REVISION



CITY OF ROGERS, ARKANSAS
ROGERS POLLUTION CONTROL FACILITY (PCF)
SOLIDS HANDLING IMPROVEMENTS, PHASE II
PLATFORM AND PIPE BRIDGE LIGHTING PLAN
FOR: ROGERS WATER UTILITIES

DATE: AUGUST 2024
SCALE: As indicated
DESIGNED BY: Designer
DRAWN BY: Author
HWEI NO.: 2020043
FILENAME:

SHEET NO.
EA-21