


- NOTES:
1. TRAPS ON THE SUCTION SIDE OF FANS SHALL HAVE MINIMUM DIMENSIONS OF 10" FOR "Y" AND 8" FOR "X".
 2. DRAIN CONNECTION TO FAN SCROLL IS TO BE TRAPPED AND DRAIN SIMILAR.

CONDENSATE DRAIN

DETAIL
12" = 1'-0"



1"
ONE INCH
AT FULL SIZE
IF NOT ONE INCH
SCALE ACCORDINGLY

REVISION	DATE



ROGERS, ARKANSAS
ROGERS POLLUTION CONTROL FACILITY (PCF)
SOLIDS HANDLING IMPROVEMENTS, PHASE II
MECHANICAL DETAILS
FOR: ROGERS WATER UTILITIES

DATE: AUGUST 2024
SCALE: AS SHOWN
DESIGNED BY: KJU/MNH
DRAWN BY: JCD
HWEI NO.: 2020043
FILENAME:

SHEET NO.
MZ-02