

8/26/2024 4:37:18 PM / RLG / PLUMBING

Autodesk Docs://406493 - Rogers PCF Solids Phase 2/406493--Maintenance Building-BVrvr

PIPING ACCESSORIES SCHEDULE				
UNIT NUMBER	MANUFACTURER	MODEL	DESCRIPTION	NOTES
FCO-1	SMITH	4239 SRIES	HEAVEY DUTY FLOOR CLEANOUT WITH ADJUSTABLE TRACTOR COVER.	---
FD-2	ORION	AWFDSTS SERIES	CORROSION RESISTANT FLOOR DRAIN, POLYPROPYLENE BODY AND GRATE.	---
SD-1	SMITH	200 SERIES	CAST IRON SHOWER WITH ADJUSTABLE STRAINER HEAD.	---
TD-1	ABT	POLYDRAIN PDX	INDUSTRIAL TRENCH SYSTEM, 8" INTERIOR WIDTH, ELEVEN 1 METER SECTIONS PER RUN.	---

PLUMBING EQUIPMENT SCHEDULE					
UNIT NUMBER	MANUFACTURER	MODEL	DESCRIPTION	APPROX WEIGHT (LBS)	NOTES
EWH-2	CHRONOMITE	R-75L	ELECTRIC INSTANTANEOUS WATER HEATER, 2.5 GPM, 57 F RISE, 20.75 KW, 277 VOLT	10	---
EWH-3	KELTECH	CLE SERIES	ELECTRIC INSTANTANEOUS EYEWASH WATER HEATER, 3.0 GPM, 40 F RISE, 18 KW, 480 VOLT, 3 PHASE.	---	1
OI-1	SMITH	8599 SERIES	INTEGRAL STORAGE TYPE OIL INTERCEPTOR	---	---

PLUMBING FIXTURE SCHEDULE									
UNIT NUMBER	MANUFACTURER	MODEL	DESCRIPTION	WATER (IN)		WASTE (IN)		APPROX WEIGHT (LBS)	NOTES
				HOT	COLD	WASTE	VENT		
EEW-1	HAWS	7433FP	EMERGENCY EYE WASH, WALL MOUNTED, FROST-PROOF, REMOTE ACTUATED BALL VALVE, 1/2" IPS SUPPLY.	---	1/2"	1 1/2"	1 1/2"	---	2,3
L-1	AMERICAN STANDARD	LAV:0355.012 LUCERNE FAUCET:7385:000 RELIANT 3	LAVATORY	1/2"	1/2"	1 1/2"	1 1/2"	---	---
SH-1	SYMMONS	C-96-1-X TEMPTROL	BUILT-UP SHOWER UNIT, WITH SHOWER VALVE, HEAD, ARM AND FLANGE, 2.0 GPM MAX FLOW.	1/2"	1/2"	2"	2"	---	---
UR-1	AMERICAN STANDARD	CHINA:6590.001 WASHBROOK VALVE:6045.051	URINAL	---	3/4"	2"	1 1/2"	---	---
WC-1	AMERICAN STANDARD	2859.016 AFWALL	WATER CLOSET	---	1"	4"	2"	---	---

BACKFLOW PREVENTER SCHEDULE								
UNIT NUMBER	LOCATION	MANUFACTURER	MODEL	SERVICE	BODY SIZE (IN)	MAXIMUM FLOW (GPM)	MAXIMUM PRESSURE DIFFERENTIAL (PSI)	NOTES
BFP-101	VEHICLE STORAGE	WATTS	LF909M1-FS	---	1 1/2"	45	10	---

MAINTENANCE BUILD. SCHEDULE NOTES

PIPING ACCESSORIES SCHEDULE:


NOTES: NONE

PLUMBING EQUIPMENT SCHEDULE:

NOTES:
1. WATER HEATER SHALL BE PROVIDED WITH OPTIONAL LEG KIT FOR FLOOR-MOUNT INSTALLATION

PLUMBING FIXTURE SCHEDULE:

NOTES:
1. FIXTURE AND INSTALLATION SHALL BE ADA COMPLIANT
2. TEMPERED WATER SUPPLY
3. COMMON FLOW SWITCH SERVES BOTH EEW-1 AND ES-1



ONE INCH AT FULL SIZE IF NOT ONE INCH SCALE ACCORDINGLY

DATE

REVISION

--	--	--	--	--	--	--	--	--	--



ROGERS, ARKANSAS
ROGERS POLLUTION CONTROL FACILITY (PCF)
SOLIDS HANDLING IMPROVEMENTS, PHASE II
PLUMBING SCHEDULES
FOR: ROGERS WATER UTILITIES

DATE: AUGUST 2024
SCALE: NONE
DESIGNED BY: DBR
DRAWN BY: RLG
HWEI NO.: 2020043
FILENAME:

SHEET NO.
PZ-03

© HAWKINS-WEIR ENGINEERS, INC. 2023