


LIGHTING FIXTURE SCHEDULE									
MARK	MANUFACTURER	CATALOG NUMBER	VOLTAGE	LAMPS			MOUNTING HEIGHT	MOUNTING TYPE	REMARKS
				WATTS	LUMENS	TYPE			
A	LITHONIA COLUMBIA DAY-BRITE	2BLT4-4BL-ADSM-EZ1-LP835	277	39.3	4,800	LED 3,500K	CEILING	RECESSED	
AE	LITHONIA COLUMBIA DAY-BRITE	2BLT4-4BL-ADSM-EZ1-LP835-E10WLCP	277	39.3	4,800	LED 3,500K	CEILING	RECESSED	EM
B	LITHONIA COLUMBIA DAY-BRITE	2BLT2-40L-ADSM-EZ1-LP835	277	31	4,000	LED 3,500K	CEILING	RECESSED	
BE	LITHONIA COLUMBIA DAY-BRITE	2BLT2-40L-ADSM-EZ1-LP835-E10WLCP	277	31	4,000	LED 3,500K	CEILING	RECESSED	EM
BL	HESS OR APPROVED EQUAL	CE180B-IF-AR450-42-30K-T5	277	15	1,417	LED 3,500K	SEE DETAIL "E-BOL"		FSA
C	LITHONIA COLUMBIA DAY-BRITE	ZL1D-L48-5000LM-FST-35K-80CRI	277	41	5,000	LED 3,500K	10'-0" A.F.F.	STEM	
CE	LITHONIA COLUMBIA DAY-BRITE	ZL1D-L48-5000LM-FST-35K-80CRI-E10WLCP	277	41	5,000	LED 3,500K	10'-0" A.F.F.	STEM	EM
D	GOTHAM PRESCOLITE CALCULITE	EVO4-35/15-AR-LSS-MWD-GZ1	277	13.7	1,500	LED 3,500K	CEILING	RECESSED	FSA
DE	GOTHAM PRESCOLITE CALCULITE	EVO4-35/15-AR-LSS-MWD-GZ1-E10WCP	277	13.7	1,500	LED 3,500K	CEILING	RECESSED	EM FSA
D2	GOTHAM PRESCOLITE CALCULITE	EVO4-35/25-AR-LSS-WD-GZ1	277	25.7	2,500	LED 3,500K	CEILING	RECESSED	FSA
D2E	GOTHAM PRESCOLITE CALCULITE	EVO4-35/25-AR-LSS-WD-GZ1-E10WCP	277	25.7	2,500	LED 3,500K	CEILING	RECESSED	EM FSA
D3	GOTHAM PRESCOLITE CALCULITE	EVO2-35/10-AR-LSS-MD-GZ1	277	12.7	1,000	LED 3,500K	CEILING	RECESSED	FSA
D4	GOTHAM PRESCOLITE CALCULITE	EVO2-35/10-AR-FL-LSS-MD-GZ1	277	12.7	1,000	LED 3,500K	CEILING	RECESSED	FSA
D5	GOTHAM PRESCOLITE CALCULITE	EVO4-35/30/AR-LSS-WD-EDXB	277	31.2	3,000	LED 3,500K	CEILING	RECESSED	DMX FSA
D5E	GOTHAM PRESCOLITE CALCULITE	EVO4-35/30/AR-LSS-WD-EDXB-ELR	277	31.2	3,000	LED 3,500K	CEILING	RECESSED	DMX EM FSA
D6	GOTHAM PRESCOLITE CALCULITE	EVO4SQ-35/25-AR-LD-EZ1	277	25.7	2,500	LED 3,500K	CEILING	RECESSED	FSA
DS	GOTHAM PRESCOLITE CALCULITE	EVO4SH-35/15-DFR-SMO	277	13.7	1,500	LED 3,500K	CEILING	RECESSED	FSA
EL	LITHONIA COLUMBIA DAY-BRITE	DMW2-L24-4000LM-ACL-WD-40K-80CRI	277	40	5,000	LED 4,000K	AS DIRECTED BY ELEVATOR SUPPLIER	SURFACE	
EM	LITHONIA COLUMBIA DAY-BRITE	ELM4L	277	2x3	2x320	LED	7'-6" A.F.F.	SURFACE	EMX FSA
G	PRUDENTIAL OR APPROVED EQUAL	BPRO3REC-REG1-LED35-SO- TMW-SAL-LP-SC-X-DM01 *LENGTH AS SHOWN ON PLANS	277	7.8 PER FOOT	950 PER FOOT	LED 3,500K	CEILING	RECESSED LAY-IN	FCL
G2	PRUDENTIAL OR APPROVED EQUAL	BPRO3REC-REG1-LED35-SO- TMW-SAL-LP-SC-X3-DM01 *LENGTH AS SHOWN ON PLANS	277	7.8 PER FOOT	950 PER FOOT	LED 3,500K	CEILING	RECESSED GYP	FCL
H	LUMINIS OR APPROVED EQUAL	SYP405-L1L10-FLD-30K-SL-STM-12IN-SWK-SP IP65 RATED	277	12	1,344	LED 3,000K	AS HIGH AS POSSIBLE - MINIMIZE STEM	PENDANT STEM	FSA
H2	LUMINIS OR APPROVED EQUAL	SYP410-L1L10-VVD-30K-ESL IP65 RATED	277	12	1,344	LED 3,000K	CEILING	OUTLET BOX	FSA
HL	HOUSE LIGHTING FIXTURE - FURNISHED BY A/E CONTRACTOR AND INSTALLED AND CONNECTED BY ELECTRICAL CONTRACTOR		120	230	-	LED RGBW	AS DIRECTED BY A/E	AS DIRECTED BY A/E	
HL2	HOUSE LIGHTING FIXTURE - FURNISHED BY A/E CONTRACTOR AND INSTALLED AND CONNECTED BY ELECTRICAL CONTRACTOR		120	150	-	LED RGBW	CEILING	RECESSED	
HL3	HOUSE LIGHTING FIXTURE - FURNISHED BY A/E CONTRACTOR AND INSTALLED AND CONNECTED BY ELECTRICAL CONTRACTOR		120	120	-	LED RGBW	AS DIRECTED BY A/E	AS DIRECTED BY A/E	
K	MARK COLUMBIA DAY-BRITE	S2PD-LSL-35K-1200LMF-DBW- SCT-MIN1-FL-LZ-F2-RDCY *LENGTH AS SHOWN ON PLANS	277	9.85 PER FOOT	1,060 PER FOOT	LED 3,500K	AS DIRECTED BY ARCHITECT	PENDANT	FSA
KE	MARK COLUMBIA DAY-BRITE	S2PD-LSL-35K-1200LMF-DBW- SCT-MIN1-FL-L1E10WLCP- ZT-F2-RDCY *LENGTH AS SHOWN ON PLANS	277	9.85 PER FOOT	1,060 PER FOOT	LED 3,500K	AS DIRECTED BY ARCHITECT	PENDANT	EM FSA
L	GOTHAM PRESCOLITE CALCULITE	EVO4CC-35/25-AR-LSS-WD-EZ1-JBXCC-PCAN-C*	277	24.7	2,500	LED 3,500K	AS DIRECTED BY ARCHITECT	PENDANT CABLE	FSA
L2	GOTHAM PRESCOLITE CALCULITE	EVO6PC-35/40-AR-LSS-MD-EZ1-JBXCC-PCAN-S** *LENGTH AS REQUIRED	277	39	4,000	LED 3,500K	BOTTOM EVEN WITH DUCT - VERIFY WITH ARCH	PENDANT STEM	FSA
L3	GOTHAM PRESCOLITE CALCULITE	EVO4CC-35/35-AR-LSS-WD-EZ1-JBXCC-PCAN-C** *LENGTH AS REQUIRED	277	38.4	3,500	LED 3,500K	BOTTOM EVEN WITH DUCT - VERIFY WITH ARCH	PENDANT STEM	FSA
L4	GOTHAM PRESCOLITE CALCULITE	IC04CC-35/45-BR-20D-JBX-C120-DBL	277	46.2	4,500	LED 3,500K	BOTTOM EVEN WITH DUCT - VERIFY WITH ARCH	PENDANT CORD	FSA
P		ALLOWANCE: \$500 PER FIXTURE	277	20 (MAX)	1,000 (MIN)	LED 3,000K	AS DIRECTED BY ARCHITECT	PENDANT	FSA
P2	EUREKA OR APPROVED EQUAL	4259-LED-24-35-80-DV-AC-60-RC*	277	30.7	2,820	LED 3,500K	AS DIRECTED BY ARCHITECT	PENDANT	FSA
P3	EUREKA OR APPROVED EQUAL	4850D-B-72-LED-LED-35-90- DV-RMP-***G981GXAC-RC5-RCA	277	113.4 (56.7 UP, 56.7 DN)	13,595 (8,041 UP, 5,554 DN)	LED 3,500K	AS DIRECTED BY ARCHITECT	PENDANT	FSA RD
P4	VSUAL COMFORT OR APPROVED EQUAL	KC1054	120	4x3W (MAX) (T4)	4x500 (MIN) (T4)	LED 3,500K	AS DIRECTED BY ARCHITECT	PENDANT	FSA
P5	EUREKA OR APPROVED EQUAL	74700D-3-LED-35-80-DV-S7- STEM LENGTHS AS DIRECTED BY ARCHITECT	277	48.7	5,239	LED 3,500K	AS DIRECTED BY ARCHITECT	PENDANT	FSA
P6		ALLOWANCE: \$800 PER FIXTURE	277						
S	LUMINIS OR APPROVED EQUAL	SYP402-L1L10-FLD-30K-UL-L1L10-UNR-30K	277	24 (12 UP, 12 DN)	2,688 (1,344 UP, 1,344 DN)	LED 3,000K	AS DIRECTED BY ARCHITECT	OUTLET BOX	FSA
S2	LUMINIS OR APPROVED EQUAL	SYP602-L1L20-FLD-30K-UL-L1L20-UNR-30K	277	42 (21 UP, 21 DN)	4,496 (2,248 UP, 2,248 DN)	LED 3,000K	AS DIRECTED BY ARCHITECT	OUTLET BOX	FSA

LIGHTING FIXTURE SCHEDULE									
MARK	MANUFACTURER	CATALOG NUMBER	VOLTAGE	LAMPS			MOUNTING HEIGHT	MOUNTING TYPE	REMARKS
				WATTS	LUMENS	TYPE			
ST	COLE OR EQUAL	L157W-HO-BLU-BLK-DIM	120	3.4	331	LED BLUE	24" A.F.F.	RECESSED IN WALL	FSA
ST2	PIL OR EQUAL	INSERT+ ZERO CLIPS-4W	120	4	162	LED 3,500K	18" ABOVE STAR TREAD	RECESSED IN WALL	FSA
STE	PRUDENTIAL OR EQUAL	FLAIR-PRO-HO-**-SAL-SUR-EMHE *LENGTH AS SHOWN ON PLANS	277	12.5 PER FOOT	1,475 PER FOOT	LED 3,500K	8'-0" ABOVE LANDING	SURFACE	EM FSA
T	LUMINII OR APPROVED EQUAL	BOSW-***HE48MO-35K-SG-F-PS24 *LENGTH AS SHOWN ON PLANS - PROVIDE WITH CABLES AND CONNECTORS AS REQUIRED	277 (24VDC DRIVER)	3.5 PER FOOT	201 PER FOOT	LED 3,000K	BOTTOM OF CANOPY	SURFACE	FSA RD
TL	JUNO OR APPROVED EQUAL	HEAD: R60SL-90CRI-PDIM-FL WITH PENDANT T-TRAC AND QUANTITY OF HEADS AS SHOWN	120	10.5	854	LED 3,500K	AS DIRECTED BY ARCHITECT	PENDANT TRACK	FSA TL
UC	KELVX OR EQUAL	UC22-3040	277	12	899	LED 3,500K	UNDER CABINET	SURFACE	UC
V	VSUAL COMFORT OR APPROVED EQUAL	700BCFINN-24-B-LED935	277	24	1,252	LED 3,500K	ABOVE MIRROR	OUTLET BOX	FSA
W	LITHONIA COLUMBIA DAY-BRITE	ARC2-LED-P4-30K	277	30	3,903	LED 3,000K	AS DIRECTED BY ARCHITECT	OUTLET BOX	FSA
WE	LITHONIA COLUMBIA DAY-BRITE	ARC2-LED-P4-30K-E4WH	277	30	3,903	LED 3,000K	AS DIRECTED BY ARCHITECT	OUTLET BOX	EM FSA
W2	LITHONIA COLUMBIA DAY-BRITE	ARC2-LED-P2-30K	277	16	2,250	LED 3,000K	AS DIRECTED BY ARCHITECT	OUTLET BOX	FSA
W2E	LITHONIA COLUMBIA DAY-BRITE	ARC2-LED-P2-30K-E4WH	277	16	2,250	LED 3,000K	AS DIRECTED BY ARCHITECT	OUTLET BOX	EM FSA
W3	LITHONIA HUBBELL SIGNIFY	TWX2-LED-ALO-30K	277	39	6,850	LED 3,000K	8'-0" A.F.F.	OUTLET BOX	FSA
X1	LITHONIA COLUMBIA DAY-BRITE	LRP-1-GC-ELN OMIT BATTERY IF FED FROM INV	277	FURNISHED BY MANUFACTURER			CEILING OR ABOVE DOOR	RECESSED HOUSING	DI EMX FSA
X1P	LITHONIA COLUMBIA DAY-BRITE	LRP-1-GC-ELN-TM-ELA-US** OMIT BATTERY IF FED FROM INV	277	FURNISHED BY MANUFACTURER			BELOW LOWEST OBSTRUCTION	PENDANT STEM	DI EMX FSA
X2	LITHONIA COLUMBIA DAY-BRITE	LRP-2-GMR-ELN OMIT BATTERY IF FED FROM INV	277	FURNISHED BY MANUFACTURER			CEILING OR ABOVE DOOR	RECESSED HOUSING	DI EMX FSA
X2P	LITHONIA COLUMBIA DAY-BRITE	LRP-2-GMR-ELN-TM-ELA-US** OMIT BATTERY IF FED FROM INV	277	FURNISHED BY MANUFACTURER			BELOW LOWEST OBSTRUCTION	PENDANT STEM	DI EMX FSA
X3	LITHONIA COLUMBIA DAY-BRITE	LQMS-3-G-ELN	277	FURNISHED BY MANUFACTURER			CEILING OR ABOVE DOOR	OUTLET BOX	DI EMX FSA
Y2	LITHONIA HUBBELL SIGNIFY	DSX1-LED-P3-30K-80CRI-T2M-RPA-NLTAIR2-PIRHN	277	102	13,055	LED 3,000K	MOUNT TO 20'-0" ROUND, TAPERED STEEL POLE - SEE DETAIL "E-LP1"		FSA WC
Y3	LITHONIA HUBBELL SIGNIFY	DSX1-LED-P3-30K-80CRI-BLC3-RPA-NLTAIR2-PIRHN	277	102	9,606	LED 3,000K	MOUNT TO 20'-0" ROUND, TAPERED STEEL POLE - SEE DETAIL "E-LP1"		FSA WC
Y4	LITHONIA HUBBELL SIGNIFY	DSX1-LED-P4-30K-80CRI-BLC4-RPA-NLTAIR2-PIRHN	277	124	15,613	LED 3,000K	MOUNT TO 20'-0" ROUND, TAPERED STEEL POLE - SEE DETAIL "E-LP1"		FSA WC
Y4L	LITHONIA HUBBELL SIGNIFY	DSX1-LED-P2-30K-80CRI-BLC4-RPA-NLTAIR2-PIRHN	277	67.8	7,038	LED 3,000K	MOUNT TO 20'-0" ROUND, TAPERED STEEL POLE - SEE DETAIL "E-LP1"		FSA WC
Y5	LITHONIA HUBBELL SIGNIFY	DSX1-LED-P5-30K-80CRI-T5M-RPA-NLTAIR2-PIRHN	277	138	17,864	LED 3,000K	MOUNT TO 20'-0" ROUND, TAPERED STEEL POLE - SEE DETAIL "E-LP1"		FSA WC
LIGHTING FIXTURE SCHEDULE GENERAL NOTES: 1. CONTRACTOR SHALL COORDINATE ALL FIXTURE MOUNTING PROVISIONS WITH THE ASSOCIATED CEILING TYPE(S) PRIOR TO ORDERING FIXTURES. 2. ALL FIXTURES AND BALLASTS/DRIVERS SHALL BE RATED FOR OPERATION IN AMBIENT TEMPERATURES SUITABLE FOR THE ENVIRONMENT FOR WHICH THEY WILL BE INSTALLED. 3. TO ENSURE PROPER COORDINATION AND LONG TERM SUPPORT FOR THE OWNER, ALL LIGHTING FIXTURES SHALL BE PURCHASED THROUGH MANUFACTURER'S REPRESENTATIVES AND DISTRIBUTORS LOCATED WITHIN ONE HUNDRED & FIFTY (150) MILES OF THE PROJECT SITE. SUBMITTALS RECEIVED THAT DO NOT COMPLY WITH THIS REQUIREMENT WILL BE REJECTED WITHOUT REVIEW. THE CONTRACTOR SHALL BE RESPONSIBLE FOR ANY DELAYS CAUSED BY NON-COMPLIANCE WITH THIS REQUIREMENT.									
LIGHTING FIXTURE SCHEDULE KEYED NOTES: DI PROVIDE DIRECTIONAL INDICATORS AS SHOWN ON DRAWINGS. DMX PROVIDE INTEGRAL DMX COMPATIBLE DRIVER AND ASSOCIATED DMX CONTROL CIRCUITRY IN CONDUIT AS DIRECTED BY A/E. EM EMERGENCY FIXTURE. PROVIDE EMERGENCY BATTERY PACK RATED FOR AT LEAST 500 LUMENS. EMX EMERGENCY FIXTURE. PROVIDE EMERGENCY BATTERY PACK RATED FOR AT LEAST 90 MINUTES OF OPERATION. FCL FURNISH IN CONTINUOUS LENGTH AS REQUIRED TO MATCH LENGTH SHOWN ON PLANS. COORDINATE MOUNTING WITH CEILING SUPPLIER PRIOR TO BID. PROVIDE ALL YOKES AND OTHER MOUNTING ACCESSORIES AS REQUIRED. FSA PROVIDE FINISH AS SELECTED BY ARCHITECT. RD PROVIDE WITH REMOTE MOUNT DRIVER LOCATED ABOVE NEAREST ACCESSIBLE CEILING AS DIRECTED BY MANUFACTURER. DISTANCE FROM FIXTURE SHALL NOT EXCEED MANUFACTURER'S SPECIFICATIONS. TL FURNISH TRACK LENGTH AS SHOWN ON PLANS COMPLETE WITH ALL CONNECTORS, SUPPORTS, ETC. AS REQUIRED FOR A FULLY FUNCTIONAL TRACK LIGHTING SYSTEM. UC FURNISH THE GREATER QUANTITY OF ONE (1) TYPE "UC" FIXTURE PER CABINET SECTION OR ONE PER 24" OF LINEAR CABINET FOR LENGTH OF CABINET INDICATED ON PLANS. FIELD COORDINATE EXACT LOCATIONS WITH CABINETRY TO COORDINATE WITH UNDERCABINET MOUNTING STRUCTURE AND TO PROVIDE UNIFORM UNDERCABINET LIGHTING LEVELS. WC FURNISH FIXTURE WITH INTEGRAL WIRELESS DIMMING, WIRELESS NETWORKING AND INTEGRAL OCCUPANCY SENSOR CONTROLS.									



CALVARY CHURCH
CALVARY CHURCH FACILITY ADDITION
BENTONVILLE, AR

Revisions		
No.	Description	Date