



Addendum 2

HVAC Upgrades for BWHS, JLHS, and Arends Center

February 24, 2026

This Addendum is hereby made a part of the Contract Documents to the same extent as though it were originally included herein. This Addendum must be acknowledged in the space provided on the Bid Form.

General Information / Attachments

1. **Bid Date: February 26, 2026 at 2:00 PM**
2. **Attachments:**
 - a. Hight Jackson Addendum No. 02: Alternate Fencing Connection

END OF ADDENDUM 2

ADDENDUM NO: 02
 PROJECT NAME: HVAC Upgrades for BWHS, LJHS & AAC
 PROJECT ADDRESS: Bentonville & Centerton AR
 PROJECT NO: 2549


DATE: 2.24.2026
 HIGHT JACKSON ASSOCIATES
 ROGERS, AR
 ARCHITECTS AND PLANNERS

Contractor shall attach this and other addenda to the specifications and they shall be considered a part thereof. Where changes are required by this addendum, they shall nullify any conflicting specifications as may be affected.

ARCHITECTURAL

Item No. 1: **Refer to Architectural Sheet A1.1, detail A7.**

1. In lieu of coring through existing footing chain link fence installer is allowed to modify connection by providing base plate attachment to the top of the existing footing and angle attachment to the vertical edge of existing concrete slab. Specific attachment design is the responsibility of the installer to ensure a sound installation. See attached sketch for possible connection. Connection is required to both footing and slab edge.



END OF ADDENDUM NO. 02

-1-

Addendum No. 02
 HVAC Upgrades for BWHS, LJHS & AAC