



ROOF FRAMING NOTES:

1. "K" JOIST FRAMING: 2 1/2" JOIST SEATS (+/-) AS REQD. FOR ROOF SLOPE), U.N.O.
2. "DARK" SHADED AREA INDICATES EXISTING BUILDING.
3. WHERE JOISTS ARE DESIGNATED "SP", JOIST MANUF. SHALL DESIGN JOIST FOR THE FOLLOWING LOAD (MULTIPLIED BY JOIST SPACING): DEAD LOAD = 20 PSF; LIVE LOAD = 21 PSF; SNOW LOAD VARIES LINEARLY FROM VALUES INDICATED IN PLAN TO INTERIOR BALANCED SNOW LOAD OF 21 PSF; ANY ADDL. LOADS NOTED ON PLAN.
4. DRAIN PIPE LOADS AND RTU LOADS SHALL BE ADDED TO THE JOIST DESIGN BY THE MANUF.
5. SNOW DRIFT AREAS INDICATED BY DIAGONAL CROSS HATCH.
6. "LIGHT" SHADED AREAS INDICATE PREFAB CANOPY, BY OTHERS. CONNECTION TO LT. GA. FRAMING, BY OTHERS. PROVIDE ADDL. LT. GA. STUDS, AS REQD. AT CANOPY CONN. DO NOT CONN. CANOPY TO VENEER.

1 ROOF FRAMING PLAN
1/4" = 1'-0"



KEY ARCHITECTURE INC.
 P.O. BOX 748 FAYETTEVILLE, ARKANSAS 72702
 PH: 479.444.6066 FAX: 479.444.1445

Revision Schedule	Date	Description
Rev. #		

NWA PEDIATRICS ADDITION
 3730 S PINNACLE HILLS PKWY #3
 ROGERS, AR 72768

MANA
 3363 N MANA CT. SUITE 201
 FAYETTEVILLE, AR 72703

DATE	DRAWN BY
02/23/26	LCG
PROJECT #	CHECKED BY
2438	LCG
SHEET	ROOF FRAMING PLAN
S2	

JLA Engineers Incorporated
 STRUCTURAL CONSULTANTS
 P.O. Box 13
 TONNITTOWN, AR 72776
 TELEPHONE: (479) 770-6650
 JLA JOB #3245

CERTIFICATE OF AUTHORIZATION
 JLA ENGINEERS INCORPORATED
 No. 1594
 ARKANSAS

These Drawings and Specifications are the exclusive property of Key Architecture Inc. and are protected by Copyright. Use or reproduction is prohibited without written consent.