



Generated by COMcheck-Web Software

Interior Lighting Compliance Certificate

Section 1: Project Information

Energy Code: 2009 IECC
Project Title: 26085 - Oz Ortho
Project Type: Alteration
Construction Site: Owner/Agent: Designer/Contractor:

Section 2: Interior Lighting and Power Calculation

A Area Category	B Floor Area (ft2)	C Allowed Watts / ft2	D Allowed Watts (B x C)
Healthcare-Clinic	3880	1	3880
Total Allowed Watts =			3880

Section 3: Interior Lighting Fixture Schedule

A Fixture ID : Description / Lamp / Wattage Per Lamp / Ballast	B Lamps/ Fixture	C # of Fixtures	D Fixture Watt.	E (C X D)
Healthcare-Clinic (3880 sq.ft.)				
D1: Other:	1	47	12	564
D2: Other:	1	6	12	72
D3: Other:	1	19	14	266
H1: Other:	1	4	20	80
L1: Other:	1	4	18	72
L2: Other:	1	8	21	168
L3: Other:	1	2	47	94
P1: Other:	1	1	40	40
P2: Other:	1	1	36	36
P3: Other:	1	1	72	72
R1 7": Other:	1	2	9.6	19.2
R1 11": Other:	1	3	19	57
S1: Other:	1	3	10	30
U1: Other:	1	1	12.2	12.2
T1 187": Other:	1	1	14.3	14.3
T1 48": Other:	1	1	36	36
T1 31": Other:	1	1	14.3	14.3
T1 2": Other:	1	1	1.5	1.5
T1 36": Other:	1	3	3	9
T1 13'11": Other:	1	1	10.5	10.5
T1 6'4": Other:	1	1	5.3	5.3
T1 4'3": Other:	1	1	3.8	3.8
T1 6": Other:	1	1	4.5	4.5
T1 7'6": Other:	1	1	10	10
T1 14'4": Other:	1	1	11.3	11.3
T1 7'2": Other:	1	1	5.3	5.3
T2 5'6": Other:	1	1	4	4
T2 37": Other:	1	1	3	3
T2 3": Other:	1	2	2.3	4.6
T2 1'6": Other:	1	1	2	2

Project Title: 26085 - Oz Ortho Report date: 08/05/26
Data filename: Page 1 of 3

T2 7'4": Other:	1	2	5.5	11
T2 8'6": Other:	1	1	6.8	6.8
T2 12": Other:	1	1	9	9
T2 4'10": Other:	1	1	3.8	3.8
T2 2'5": Other:	1	1	2.5	2.5
L4: Other:	1	2	54	108
Total Proposed Watts =				1865

Section 4: Requirements Checklist

- Interior Lighting PASSES
- Lighting Wattage:**
- ☐ 1. Total proposed watts must be less than or equal to total allowed watts.
- | Allowed Watts | Proposed Watts | Complies |
|---------------|----------------|----------|
| 3880 | 1865 | PASSES |
- Controls, Switching, and Wiring:**
- ☐ 2. Daylight zones under skylights more than 15 feet from the perimeter have lighting controls separate from daylight zones adjacent to vertical fenestration.
- ☐ 3. Daylight zones have individual lighting controls independent from that of the general area lighting.
- Exceptions:**
- ☐ Contiguous daylight zones spanning no more than two orientations are allowed to be controlled by a single controlling device.
- ☐ Daylight spaces enclosed by walls or ceiling height partitions and containing two or fewer light fixtures are not required to have a separate switch for general area lighting.
- ☐ 4. Independent controls for each space (switch/occupancy sensor).
- Exceptions:**
- ☐ Areas designated as security or emergency areas that must be continuously illuminated.
- ☐ Lighting in stairways or corridors that are elements of the means of egress.
- ☐ 5. Master switch at entry to hotel/motel guest room.
- ☐ 6. Individual dwelling units separately metered.
- ☐ 7. Medical task lighting or art/history display lighting claimed to be exempt from compliance has a control device independent of the control of the nonexempt lighting.
- ☐ 8. Each space required to have a manual control also allows for reducing the connected lighting load by at least 50 percent by either controlling all luminaires, dual switching of alternate rows of luminaires, alternate luminaires, or alternate lamps, switching the middle lamp luminaires independently of other lamps, or switching each luminaire or each lamp.
- Exceptions:**
- ☐ Only one luminaire in space.
- ☐ An occupant-sensing device controls the area.
- ☐ The area is a corridor, storeroom, restroom, public lobby or sleeping unit.
- ☐ Areas that use less than 0.6 Watts/sq.ft.
- ☐ 9. Automatic lighting shutoff control in buildings larger than 5,000 sq.ft.
- Exceptions:**
- ☐ Sleeping units, patient care areas; and spaces where automatic shutoff would endanger safety or security.
- ☐ 10. Photocell/astromonical time switch on exterior lights.
- Exceptions:**
- ☐ Lighting intended for 24 hour use.
- ☐ 11. Tandem wired one-lamp and three-lamp ballasted luminaires (No single-lamp ballasts).
- Exceptions:**
- ☐ Electronic high-frequency ballasts; Luminaires on emergency circuits or with no available pair.

Section 5: Compliance Statement

Compliance Statement: The proposed lighting alteration project represented in this document is consistent with the building plans, specifications and other calculations submitted with this permit application. The proposed lighting alteration project has been designed to meet the 2009 IECC, Chapter 6, requirements in COMcheck-Web and to comply with the mandatory requirements in the Requirements Checklist.

Project Title: 26085 - Oz Ortho Report date: 08/05/26
Data filename: Page 2 of 3

Name - Title Signature Date

JOE
ARCHITECT



DYNAMIC MEP
CONSULTING ENGINEERS
303.421.3208 | info@dmce.com

Oz Orthodontics
3334 N Mana Ct, 3rd Floor, Fayetteville, AR 72703



REVISIONS		
#	Date	Description

DATE:	18 Aug 2026
PROJECT NO:	26085
DRAWN BY:	JG / MAB
ISSUED FOR:	Permit Set

COMCHECK

E3.0