



175 Montrose West Ave., Suite 400
Akron, OH 44321
330.665.0660
www.cesoinc.com

REVISION**1**Project: **TCC Mountain Home**Address: **2356-AR-201**City, ST: **Mountain Home, AR 72653****June 10, 2026**CESO #: **766951-01****FOR PROJECTS IN THE BIDDING PHASE (PRIOR TO CONTRACT AWARD):**

THIS REVISION (ADDENDUM) SUPPLEMENTS AND AMENDS THE ORIGINAL CONTRACT DOCUMENTS AND SHALL BE TAKEN INTO ACCOUNT IN PREPARING PROPOSALS, AND SHALL BECOME A PART OF THE CONTRACT DOCUMENTS. RECEIPT OF THIS REVISION MUST BE NOTED ON THE FORM OF PROPOSAL.

FOR PROJECTS IN THE CONSTRUCTION PHASE (OR FOLLOWING CONTRACT AWARD):

1. THIS REVISION (BULLETIN) IS A REQUEST FOR A QUOTATION ONLY, AND IS NOT AN AUTHORIZATION TO PROCEED WITH THE CHANGES PROPOSED. SUCH AUTHORIZATION MAY BE ISSUED LATER.
2. MATERIAL AND INSTALLATION SHALL COMPLY WITH THE CONTRACT DRAWINGS AND SPECIFICATIONS.
3. THE CONTRACTOR SHALL PROVIDE TO THE OWNER, ON CONTRACTOR'S LETTERHEAD, A STATEMENT OF PROPOSED CHANGES AND CONTRACT TIME LIMITS, OR STATING THAT NO CHANGE IS REQUIRED. PRICES, WHETHER PROPOSED ADDITIONS OR DEDUCTIONS, SHALL BE ACCOMPANIED BY AN ITEMIZED BREAKDOWN IN SUFFICIENT DETAIL TO BE EVALUATED BY THE OWNER AND ARCHITECT. REFER TO FRONT END SPECIFICATIONS OR OWNER'S CONTRACT FOR CONSTRUCTION FOR ADDITIONAL PRICING BREAKDOWN REQUIREMENTS.
4. IT IS THE RESPONSIBILITY OF EACH CONTRACTOR TO REVIEW ALL CHANGES RELATING TO EACH BID PACKAGE AS DESCRIBED BELOW AND RELATE ANY CHANGES WHICH MAY OCCUR IN ACCORDANCE WITH THEIR WORK.

SUMMARY:

- Updates to the drawings and specs have been made to reflect changes to the building and site per the tenant, and revisions to reflect latest tenant standards. Revisions include the addition of a single user restroom and adjustments to the FIRE RISER room, ELECTRICAL room, DEMARC cage and relocation of roof hatch. The canopy was revised and load out doors and access doors were adjusted. Low voltage equipment were updated and tenant equipment was revised.
- While this narrative intends to identify all changes issued as part of this Revision, the Contractor shall carefully review the plans for any revisions that may not be identified herein.

DISTRIBUTION:

☒ OWNER - Trammell Crow
☒ TENANT(S)
☒ GENERAL CONTRACTOR - Catamount
☐ OTHER
☐ OTHER
☐ OTHER

DISCIPLINES:

☐ CIVIL
☒ ARCHITECTURAL
☒ STRUCTURAL
☒ PLUMBING
☒ MECHANICAL
☒ ELECTRICAL



175 Montrose West Ave., Suite 400
Akron, OH 44321
330.665.0660
www.cesoinc.com

REVISION**1**Project: **TCC Mountain Home**Address: **2356-AR-201****June 10, 2026**City, ST: **Mountain Home, AR 72653**CESO #: **766951-01****GENERAL****G0.01 COVER SHEET**

- BASIS OF DESIGN: Revised and added sources of standards.
- Added Sustainability Tracker.
- Revised Sheet Index for Revision Number and Date.
- Added Sheet G1.11.
- Revised name of Sheet A0.04.

G0.02 NOTES, ABBREVIATION, SYMBOLS AND RESPONSIBILITY MATRIX

- Removed Sustainability Notes.
- Project General Notes: Revised note 54.
- Project Symbols: Revised North Arrow.
- ABBREVIATIONS: Added FRT.
- RESPONSIBILITY MATRIX: Revised to meet tenant standards.

G1.00 CODE ANALYSIS AND LIFE SAFETY PLAN

- Code Basis of Design: Updated from typing error.
- Code -Building Information: Plans updated to reflect building changes, Canopy SF updated.
- Occupant Load: SF of space in Building Use Group S-1 updated to reflect plan changes.
- Egress Components: N001 door split into N001 and N002, which changed the number of exits, and the related calculations.
- Path of Travel Distances: Revised Travel Distances for path 1A and 1B.
- New single-use restroom added to Plumbing Fixture Requirements table.
- New single-use restroom added to Accessible Toilet Stall Requirements table.
- 1/G1.00: Revised plan to reflect launchpad canopy reconfiguration, office block changes and changes from current tenant standards.
- 1/G1.00: N001 door split into N001 and N002, and renamed doors to reflect this.
- 1/G1.00: Revised North Arrow.

G1.01 OFFICE CORE LIFE SAFETY PLAN

- Path of Travel Distances: updated Path 4A because of addition of new restroom.
- 1/G1.01: Added 116 Single User Restroom, revised Office Block.
- 2/G1.01: Text revised in Fire Extinguisher Mounting Detail to meet tenant standards.

G1.02 2010 ACCESSIBILITY STANDARDS

- Tactile Sign Requirements - Notes: Note 4 revised to meet tenant standards.
- 2/G1.02: Name revised to remove typing error.
- 3/G1.02: Name revised to remove typing error.
- 3/G1.02: Position of text revised for legibility.



175 Montrose West Ave., Suite 400
Akron, OH 44321
330.665.0660
www.cesoinc.com

REVISION**1**Project: **TCC Mountain Home**Address: **2356-AR-201****June 10, 2026**City, ST: **Mountain Home, AR 72653**CESO #: **766951-01**G1.10 BUILDING SIGNAGE AND GRAPHICS

- Revised detail callout numbers and titles.
- Reorganized signage on sheet.
- Revised sheet signage per newest signage guideline.

G1.11 BUILDING SIGNAGE AND GRAPHICS

- Added sheet in its entirety.
- Relocated signage from sheet G1.10.
- Revised sheet signage per newest signage guideline.

ARCHITECTURAL SITE PLANAS1.01 ARCHITECTURAL SITE PLAN

- New Site plan shown.
- Trash enclosure rotated, canopy over van loading area revised.
- Revised North Arrow.

ARCHITECTURALA0.01 WALL/PARTITION TYPES & DETAILS

- Detail 12/A0.01: To Deck 1-HR Rated detail revised to meet tenant standards.

A0.03 Ceiling Details

- Detail 12/A0.03: updated.

A0.04 SEISMIC DESIGN CATEGORIES D, E & F CEILING GRID DETAILS

- Lateral force bracing description revised to fix spelling errors.
- Sheet title revised.



175 Montrose West Ave., Suite 400
Akron, OH 44321
330.665.0660
www.cesoinc.com

REVISION**1**Project: **TCC Mountain Home**Address: **2356-AR-201****June 10, 2026**City, ST: **Mountain Home, AR 72653**CESO #: **766951-01****A1.01 OVERALL FLOOR PLAN**

- 1/A1.01: Layout revised to reflect office revisions per tenant.
- 1/A1.01: Storefronts along column grid 1 changed from type 3 to 2 per current client standards.
- 1/A1.01: Door N001 configuration changed to door N001 and N002 per current client standards. All other non-overhead door numbers adjusted.
- 1/A1.01: W010 revised to 4'-0" door in 4'-4" R.O. per current client standards.
- 1/A1.01: Revised launch pad and canopy design. Locations of overhead doors 401, 402 and 403 adjusted.
- 1/A1.01: Location of water coolers, low-voltage equipment, and other equipment relocated to accommodate tenant changes.
- 1/A1.01: IDF units and bollard layouts revised per current client standards.
- 1/A1.01: Signage AG-18 has been changed to AG-XX per current client signage standards.
- 1/A1.01: Panel joint location adjusted to eliminate panel joint conflict with revised locations of exterior doors 401 and 401A.
- 1/A1.01: Panel joint locations along column grid 7 slightly shifted to match structural.
- 3/A1.01: ENLARGED PLAN, IDF AND ACP LAYOUT added.
- 1/A1.01 & 2/ A1.01: Revised North Arrows.
- EQUIPMENT SCHEDULE added to sheet.
- Keynotes 0507, 0509, 0510, and 0538 have been revised to reflect current tenant standards.
- Keynotes 0514 and 2514 have been removed to reflect current tenant standards.

A1.02 ENLARGED OFFICE AND INTERIOR SIGNAGE PLANS

- 1/A1.02: Layout revised to reflect office revisions per tenant.
- 1/A1.02: ADA push button pedestal location adjusted to reflect current tenant standards.
- 1/A1.02: Adjusted insulation per office revisions per tenant.
- 1/A1.02: Relocated water cooler.
- 2/A1.02: Layout revised to reflect office revisions per tenant. Signage relocated and added for new restroom.
- 2/A1.02: Signage BS-R# added for Breakroom.
- 2/A1.02: Signage BS-2U revised to BS-2.
- Keynotes 1020, 1028, 1029, 1030, and 1501 have been added to reflect current tenant standards.
- Keynotes 0019 and 1017 have been removed to reflect current tenant standards.

A1.03 FINISH PLAN AND SCHEDULE

- 1/A1.03: Revised warehouse finishes per current tenant standards.
- 1/A1.03: Finish tags revised, to coordinate with elevations on A1.05 and current tenant standards.
- 1/A1.03: Finish tags added for new restroom.
- Sheet Note J revised to reflect current tenant standards.
- Material Finish Key Notes: F, K and M updated per current tenant standards.
- Material Finish Key: SC-0 updated to reflect current tenant standards.



175 Montrose West Ave., Suite 400
Akron, OH 44321
330.665.0660
www.cesoinc.com

REVISION**1**Project: **TCC Mountain Home**Address: **2356-AR-201****June 10, 2026**City, ST: **Mountain Home, AR 72653**CESO #: **766951-01****A1.04 OFFICE FURNITURE PLAN**

- 1/A1.04: Revised office furniture plan to reflect changes to office layout.
- Plumbing Fixture Schedule: quantities updated.
- Equipment Schedule: E-19 and E-20 Comments updated.

A1.05 ENLARGED RESTROOM PLANS AND RESTROOM ELEVATIONS

- 1/A1.05: Single User Restroom 116 added.
- 2/A1.05: Single User Restroom 116 added.
- 3/A1.05: Single User Restroom 116 added.
- 3/A1.05: Revised lighting fixtures in all Single User Restrooms.
- New restroom elevations 9/A1.05 and 10/A1.05 added.

A1.51 OVERALL REFLECTED CEILING PLAN

- SHEET NOTES: Added notes O, P and Q.
- Keynote 2010 has been revised to reflect current tenant standards.
- Revised canopy and view reference per tenant updates.
- Revised office block and roof ladder per tenant updates.

A1.52 OFFICE REFLECTED CEILING PLAN

- SHEET NOTES: Added notes O, P and Q.
- 1/A1.52: Added a Single Use Restroom and room tag.
- 1/A1.52: Revised Fire Riser, Electrical, and Demarc rooms and lighting.
- 1/A1.52: Revised roof ladder and commensurately adjusted view reference.
- 1/A1.52: Revised lighting fixtures in Single User Restrooms, Lactation Room, and Multi-Faith Room.
- 2/A1.52: Added a Single Use Restroom and room tag.
- 2/A1.52: Revised Fire Riser room.
- 3/A1.52: Revised roof ladder and location.

A1.61 OVERALL ROOF PLAN

- Revised location of 2510 keynote to match adjusted walk path.
- Swapped keynotes 2512 and 2511 near Grids 1 and 2.
- Added keynote 2512 to penetration near Grid D.
- Roof footpath reduced to only 3ft perimeter around roof units to reflect current tenant
- Typical dimensions of revised footpath given near column grid C and 2.
- Footpath adjusted for revised roof access point.
- Revised dimensions of roof access point.
- Revised canopy design and commensurately adjusted view reference.



175 Montrose West Ave., Suite 400
Akron, OH 44321
330.665.0660
www.cesoinc.com

REVISION**1**Project: **TCC Mountain Home**Address: **2356-AR-201****June 10, 2026**City, ST: **Mountain Home, AR 72653**CESO #: **766951-01****A2.01** **EXTERIOR ELEVATIONS**

- 1/A2.01: Revised canopy design, locations of exterior lighting, exterior doors, and overhead doors.
- 1/A2.01: Panel sizes adjusted to eliminate panel joint conflict with revised exterior door location.
- 2/A2.01: Revised locations of exterior lighting, to center in panels.
- 3/A2.01: Revised canopy design.
- 3/A2.01: Panel joint locations adjusted to match structural, exterior lighting centered on panels.
- 4/A2.01: Revised canopy design, storefront glazing, locations of exterior lighting, and exterior door.
- SHEET NOTES: Removed prior note G and relettered notes respectively.
- Keynotes 0507, 0509, and 0510 have been revised to reflect current tenant standards.

A3.01 **BUILDING SECTIONS**

- Revised "VAPOR RETARDER" to "VAPOR BARRIER".
- AA/A3.01: Revised launchpad canopy.

A3.21 **WALL SECTIONS**

- A/A3.21: Revised parapet cap.
- B/A3.21: Changed detail callout 10/A5.01 to be part of 9/A5.01.
- B/A3.21: Revised entry storefront and door glazing.
- B/A3.21: Removed exterior exit lighting over entry storefront.
- B/A3.21: Revised parapet cap.
- C/A3.21: Changed detail callout 10/A5.01 to be part of 9/A5.01.
- C/A3.21: Revised storefront glazing and base detail.
- C/A3.21: Revised parapet cap.
- D/A3.21: Changed detail callout 10/A5.01 to be part of 9/A5.01.
- D/A3.21: Changed overhead doors to meet tenant standards.
- D/A3.21: Revised track guard and insulation text to meet tenant standards.
- D/A3.21: Revised parapet cap.
- D/A3.21: Relocated launchpad canopy and text.
- E/A3.21: Changed detail callout 10/A5.01 to be part of 9/A5.01.
- E/A3.21: Revised dock door detail and text to meet tenant standards.
- E/A3.21: Revised track guard text to meet tenant standards.
- E/A3.21: Revised parapet cap.



175 Montrose West Ave., Suite 400
Akron, OH 44321
330.665.0660
www.cesoinc.com

REVISION**1**Project: **TCC Mountain Home**Address: **2356-AR-201****June 10, 2026**City, ST: **Mountain Home, AR 72653**CESO #: **766951-01****A5.01** **EXTERIOR DETAILS**

- 1/A5.01 Roof Ladder: Replaced to meet tenant standards.
- 2/A5.01 Roof Hatch: Revised to meet tenant standards.
- 4/A5.01 Plumbing Vent: Revised note for clarification.
- 7/A5.01 Parapet Step: Replaced to meet tenant standards.
- 8/A5.01 Typ. Roof Parapet: Cap and detail callout revised to meet tenant standards.
- 9/A5.01: Replaced FLASHING MEMBRANE detail with TOP OF WALL AT CONCRETE PANEL detail.
- 10/A5.01: Removed detail.
- 12/A5.01 Typical 2" Panel Joint: Added dimension.
- 14/A5.01 Typ. Roof Overflow Scupper - Sect: Changed 10" opening to 12".
- 15/A5.01 Roof Ladder: Added detail.
- 16/A5.01 Roof Penetration: Added detail.

A5.02 **TRASH ENLOSURE - CONCRETE**

- 1/A5.02: Trash Enclosure rotated to fit new site location.
- 1/A5.02: Enclosure doors changed to meet tenant standards.
- 2/A5.02: Enclosure doors changed to meet tenant standards.
- 4/A5.02: Top of enclosure wall revised to align with structural drawing, dimension added for slope at top of wall.

A5.03 **EXTERIOR DETAILS**

- 1/A5.03: Revised to meet tenant standards.
- 1/A5.03: DOCK EQUIPMENT SCHEDULE: DE 112 changed to 48".
- 2/A5.03: Revised for high speed roll up door to meet tenant standards.
- 2/A5.03: Added Clear Zone and AG-40 text to meet tenant standards.
- 4/A5.03: Removed note on bar grate tread finish, to align with tenant standards.
- 6/A5.03: Revised to meet tenant standards.
- 7/A5.03: Surface Bollard revised to be 4" meeting tenant standards.
- 13/A5.03: Surface bollard detail added.
- 14/A5.03: Added equipment plan, exterior elevation, and interior elevation.



175 Montrose West Ave., Suite 400
Akron, OH 44321
330.665.0660
www.cesoinc.com

REVISION**1****June 10, 2026**Project: **TCC Mountain Home**Address: **2356-AR-201**City, ST: **Mountain Home, AR 72653**CESO #: **766951-01****A6.01 DOOR TYPES, SCHEDULES, AND DETAILS**

- EXT. DOOR AND FRAME SCHEDULE: Associate Entry door changed and split into 2 doors
- EXT. DOOR AND FRAME SCHEDULE: Doors renamed to adjust for new entry door.
- EXT. DOOR AND FRAME SCHEDULE: Trash and DSP doors combined.
- EXT. DOOR AND FRAME SCHEDULE: Door W010 width changed to 4'-0".
- EXT. DOOR AND FRAME SCHEDULE: Comments for doors S009, W010 & W011 are reordered for clarity.
- OVERHEAD DOOR AND FRAME SCHEDULE: Doors 401, 402, 403 - LOAD-OUT-C changed to LOAD-OUT-S.
- OVERHEAD DOOR AND FRAME SCHEDULE: LOAD-OUT-S door type changed to G3.
- INT. DOOR AND FRAME SCHEDULE: Door 101 hardware changed to (ALT).
- INT. DOOR AND FRAME SCHEDULE: Door 115 frame type changed to DM1.
- GENERAL DOOR NOTES: Added note 13.
- DOOR SCHEDULE NOTES: Revised notes C and G.
- DOOR SCHEDULE NOTES: Added note O.
- DOOR ABBREVIATIONS: Added note "'T' INDICATES TEMPERED - CATEGORY II SAFETY GLASS ON BOTH PANES."
- DOOR AND FRAME TYPES: Removed G1.
- DOOR AND FRAME TYPES: Revised G and CLF1.
- DOOR AND FRAME TYPES: Added GT and DM1.
- DOOR AND FRAME TYPES: Added sections on G3 for Load-Out doors, and noted Dock door sections.
- STOREFRONT TYPES: Revised Storefront elevations 1& 2. Removed type 3.
- 11/A6.01: Revised detail.
- 14/A6.01: Revised detail.

A6.02 DOOR DETAILS

- 1/A6.02: Changed detail to G2-G3 DOOR - HEAD.
- 5/A6.02: Changed detail to G2-G3 DOOR - JAMB.
- 9/A6.02: Revised track guard note per Design Bulletin G-101.
- 10/A6.02: Changed detail to G2-G3 DOOR - SILL.
- 12/A6.02: Revised detail per tenant standards.

A8.01 LAUNCH PAD CANOPY PLANS

- Revised canopy, launchpad parking, doors, and lighting per tenant updates.
- Removed keynote 0002.
- Keynote 0023 has been revised to reflect current tenant standards.



175 Montrose West Ave., Suite 400
Akron, OH 44321
330.665.0660
www.cesoinc.com

REVISION**1**Project: **TCC Mountain Home**Address: **2356-AR-201****June 10, 2026**City, ST: **Mountain Home, AR 72653**CESO #: **766951-01****A8.02 LAUNCH PAD CANOPY SECTION AND DETAILS**

- 1/A8.02: Lowered canopy and adjusted minimum clear height of canopy to be 12'-0". Notes shifted to accommodate change in height.
- 1/A8.02: Roof note Revised from "ROOF PER SHEET A8.01" to "TPO ROOFING OVER 5/8" RECOVERY BOARD AND METAL DECK."
- 1/A8.02: Revised notes per Design Bulletin G-101.
- 1/A8.02: Changed launchpad doors per Design Bulletin G-101.
- 2/A8.02: Revised detail per Design Bulletin G-101.
- 3/A8.02: Revised detail per tenant updates.
- 5/A8.02: Revised notes per Design Bulletin G-101.
- 6/A8.02: Revised detail per Design Bulletin G-101.
- 7/A8.02: Corrected foundation detail.

STRUCTURAL**S1.00 FOUNDATION PLAN**

- Resize and relocate canopy.
- Relocate openings.
- Relocate and rotate trash enclosure.
- Add footing F4.

S1.10 ROOF FRAMING PLAN

- Resize and relocate canopy.
- Revise J4 and J5 joist loadings.
- Relocate Roof Hatch.

S3.00 GENERAL SCHEDULES AND DETAILS

- 3/S3.00: Update Canopy area on Roof Deck Diagram.

S3.20 EXTERIOR WALL ELEVATIONS

- Relocate canopy gridlines.
- Revise opening locations.
- Relocate panel joint between panel 008 and 009.

S3.21 EXTERIOR WALL ELEVATIONS

- Revise parapet step location.
- Add Knockout panel.

PLUMBING**P0.02 PLUMBING SCHEDULE**

- Revised Foot Bath model number.



175 Montrose West Ave., Suite 400
Akron, OH 44321
330.665.0660
www.cesoinc.com

REVISION**1**Project: **TCC Mountain Home**Address: **2356-AR-201****June 10, 2026**City, ST: **Mountain Home, AR 72653**CESO #: **766951-01****P1.01A LEVEL 1 SANITARY AND VENT PLAN**

- Revised canopy storm drain piping.

P1.01B LEVEL 1 SUPPLY PLAN

- Revised drinking fountain locations (EWC-2).

P1.02 PLUMBING ROOF PLAN

- Revised canopy roof area.

P3.01 PLUMBING ENLARGED PLANS

- Added Restroom 116 and associated plumbing.
- Revised floor drain location and associated piping in Fire Riser Room.

P3.02 PLUMBING ENLARGED PLANS

- Added Restroom 116 and associated plumbing.
- Revised Booster Pump location and associated piping in Fire Riser Room.

P5.01 PLUMBING DRAIN AND VENT RISER

- Added Restroom 116 and associated plumbing.

MECHANICAL**M0.02 MECHANICAL SCHEDULES**

- Updated Fan Schedule to accommodate new restroom.

M1.01 LEVEL 1 HVAC PLAN

- Fixed/Adjusted positions of equipment in rooms that have been modified.

M3.01 MECHANICAL ENLARGED PLANS

- Modified exhaust and supply ductwork to accommodate new restroom.
- Adjusted layout of fire riser and electrical room equipment.

ELECTRICAL**E1.01 OVERALL POWER PLAN**

- Added recep and FA strobe to new bathroom.
- Relocated electrical devices in NE corner for new bathroom.
- Adjusted electrical devices for relocated loadout doors.
- Relocated canopy receptacles to columns.
- Removed electrical device for removed water cooler.

E1.02 ROOF EQUIPMENT POWER PLAN

- Arch background change.



175 Montrose West Ave., Suite 400
Akron, OH 44321
330.665.0660
www.cesoinc.com

REVISION**1**Project: **TCC Mountain Home**Address: **2356-AR-201****June 10, 2026**City, ST: **Mountain Home, AR 72653**CESO #: **766951-01****E1.03 ENLARGED OFFICE ELECTRICAL PLANS**

- Relocated devices in Electrical, Fire Riser and NE corner of warehouse for addition of new bathroom.
- Relocated and added lights in Electrical, Fire Riser and NE corner of warehouse for addition of new bathroom.

E2.01 OVERALL LIGHTING PLAN

- Adjusted locations of exterior wall mounted lights.
- Added exterior wall mounted lights to match architectural.
- Added/adjusted canopy lights.
- Updated architectural background with new bathroom.

E2.02 INTERIOR LIGHTING PHOTOMETRICS

- New interior photometrics for new bathroom/office area adjustment.

E3.03 ELECTRICAL SCHEDULES

- Panelboard H1: Adjusted wire sizes for voltage drop and added spares to blank spaces.

E3.04 ELECTRICAL SCHEDULES

- Panelboard L3: Added spare to blank panel space.

E5.01 ELECTRICAL SITE PLAN

- Coordinated site lighting with new site plan.

E5.02 SITE PHOTOMETRICS

- New photometrics for revised site lighting layout.

SPECIFICATION**SECTION 000000 - COVER**

- Revision date added.

SECTION 000110 - TABLE OF CONTENTS

- Revised to reflect added and deleted sections, and indicated which specification sections have been revised.

SECTION 013300 - SUBMITTAL AND RFI PROCEDURES

- Added clarification to require design professionals responsive action in sections 1.2.A and 1.2.B.
- Added 1.2.C. Closeout Submittals.
- Added clarification to section 1.4.D.2.
- Added clarification for submittal time period of 10 business days to section 3.4.F.
- Added clarification to section 3.4.K.
- Removed sections 3.4.R - 3.4.DD.



175 Montrose West Ave., Suite 400
Akron, OH 44321
330.665.0660
www.cesoinc.com

REVISION**1**Project: **TCC Mountain Home**Address: **2356-AR-201****June 10, 2026**City, ST: **Mountain Home, AR 72653**CESO #: **766951-01****SECTION 017329 - CUTTING AND PATCHING**

- Updated section name from 017300 - Execution and Closeout Requirements.

SECTION 017400 - PROGRESS CLEANING

- Added Section 017423 - Final Cleaning under Related Requirements in section 1.1.C.
- Removed section 3.2.

SECTION 017700 - CLOSEOUT PROCEDURES

- Updated bullets B and C under section 1.3.
- Updated bullets 1 and 2 under section 1.5.
- Removed parts 2 and 3.

SECTION 019113 - GENERAL COMMISSIONING REQUIREMENTS

- Add section in its entirety.

SECTION 080800 - COMMISSIONING OF OPENINGS

- Add section in its entirety.

SECTION 083323 - OVERHEAD COILING DOORS

- Remove section in its entirety.

SECTION 083615 - HIGH SPEED ROLL UP DOORS

- Add section in its entirety.

SECTION 097200 - WALL COVERINGS

- Remove section in its entirety.

SECTION 110800 - COMMISSIONING OF EQUIPMENT

- Add section in its entirety.

SECTION 220800 - COMMISSIONING OF PLUMBING SYSTEMS

- Add section in its entirety.

SECTION 230800 - COMMISSIONING OF HVAC SYSTEMS

- Content of section replaced in its entirety.

SECTION 238149 - ROOFTOP HEAT PUMP UNITS

- Revised language on Compressors under section 2.1.I to require modulating staged compressors.
- Revised language on Compressors under section 2.2.I to require modulating staged compressors.



175 Montrose West Ave., Suite 400
Akron, OH 44321
330.665.0660
www.cesoinc.com

REVISION**1**Project: **TCC Mountain Home**Address: **2356-AR-201**City, ST: **Mountain Home, AR 72653****June 10, 2026**CESO #: **766951-01**SECTION 250800 - COMMISSIONING OF BUILDING MANAGEMENT SYSTEM

- Add section in its entirety.

SECTION 260800 - COMMISSIONING OF ELECTRICAL EQUIPMENT

- Add section in its entirety.

SECTION ELECTRICAL QUALITY SPECIFICATION

- Add section in its entirety.

END OF REVISION 1BY: **Jacqueline Roman for CESO, Inc.**