







1 ENLARGED FLOOR PLAN - MECH 108 & MEN 107
SCALE: 1/4" = 1'-0"



2 ENLARGED FLOOR PLAN - WOMEN 106 & BREAKROOM 105
SCALE: 1/4" = 1'-0"





3 ENLARGED FLOOR PLAN - JAN 115 & FISH LAB 116
SCALE: 1/4" = 1'-0"



PLUMBING KEYED NOTES

1. PROVIDE PPP PR-500 SERIES TRAP PRIMER, AND IF REQUIRED DU-U MULTIPLE DRAIN CONNECTIONS, WITH WALL ACCESS PANEL.
2. PROVIDE PPP SC SERIES WATER HAMMER ARRESTOR.
3. 1" COLD WATER AND 1" HOT WATER DOWN TO WATER HEATER CONNECTION.
4. POINT OF CONNECTION OF 2" SANITARY SEWER TO ABOVE SLAB EXISTING 2" SANITARY SEWER PIPING.
5. 1/2" COLD WATER AND 1/2" HOT WATER DOWN IN WALL AND CONNECT TO LAVATORY FIXTURE.
6. 3/4" COLD WATER AND 3/4" HOT WATER DOWN IN WALL AND CONNECT TO SINK FIXTURE.
7. 1/2" COLD WATER DOWN IN WALL AND CONNECT TO ICE MAKER BOX.
8. 1-1/2" COLD WATER DOWN IN WALL AND CONNECT TO WATER CLOSET FIXTURE.
9. 1/2" COLD WATER DOWN IN WALL AND CONNECT TO ELECTRIC WATER COOLER FIXTURE.
10. POINT OF CONNECTION OF 4" SANITARY SEWER TO EXISTING 4" SANITARY SEWER PIPING.
11. POINT OF CONNECTION OF 2" SANITARY SEWER TO EXISTING 4" SANITARY SEWER PIPING.
12. POINT OF CONNECTION OF 3" SANITARY SEWER TO EXISTING 4" SANITARY SEWER PIPING.
13. 3/4" CONDENSATE DRAIN FROM MECHANICAL UNIT, ROUTE ALONG WALL AND SPILL TO FLOOR SINK WITH APPROVED AIR GAP.
14. 3/4" CONDENSATE DRAIN FROM MECHANICAL UNIT, AND SPILL TO SERVICE SINK WITH APPROVED AIR GAP.



NO.	DATE	DESCRIPTION
-----	------	-------------

25-065

07.30.2026

ISSUE

P103



ARKANSAS GAME AND FISH COMMISSION
JONESBORO FIELD OFFICE RECONSTRUCTION
600 EAST LAWSON RD
JONESBORO, AR 72404

ENLARGED PLANS - PLUMBING