

M.L. HARRIS
AUDITORIUM
RENOVATION



1 UPON ACTIVATION OF RATE OF RISE HEAT DETECTOR, THE FIRE ALARM SYSTEM SHALL RELEASE THE PROSCENIUM CURTAIN, OPEN SMOKE VENTS ABOVE STAGE, AND ACTIVATE AN ALARM SIGNAL



1. CROMWELL ARCHITECTS ENGINEERS, INC.
ALL RIGHTS RESERVED

2. THIS SHEET DESIGNED FOR COLOR PRINTING.
CRITICAL INFORMATION MAY BE LOST WITH
BLACK AND WHITE PRINTING.

2024-060

09-10-2026

**FIRE ALARM SECOND
FLOOR PLAN**

FA102