



- NOTES:**
1. ALCR SHALL BE UL 924 LISTED, EQUAL TO MEYERS MODEL EPC-2-D, AND SHALL ENERGIZE EMERGENCY LIGHTING UPON LOSS OF NORMAL POWER BY BYPASSING OTHER CONTROLS.
 2. INSTALL PER MANUFACTURER'S INSTRUCTIONS.
 3. MOUNT ALCRs ADJACENT TO INVERTER.
 4. TYPICAL CIRCUIT IS ILLUSTRATED. DUPLICATE FOR OTHER 3 LIGHTING CIRCUITS.
 5. EXTEND THIS CIRCUIT TO THE EMERGENCY DMX BYPASS DEVICE. SEE EL102 FOR LOCATION.

