



*Quality People. Building Solutions.*

Comfort Systems USA (Arkansas), Inc.  
P.O. Box 16620  
Little Rock, AR 72231  
Phone 501-834-3320  
Fax 501-834-5416

**Date:** 1/17/2024

**Return Request:** 1/27/2024

**Project:** Academies of Math & Science Little Rock

**Supplier:** Comfort Systems USA (Arkansas), Inc.

**Manufacturer:** Various

**Submittal:** HVAC Piping

**Submittal Number:** 23 00 00-01

**Drawing # and Installation:** Mechanical Drawings

**ARCHITECT**

Lewis Architects Engineers  
11225 Huron Lane, Suite 104  
Little Rock, AR 72211  
501-223-9302

**ENGINEER**

Lewis Architects Engineers  
11225 Huron Lane, Suite 104  
Little Rock, AR 72211  
501-223-9302

**GENERAL CONTRACTOR**

Clark Contractors  
15825 Cantrell Rd.  
Little Rock, AR 72223  
501-223-9302

**MECHANICAL SUBCONTRACTOR**

Comfort Systems USA (Arkansas), Inc.  
9924 Landers Rd.  
N. Little Rock, AR 72117  
501-834-3320

Notes:

**CSUSA PROJECT NO.**

**23-1028**

[jon@comfortar.com](mailto:jon@comfortar.com)

9924 Landers Rd.  
No. Little Rock, AR 72117

Pipe Valve & Fitting Schedule - Academies of Math & Science (HVAC)				
System	Spec Section	Pipe	Fittings	Joint
Condensate Drains - Interior	23 00 00; 2.6	Schedule 40 PVC Pressure; ASTM D2655	PVC Pressure Sch 40; ASTM D2655/ASTM D3311	Solvent Weld (Glue & Primer); ASTM D2564
Condensate Drains - Exterior	23 00 00; 2.6	Schedule 80 PVC Pressure; ASTM D2655	PVC Pressure Sch 80; ASTM D2655/ASTM D3311	Solvent Weld (Glue & Primer); ASTM D2564
Refrigerant Piping	23 00 00; 2.7	ACR Hard Copper	Wrought Copper Long Radius	Silfos; AWS A5.8 BCuP
Refrigerant Piping	23 00 00; 2.7	Line Sets; ASTM B1003	N/A	Silfos; AWS A5.8 BCuP