

*Quality People. Building Solutions.*

Comfort Systems USA (Arkansas), Inc.  
P.O. Box 16620  
Little Rock, AR 72231  
Phone 501-834-3320  
Fax 501-834-5416

**Date:** 5/17/2024

**Return Request:** 5/27/2024

**Project:** CALS Main Library Renovations

**Supplier:** Comfort Systems USA (Arkansas), Inc.

**Manufacturer:** Various

**Submittal:** Hydronic Piping

**Submittal Number:** 23 21 13-01

**Drawing # and Installation:** Mechanical Drawings

**ARCHITECT**

Polk Stanley Wilcox  
801 South Spring St.  
Little Rock, AR 72201  
501-378-0878

**ENGINEER**

Bernhard  
1 Allied Drive, Bldg. 2, Suite 2600  
Little Rock, AR 72202  
501-666-6776

**GENERAL CONTRACTOR**

CDI  
3000 Cantrell Rd.  
Little Rock, AR 72202  
501-5666-4300

**MECHANICAL SUBCONTRACTOR**

Comfort Systems USA (Arkansas), Inc.  
9924 Landers Rd.  
N. Little Rock, AR 72117  
501-834-3320

Notes:

**CSUSA PROJECT NO.**

**23-8016**

[dpierce@comfortar.com](mailto:dpierce@comfortar.com)

9924 Landers Rd.  
No. Little Rock, AR 72117

Pipe Valve & Fitting Schedule - CALS Main Library Renovation				
System	Spec Section	Pipe	Fittings	Joint
Heating Water Piping 2" & Below - Above Grade	23 21 13	Type L Hard Copper; ASTM B88	Wrought Copper; ASME B.16.22/Press Copper	Lead-Free Solder; ASTM B32/Press
Heating Water Piping 2 1/2" & Above - Above Grade	23 21 13	Schedule 40 Steel; ASTM A53	Schedule 40 Steel; ASME B16.3/ASTM A234	Welded/Threaded
Chilled Water Piping 2" & Below - Above Grade	23 21 13	Type L Hard Copper; ASTM B88	Wrought Copper; ASME B.16.22/Press Copper	Lead-Free Solder; ASTM B32/Press
Chilled Water Piping 2 1/2" & Above - Above Grade	23 21 13	Schedule 40 Steel; ASTM A53	Schedule 40 Steel; ASME B16.3/ASTM A234	Welded/Threaded
Equipment Drains & Overflows	23 21 13	Type M Hard Copper; B88	Wrought Copper; ASME B.16.29	Lead-Free Solder; ASTM B32