

*Quality People. Building Solutions.*

Comfort Systems USA (Arkansas), Inc.  
P.O. Box 16620  
Little Rock, AR 72231  
Phone 501-834-3320  
Fax 501-834-5416

**Date:** 3/13/2024

**Return Request:** 3/23/2024

**Project:** Stone Bank HQ - Chenal

**Supplier:** Fluid Solutions

**Manufacturer:** Nelson

**Submittal:** Heat Trace

**Submittal Number:** 22 00 00-04

**Drawing # and Installation:** Plumbing Drawings

**ARCHITECT**

WDD Architects  
5050 Northshore Lane  
N. Little Rock, AR 72118  
501-376-6681

**ENGINEER**

Batson Inc.  
1300 Brookwood Dr.  
Little Rock, AR 72202  
501-664-3311

**GENERAL CONTRACTOR**

East Harding  
2230 Cottondale Lane #3  
Little Rock, AR 72202  
501-661-1646

**MECHANICAL SUBCONTRACTOR**

Comfort Systems USA (Arkansas), Inc.  
9924 Landers Rd.  
N. Little Rock, AR 72117  
501-834-3320

Notes:

--


[dpierce@comfortar.com](mailto:dpierce@comfortar.com)



9924 Landers Rd.  
No. Little Rock, AR 72117

# Installation & Maintenance

---



---

SELF-REGULATING  
**HEATER CABLE**

---

---

## CONTENTS

CONTENTS .....	2
GENERAL INFORMATION .....	4
<i>How Heating Systems Work</i> .....	4
PRODUCT SELECTION .....	4
RECEIPT & STORAGE .....	4
<i>Receipt</i> .....	4
<i>Storage</i> .....	4
<i>Withdrawal from Storage</i> .....	4
CONDITIONS OF SAFE USE .....	5
INSTALLATION .....	7
<i>Scheduling</i> .....	7
<i>Pre-Installation Check</i> .....	7
<i>Heater Handling</i> .....	7
<i>Heater Cable Location</i> .....	8
<i>Straight Tracing</i> .....	8
<i>Spiraling</i> .....	8
<i>Attachment</i> .....	9
<i>Cutting the Heater Cable</i> .....	9
<i>Installation Details</i> .....	9
SYSTEM COMPONENTS .....	12
<i>Accessories</i> .....	12
THERMAL INSULATION .....	13
<i>Pre-Installation Checks</i> .....	13
<i>Installation</i> .....	13
<i>Marking</i> .....	13
THERMOSTATS & SENSORS .....	14
ELECTRICAL REQUIREMENTS .....	14
<i>Voltage Rating</i> .....	14
<i>Electrical Loading</i> .....	14
<i>Protection Requirements for Branch Circuits</i> .....	14
<i>Waterproofing</i> .....	15
<i>Testing</i> .....	15
<i>Procedure</i> .....	16
START-UP .....	19
<i>Heat-up Time</i> .....	19
<i>Diversity Factor</i> .....	19
OPERATION & MAINTENANCE .....	19

---

<i>System Design, Installation &amp; Documentation</i> .....	19
<i>Preventive Maintenance</i> .....	19
<i>Visual Inspections</i> .....	19
<i>Frequency</i> .....	19
<i>Personnel Training</i> .....	19
<i>Maintenance</i> .....	20
<i>Piping Repairs</i> .....	20
DAMAGED PRODUCTS .....	20
TROUBLESHOOTING .....	21

---

## GENERAL INFORMATION

The Installation and Maintenance Manual is intended for use with Nelson Heat Trace self-regulating heating cable and component system on insulated pipes and vessels only. These instructions are suitable for use with the heating cables and components listed on sheets 5, 6 and 13. For applications not specifically addressed, please contact your local representative.

### *How Heating Systems Work*

An electric heating cable system uses the heater cable to replace the heat that is lost through the thermal insulation system. Replacing the lost heat allows the pipe and product inside the pipe to be kept at a constant temperature. This will keep water from freezing and bursting a pipe, or a liquid from setting up and plugging the pipe. Simple systems may turn the entire system on with a contactor or switch, while others will use a thermostat or controller with each heater cable to regulate the temperature.




Figure 1

## PRODUCT SELECTION

Check and verify that the proper heater cables are being installed on each pipe and vessel. If no design/installation documents exist, check Nelson Heat Trace Design & Selection Guides to determine the proper equipment for the application.

## RECEIPT & STORAGE

### *Receipt*

- Compare the material received against the shipping bill to verify receipt of the correct product and quantities.
- Inspect heating cable and components for any shipping damage. Insulation resistance tests on each spool of cable are recommended.
- If design documents (line lists or per circuit bills of material) exist, check the received material against the lists to verify all needed materials. If no design documents exist, keep a receipt log of all materials received.
- Record Lot Numbers on the Heat Trace Installation Record (see Figure 15) for product traceability. Lot number coding is printed on the heating core of HLT and QLT cables, and on the first electrical jacket of all other cables. The last 2 digits designate the year of manufacture and the preceding digits represent the sequential lot numbering format. Example: 35407 would represent lot number 354 manufactured in 2007. Lot numbers are repeated every 30.5cm (12.0"). Lot numbers can also be located on each shipping spool identification label.

### *Storage*

Cable and system components should be stored in a clean, dry area. The equipment should be protected from mechanical damage during storage. The storage temperature range is -40°C to +60°C (-40°F to +140°F).

### *Withdrawal from Storage*

It is recommended that a check out record be kept (in conjunction with the receipt records) on equipment as it is removed from storage. This will serve to identify material shortages before they happen as project additions often cause the use of material for other than designated piping.

## CONDITIONS OF SAFE USE

### Ordinary Locations:

For ordinary location approvals, please refer to marking on respective product or contact manufacturer.

### Hazardous Locations:

#### Compliance with Safety Requirements has been assured by compliance with:

NEC® 2014; NFPA 70: National Electrical Code®, International Electrical Code Series

IEEE Std 515™-2011 Standard for the Testing, Design, Installation, and Maintenance of Electrical Resistance Heat Tracing for Industrial Applications

IEEE Std 515.1™-2012 Standard for the Testing, Design, Installation, and Maintenance of Electrical Resistance Heat Tracing for Commercial Applications

#### UL

Certificate No.	Coding
LT: E49805	Class I, Division 2, Group ABCD. Class II, Division 2, Group FG. Class III Class I, Zone 1 and 2, Group IIC
QLT: E49805	Class I, Division 2, Group ABCD. Class II, Division 2, Group FG. Class III Class I, Zone 1 and 2, Group IIC
HLT: E49805	Class I, Division 2, Group ABCD. Class II, Division 2, Group FG. Class III Class I, Zone 1 and 2, Group IIC
XLT: E49805	Class I, Division 2, Group ABCD. Class II, Division 2, Group FG. Class III
D1-LT: E49805	Class I, Division 1, Group BCD. Class II, Division 1 Group EFG. Class III
D1-HLT: E49805	Class I, Division 1, Group BCD. Class II, Division 1 Group EFG. Class III
D1-XLT: E49805	Class I, Division 1, Group BCD. Class II, Division 1 Group EFG. Class III

#### FM

Certificate No.	Coding
LT: AM2A4.AF	Class I, Division 2, Group BCD. Class II, Division 2, Group G. Class III Class I, Zone 1, Group IIC
HLT: AM2A4.AF	Class I, Division 2, Group BCD. Class II, Division 2, Group G. Class III Class I, Zone 1, Group IIC
D1-LT: 3004655	Class I, Division 1, Group BCD Class I, Zone 1, Group IIB
D1-HLT: 3004655	Class I, Division 1, Group BCD. Class I, Zone 1, Group IIB

#### CSA







Certificate No.	Coding
LT: LR 42104	Class I, Division 1 and 2, Group BCD. Class II, Division 1 and 2, Group EFG. Class I, Zone 1 and 2, Ex e IIC T6** (T5**).
HLT: LR 42104	Class I, Division 1 and 2, Group BCD. Class II, Division 1 and 2, Group EFG. Class I, Zone 1 and 2, Ex e IIC T3.
XLT: LR 42104	Class I, Division 1 and 2, Group BCD. Class II, Division 1 and 2, Group EFG. Class I, Zone 1 and 2, Ex e IIC T3.
LLT: LR 42104	Class I, Division 1 and 2, Group BCD. (US only) Class II, Division 1 and 2, Group EFG. (US only) Class I, Zone 1 and 2, Ex e IIC T3. (US only)

**Compliance with the Essential Health and Safety Requirements has been assured by compliance with:**

**ATEX:** EN 60079-0:2012 + A11:2013, EN 60079-30-1:2007, EN 60079-31:2014

**IECEx:** IEC 60079-0:2011, IEC 60079-30-1:2007, IEC 60079-31:2013

**KEMA**

Certificate No.	Coding
LT / UT-1: KEMA 07ATEX0124	0344  II 2 G Ex e IIC T6** Gb (LT3, LT23, LT5, LT25) II 2 D Ex tb IIIC T 80°C Db II 2 G Ex e IIC T5** Gb (LT8, LT28, LT10, LT210, UT-1) II 2 D Ex tb IIIC T 95°C Db
QLT: KEMA 07ATEX0124	0344  II 2 G Ex e IIC T3 Gb II 2 D Ex tb IIIC T 195°C Db
HLT: KEMA 07ATEX0124	0344  II 2 G Ex e IIC T3 Gb II 2 D Ex tb IIIC T 195°C Db
XLT: KEMA 07ATEX0124	0344  II 2 G Ex e IIC T3 Gb II 2 D Ex tb IIIC T 195°C Db
LLT: DEKRA 15ATEX0064	0344  II 2 G Ex e IIC T5 Gb II 2 D Ex IIIC T 95°C Db
UT-2: DEKRA 15ATEX0064	0344  II 2 G Ex e IIC T5 Gb II 2 D Ex IIIC T 95°C Db

**IECEx**

Certificate No.	Coding
LT / UT-1: IECEx KEM 07.0041	Ex e IIC T6** Gb (LT3, LT23, LT5, LT25) Ex tb IIIC T 80°C Db Ex e IIC T5** Gb (LT8, LT28, LT10, LT210, UT-1) Ex tb IIIC T 95°C Db
QLT: IECEx KEM 07.0041	Ex e IIC T3 Gb Ex tb IIIC T 195°C Db
HLT: IECEx KEM 07.0041	Ex e IIC T3 Gb Ex tb IIIC T 195°C Db
XLT: IECEx KEM 07.0041	Ex e IIC T3 Gb Ex tb IIIC T 195°C Db
LLT: IECEx DEK15.0032	Ex e IIC T5 Gb Ex tb IIIC T 95°C Db
UT-2: IECEx DEK15.0032	Ex e IIC T5 Gb Ex tb IIIC T 95°C Db

\*\* For more specific details on approvals, please refer to marking on respective product or contact manufacturer.

**Electrical Data:**

Product	Rated Voltage	Maximum Overcurrent Protection	Maximum Steady-State Current
LT, QLT, HLT, D1-LT, D1-HLT	100V, 110V, 120V	40 Amps	18 Amps
LT2, QLT2, HLT2, UT-1, D1-LT2, D1-HLT2	200V, 208V, 220V, 230V, 240V, 277V	40 Amps	18 Amps
XLT	100V, 110V, 120V	40 Amps	25 Amps
XLT2	200V, 208V, 220V, 230V, 240V, 277V	40 Amps	25 Amps
LLT / UT-2	200V, 208V, 220V, 230V, 240V, 277V	60 Amps	38 Amps

**Specifications:**

	LT / UT-1	QLT	HLT	D1-LT	D1-HLT	LLT / UT-2	XLT
Maximum Maintain Temperature	65°C (150°F)	121°C (250°F)	121°C (250°F)	65°C (150°F)	121°C (250°F)	65°C (150°F)	121°C (250°F)
Maximum Continuous Exposure Temperature (continuous power on)	65°C (150°F)	121°C (250°F)	121°C (250°F)	65°C (150°F)	121°C (250°F)	65°C (150°F)	150°C (300°F)
Maximum Intermittent Exposure Temperature (1000 hours cumulative exposure)	85°C (185°F)	121°C (250°F)	215°C (420°F)	85°C (185°F)	215°C (420°F)	85°C (185°F)	232°C (450°F)
Temperature Classification (Cable wattage if applicable)	T6** (3, 5) T5** (8, 10)	T3	T3	T6** (3, 5) T5** (8, 10)	T3 (3 - 15) T2C (18, 20)	T5	T3
Minimum Installation Temperature	-40°C (-40°F)	-40°C (-40°F)	-40°C (-40°F)	-40°C (-40°F)	-40°C (-40°F)	-40°C (-40°F)	-40°C (-40°F)
Minimum Bend Radius at -40°C (-40°F)	25.0 mm (1.0 in)	25.0 mm (1.0 in)	25.0 mm (1.0 in)	25.0 mm (1.0 in)	25.0 mm (1.0 in)	25.0 mm (1.0 in)	25.0 mm (1.0 in)

TULSA, OK 74101 ■ TEL 918-627-5530 ■ FAX 918-641-7336 ■ www.nelsonheaters.com

**GA-1765 Rev. 9**

Sheet 6 of 22

August 2016



# INSTALLATION

## General Information

While there are many acceptable ways of installing Nelson Heat Trace electric heating equipment, certain actions can be dangerous to personnel and your installations. Please take care to avoid the following problems:

- **Do not twist the bus wires together at either end of the heater cable. Each of these wires has a voltage or neutral applied to it; twisting them together will cause a short circuit.**
- **Insulate the black polymer surrounding the bus wires. The black compound around the bus wires is electrically conductive and should be treated as a conductor.**
- **De-energize all power circuits before installation or servicing.**
- **Keep ends of the heating cable and kit components dry before and during installation.**
- **To prevent electrical arcing and fire hazard, all cable connections and electrical wiring connections should be sealed against moisture. This includes the use of proper cable sealing kits and the moisture proofing of all wire connections.**
- **The metal sheath/braid of the heater cable must be connected to a suitable ground path.**
- **Do not use products containing plasticizers, such as vinyl electrical tape, or duct tape when installing self-regulating heater cables.**
- **Do not expose heater cables to temperatures above their maximum ratings. Higher temperatures can greatly shorten the life of a heater cable.**
- **Immediately replace any damaged heater cable or components. Failure to replace any damaged components (heater cable, components, or thermal insulation) will result in system failure.**
- **Classified areas (explosive dust or gases) require the use of special electrical components. Any area having explosive gases (such as chemical / petrochemical installations) or explosive dusts (such as coal handling or granaries) require special cable, connection components and control components that are approved for use in these areas. Installation of non-approved products can result in fires or explosions.**
- **Installation on plastic pipe requires special considerations in selections & installation. See the Nelson Heat Trace Design Guide for details in design and selection.**
- **To prevent creases it shall be assured that the minimum bending radius is 25 mm (1.0inch).**
- **All the self-regulating heating cables have minimum installation temperature of - 40°C (- 40°F).**

## Scheduling

The installation of the electric heat tracing requires coordination with the piping, insulation, electrical and instrument groups. Cable installation should begin only after the majority of mechanical construction is complete. Pressure testing of the pipe and installation of the instruments should be complete prior to the start of the heater cable installation.

## Pre-Installation Check

Walk the piping system and plan the routing of the heater cable. This action is used to verify completion of all instrumentation and mechanical work. All coatings (paint, etc.) and surfaces must be dry before attempting the heater cable installation.

## Heater Handling

- To avoid damage, use a reel holder to roll out the heater cable.
- Keep the cable strung loosely and close to the pipe being traced. This will avoid interference with supports and other equipment.
- Leave an extra 30-46cm (12-18") of heater cable at all power connections, tee splices and end seal connections to facilitate ease of working with the connections.
- **Additional heater cable is required on valves, pipe supports and other equipment.** See the installation detail section for exact lengths and method of installation.
- When handling the heater cable, avoid pulling it over or installing against sharp edges.
- Do not kink or crush the cable, including walking on it or driving over it with equipment.



## Heater Cable Location

The heater cable may be installed in either straight runs or spiraled around the pipe. Spiraling is generally used when a limited number of cable types are available. Where possible, the heating cable shall be applied flat to the heated object.

## Straight Tracing

When straight tracing is used, install the heater cable on the lower quadrant of the pipe. This helps prevent physical damage to the heater cable from falling objects and from being walked on.




Figure 2

## Spiraling

Spiraling increases the length of heater cable installed per foot of pipe. Installed cable length = Pipe Length X Spiral Factor.

The following example and table will allow you to determine the correct pitch for each pipe size and spiral factor:

*Example: When using .43m (1.4ft) of heater cable on 102mm (4") IPS pipe, the Pitch (P) would be 356mm (14")*




Figure 3


Table I  
Spiral Pitch Table (Inches)

Pipe Size (IPS)	SPIRAL FACTOR (feet of heater cable per foot of pipe)				
	1.1	1.2	1.3	1.4	1.5
1.0	NR	NR	NR	NR	NR
1.5	NR	NR	NR	NR	NR
2.0	17	NR	NR	NR	NR
2.5	20	14	NR	NR	NR
3.0	24	17	13	NR	NR
3.5	28	19	15	13	NR
4.0	31	21	17	14	NR
4.5	35	24	19	16	14
5.0	39	26	21	18	15
6.0	46	31	25	21	18
8.0	59	41	33	28	24


1 inch = 25mm

## Attachment

For normal installations, the heater cable may be attached with fiberglass tape. Plastic wire ties may also be used provided the plastic has a maximum temperature rating equal to or better than the system requirements. The cable should fit snugly against the pipe and be secured at one 305mm (12") intervals, as shown in Figure 4.



**Figure 4**



**Figure 5**

### Notes:

- 1) To prevent possible damage to the heater cable, do not fasten with metal straps, wire, vinyl electrical tape or duct tape.
- 2) Aluminum foil tape should only be used if specified by design. The tape is normally installed continuously along the entire length of the heater cable. The foil is most often used on plastic pipe to offset the insulating effect of the plastic. See the Nelson Heat Trace Design Guide for details. See Figure 5 above.

## Cutting the Heater Cable

Do not cut the cable until it is attached to the pipe. Confirm the allowances for terminations, connections and heat sinks (valves, support, etc.) before cutting the cable. Heater cable power output is not affected by cutting to length. Protect all heater cable ends from moisture and mechanical damage if exposed for long periods of time.


## Installation Details

Heater cables should be applied in a manner to facilitate the easy removal of valves and small in-line devices without the removal of excessive thermal insulation or having to cut the heater cable. The best way to accomplish this is to loop the cable. The amount of heater cable installed on each valve, hanger, etc. varies with the pipe size and type of device. Table II gives the correct amount of additional cable to be installed on each device.

---


## Installation Details (continued)

The following figures show installation details for various typical situations:




**Figure 6**

### Elbow




**Figure 7**

### Flange



**Figure 8**


## Hanger Support




**Figure 9**

## Shoe Support

Side View



Bottom View



**Figure 10**

Table II  
Heat Loss Adder

Pipe Fitting Type					
Pipe Size	Flange Pair	Vent & Drain	Pipe Support	Globe, Ball & Butterfly Valves	Gate Valve
.50	.30	1.0	1.0	1.0	1.0
.75	.30	1.0	1.5	1.0	1.5
1.00	.30	1.0	1.5	1.0	2.0
1.50	.30	1.0	2.0	1.5	2.5
2.00	.30	1.0	2.0	2.0	2.5
3.00	.30	1.0	2.0	2.5	3.0
4.00	.50	1.0	2.5	3.0	4.0
6.00	.80	1.0	2.5	3.5	5.0
8.00	.80	1.0	2.5	4.0	7.0
10.00	.80	1.0	3.0	4.5	8.0
12.00	.80	1.0	3.0	5.0	9.0
14.00	1.0	1.0	3.0	5.5	10.0
16.00	1.0	1.0	3.5	6.0	11.0
18.00	1.0	1.0	3.5	7.0	12.0
20.00	1.0	1.0	3.5	7.5	13.0
24.00	1.0	1.0	4.0	8.0	15.0

1 foot = 30.5 cm

### Notes:

- 1) Nominal pipe length is given in feet. Adders are for various in-line pipe fittings to compensate for greater areas of heat loss.
- 2) Values above are based on area average of various fittings available with the assumption that fitting insulation will be equivalent to pipe insulation. The nominal length of tracer to be applied to a particular fitting would be the value shown in this chart plus the flange-to-flange length of the fitting.
- 3) For a flanged valve, choose Valve Type and then add one Flange Pair for total adder length.

---

## SYSTEM COMPONENTS

Only Nelson Heat Trace approved termination, connection and splice kits should be used in accordance with manufacturer's installation instructions. Failure to do so will void warranties and agency approvals. For the connection of the heating cable to power, certified enclosures must be used that are suitable for the application and are correctly installed. When connecting to Ex e or other certified terminals using associated accessories, the required creepage distances and clearances shall be observed. Other terminations and connections, not mentioned in this document, that are to be installed as an integral part of the heating cable system, shall be certified according to the requirements of the applicable standards for their types of protection. Installation instructions in each component kit should be followed regarding heater cable preparation and assembly. Make end terminations and splice connections before making the power connections. It is recommended that all heater cables be tagged as they are installed with a discrete circuit number. Proper labeling will facilitate identification, component requirements and electrical wiring during later phases of the installation. Power, splice and tee connection kits utilize adapters for installation on equipment other than piping systems such as instrument tubing and tanks. Installation instructions for proper mounting are included in each kit.

### Accessories


Certification details can be found in the installation instructions of individual accessories, if applicable.

Type	Description	Applicable for
PLT Series	Connection System, non-metallic	LT, QLT, HLT, XLT
ALT Series	Connection System, metallic	LT, QLT, HLT, XLT
HASK Series	Connection System, Division 1 only	D1-LT, D1-HLT
AX Series	Connection System, NEC Wiring Methods	LT, QLT, HLT, XLT, UT-1
EX Series	Connection System, IEC Wiring Methods	LT, QLT, HLT, XLT, UT-1
AX-LLT Series	Connection System, NEC Wiring Methods	LLT, UT-2
EX-LLT Series	Connection System, IEC Wiring Methods	LLT, UT-2
HEC100	Connection System, end termination	LT, QLT, HLT, XLT, UT-1
HEC100-LLT	Connection System, end termination	LLT, UT-2
HEL100	Connection System, lighted end termination	LT, QLT, HLT, XLT, UT-1
HPC, HSC, HTC	Connection System, termination components	LT, QLT, HLT, XLT, UT-1
LT-ME, LT-MP	Cable Seal Kit	LT, QLT, HLT, XLT, UT-1
LLT-ME, LLT-MP	Cable Seal Kit	LLT, UT-2
LT-SE, LT-SP	Cable Seal Kit, shrink tubing	LT
LT-HSE, LT-HSP	Cable Seal Kit, shrink tubing	HLT, XLT
LT-SS, HSK-85	Splice Connections, shrink tubing	LT
LT-HSS	Splice Connections, shrink tubing	HLT, XLT
HPS, HES	Cable Seal Kit	LT, QLT, HLT, XLT, UT-1
GH-M25	Heater Cable Gland	LT, QLT, HLT, XLT, UT-1
HCSK	Heater Cable Sealing Kit	LT, QLT, HLT, XLT, UT-1
GHK-M25	Termination Kit	LT, QLT, HLT, XLT, UT-1

Refer to Figure 11 for common examples of heating cable and accessories installation for a standard piping application.

**WARNING:**

Connecting bus wires together  
will create an electrical short.

**Figure 11****THERMAL INSULATION*****Pre-Installation Checks***

Inspect the heater cable and components for correct installation and possible damage. In particular, verify that:

- The correct additional amount of heater cable has been installed at each valve, flange, pipe support, etc. and that it is free from nicks, tears or gouging. Additional cable beyond the specified amount at a heat sink is not a problem due to the self-regulation effect of the heater cable.
- Connections, splices and end seals are correctly installed, including cable seals in power connection enclosures.

***Installation***

Check the thermal insulation type and thickness against the design criteria. Changes in insulation type and/or thickness may require a different heater cable. Verify that all pipe work, including wall penetrations, fittings, etc. has been completely insulated.

Check the system to verify that:

- Insulation is not wet from rainfall or leakage prior to the application of waterproofing.
- Lap joints on vertical piping are properly installed - higher piece lapped over the top of lower piece.
- Band seals are used at lap joints to prevent the ingress of water.
- All penetrations of lagging (valve stems, hanger rods, etc.) are properly water proofed.
- Irregular shaped items (i.e. pumps, etc.) are properly waterproofed.

To minimize potential damage to the heater cable, install the insulation as soon as possible. It is recommended that another insulation resistance (megger) test be done after the insulation has been installed to verify that the heater cable was not damaged during the insulation installation.

***Marking***

Install "Electric Trace" signs on alternate sides of the piping at regular intervals as a warning to maintenance personnel. Permanently mark the outside of the insulation lagging with the location of heater cable components. This will facilitate maintenance in the event of a problem.

---

## THERMOSTATS & SENSORS

Temperature sensitive applications will require the use of temperature control. Selection of the proper thermostat or controller must consider voltage and amperage ratings of the device as well as the suitability of housing for the environment (explosion proof, rain tight, corrosion resistance, etc.). The enclosure housing should be mounted as close as possible to the power connection kit. It may be attached to the power connection kit provided code requirements are met with regard to connections seals, etc. To sense the coolest air temperature, ambient (air sensing) thermostats should be mounted in the shade when possible. When using pipe-sensing thermostats, the bulb (sensor) should be mounted on the opposite side of the pipe from the heater, or as far away as is practical. This will allow the thermostat to sense the actual pipe temperature and not be influenced by the heater temperature. Mount the bulb at least three (3) feet from the closest heat sink if possible.

Moisture inside the enclosure will cause both corrosion and electrical shorting problems. The potential for this type of problem can be greatly reduced by:

- Proper sealing of all enclosures openings.
- Keeping enclosure cover closed and secured as much as possible during installation sequence.
- Proper closing and sealing of the cover to prevent leaking into the housing.
- Use of a moisture proofing/electrical spray (aerosol) sealant on thermostat and electrical connections (including all metal parts) at completion of installation.
- Connection and use of space heater if thermostat is so equipped. **Do not de-energize space heater during summer months.**

## ELECTRICAL REQUIREMENTS

### ***Voltage Rating***

Verify that the heater cable voltage rating is suitable for the service being used. Cables with 240 volt ratings may be used with voltages from 200 to 277 volts, with an accompanying change in power output. See Nelson Heat Trace Design Guide for power correction factor. Nominal voltage and wattage ratings are printed on the heater cable.

### ***Electrical Loading***

Size the branch breakers or over-current protective devices according to Nelson Heat Trace Specification and Application Literature.

### ***Protection Requirements for Branch Circuits***

The National Electrical Code requires ground fault protection of equipment for electric heat tracing and heating panels. This requirement shall not apply in industrial establishments where there is alarm indication of ground faults and the following conditions apply:

- (1) Conditions of maintenance and supervision ensure that only qualified persons service the installed systems.
- (2) Continued circuit operation is necessary for safe operation of equipment or processes.

The Standards EN 60079-30-1:2007 and IEC 60079-30-1:2007 have the following minimum requirements for heat trace systems for use in explosive gas atmospheres:

All line conductors must have the ability to be isolated from the associated electrical supply.

Over-current protection must be provided for each branch circuit.

Protection against earth faults is required for all circuits. (See IEC 60364-5-55 for definitions).

For TT and TN systems:

The trace heater branch circuit protection shall be capable of interrupting high-impedance earth faults as well as short circuit faults. This shall be accomplished by an earth-fault protective device or controller with earth-fault interruption capability for use in conjunction with suitable circuit protection. The preferred trip level for adjustable devices is 30 mA above any inherent capacitive leakage characteristic of the heater as specified by the trace heater supplier. Where conditions of maintenance and supervision ensure that only qualified persons will service the installed systems, and continued circuit operation is necessary for the safe operation of equipment or processes, earth-fault detection without interruption is acceptable if alarmed in a manner to ensure acknowledged response.

For IT systems:

An electrical insulation monitoring device shall be installed to disconnect the supply whenever the electrical resistance is not greater than 50  $\Omega$  / V of rated voltage.

## **Waterproofing**

Moisture penetration of the electrical system is the single largest source of problems in a heater cable installation. Particular care must be given to the proper sealing of all electrical connections and splices. Heater cable sealing kits will provide a proper seal for the heater cable itself when used per kit instructions. All other electrical connections (heater to power wiring, thermostat connections, panel and breaker connections, etc.) should be sealed or moisture proofed in some fashion. Either mastic shrink tube or an aerosol electrical insulative sealant should be used on all connections to reduce any moisture penetration. The sealant will also reduce the potential for corrosion on exposed metal parts.

## **Testing**


Electrical tests are required at specific points in the installation of the heater cable. Periodical testing is designed to prevent the expenditure of wasted labor in the event of damage to the product. Installation costs of the cable and thermal insulation are much greater than the cost of the heater cable itself. Quick identification of any heater cable damage is the most economic approach to an installation. An insulation resistance test should be performed at the following points during the installation process:

- Upon RECEIPT of the heater cable
  - BEFORE thermal insulation installation
  - Immediately AFTER thermal insulation installation
- Note: ATEX certified installations require megger at this point*
- As part of a PERIODIC MAINTENANCE program



## Procedure

The insulation resistance test is used to check for damage to electrical jackets. Connections for the megger are shown in *Figures 12 & 13*.




### WARNING:

Do not connect bus wires together in the end cap as this will create an electrical short.

Figure 12

*Note: Test should use a minimum 1000 VDC megger. Do not use a megger with an excess of 2500 VDC. Minimum acceptable readings should be 20 megohms per circuit, regardless of length.*



### WARNING:

Do not connect bus wires together in the end cap as this will create an electrical short.

Figure 13

A record should be kept of the readings taken from the time the cable is first installed on the pipe. A history of the insulation resistance reading can be helpful in spotting moisture ingress into the electrical system by seeing a gradual decline in the insulation resistance or physical damage to the heater cable by seeing a sharp decline in the insulation resistance. A sample record for this is shown in *Figure 14*.

# NELSON HEAT TRACE

Circuit Number
Heater Type
Circuit Length

## Periodic Inspection Record

### Freeze Protection Circuits -

Perform these checks as season requiring use approaches.

### Temperature Maintenance Circuits -

Perform these checks at least twice per year.


Maintenance Checks for		Month	Year			
Visual inspection inside connection box corrosion, moisture, etc.	Initial					
	Date					
Damage or cracks (leaks) in insulation seals at valves, hangers, pumps, etc.	Initial					
	Date					
Heater cable properly connected and grounded. Heater cable and connections insulated from connection box.	Initial					
	Date					
Thermostat checked for moisture, corrosion, set point, switch operation, and capillary damage	Set Point					
	Initial					
	Date					
Megger tests performed at power connection with both bus wires disconnected from power wiring.	Reading					
	Initial					
	Date					
Circuit voltage at power connection.	Reading					
Circuit amperage after 5 minutes	Reading					
Pipe temperature at time amps were measured.	Reading					
Watts/Ft.						
Volts x Amps = w/ft. feet	Initial					
	Date					
All connections, boxes, and thermostats have been resealed.	Initial					
	Date					
End seals, covered splices and tees marked On insulation cladding.	Initial					
	Date					

Periodic Inspection Record Form

Remarks & Comments						

**Figure 14**  
**Periodic Inspection Record Form**

The Periodic Inspection record Form may be used in one of two ways:

- 1) **One Sheet per Circuit.** - The results of periodic tests of a single circuit are posted in vertical columns, beginning on the left and working toward the right. This allows easy comparison of test values for up to seven test sequences on an individual circuit.
- 2) **One Circuit per Column.** - Test data for a single test sequence can be recorded on a single sheet.

## Heat Trace Installation Record

**NELSON**  
**HEAT TRACE**

Location	System	Project Number	Reference Drawing(s)
Trace Heater Number	Line Number	Area Classification	AIT / T-Classification
Panel Number	Location	Circuit Number	Circuit Amp / Voltage
Trace Heater Mfg	Heater Model	Trace Heater Wattage unit length / Voltage Rating	
Megohmmeter Manufacturer / Model		Voltage Setting	Accuracy / Full Scale
Megohmmeter date of last calibration			
Multimeter Manufacturer / Model		Ohm Setting	Accuracy / Full Scale
<b>TRACE HEATER TESTING :</b>		Test Value / remarks	Date Initials
Note Minimum acceptable insulation resistance should be 20 megohms. Minimum acceptable test voltage is 500 Vdc. However 1000 Vdc recommended for MI, 2500 Vdc for polymeric cables.			
1. Receipt of Material on Reel			
Continuity Test on Reel (see note 1)			
Insulation Resistance Test on Reel			
2. Piping Completed (Approval to start heater installation)			
3. After Installation			
Continuity Test (see note 1)			
Insulation Resistance Test			
4. Trace heater Installed (Approval to start Thermal Insulation Installation)			
Trace heater correctly installed on pipe, vessel or equipment			
Trace heater correctly installed at valves, pipe supports, other heat sinks			
Components correctly installed and terminated (Power, Tee, End Seal)			
Installation agrees with manufacturers instructions and circuit design			
5. Thermal Insulation Installation Complete			
Continuity Test (see note 2)			
Insulation Resistance Test(5 megohm min)			
<b>SYSTEM INSPECTED :</b>		Date	Initials
6. Tagging & Identification Complete (Panel, Field Components, Pipe Decal)			
7. Trace heater effectively grounded			
8. Temperature Controls Properly installed & Set Points verified			
9. Ex-Proof Seals poured			
10. Thermal Insulation Weathertight (all penetrations sealed)			
11. End Seals, covered Splices marked on insulation outer cladding			
12. Drawings, Documentation marked as-built			
Performed by	Company	Date	
Witnessed by	Company	Date	
Accepted by	Company	Date	
Approved by	Company	Date	
<b>NOTES</b>			
1- Minimum acceptable insulation resistance should be 20 megohm. Minimum acceptable test voltage is 500 Vdc. However, 1000 Vdc recommended for MI, 2500 Vdc for polymeric trace heaters.			
2. Continuity test on self-regulating trace heater only used for short or open circuit.			

The **Heat Trace Installation Record** can be used to monitor the initial installation and check out process. This form can be used in conjunction with the **Periodic Inspection Record** shown in *Figure 14*.

**Figure 15**

## START-UP

### *Heat-up Time*

Heat-up capacity (the ability to heat the pipe and its contents rapidly) is not normally designed into the system. Cold start-ups should allow adequate time for the pipe to come up to temperature.

### *Diversity Factor*

If the electrical supply capability is limited, then a diversity factor may be used in a cold start situation. This is accomplished by staggering the initial turn on of the heater cable circuits to allow the inrush currents to occur in a sequential fashion rather than all at once.

## OPERATION & MAINTENANCE

### *System Design, Installation & Documentation*

The heater cable system must be properly designed, installed and documented. This documentation should include line lists and location identification documentation. As-built installation drawings provided the optimum maintenance tool. Test records should also be considered as part of the system documentation requirements. See Figure 15.

### *Preventive Maintenance*

A preventive maintenance program is needed which will encompass both visual and electrical checks of the system. These should be done not only before initial operation of the system, but also on a scheduled basis. The checks should also be done after any maintenance has been performed.

### *Visual Inspections*

- Thermal insulation - check weatherproofing for damage, missing seals, cracks or gaps in caulking and mastic coatings, damaged or missing lagging. When damage does exist, the insulation will need to be repaired or replaced, and then resealed. **Wet insulation has poor insulating properties and must be kept dry at all times.** If insulation has been damaged, check the heater cable for damage and replace any damaged sections.
- Inspect junction boxes, connection boxes and thermostats for corrosion, moisture or foreign matter.
- Tightness of electrical connections, proper electrical insulation of heater cable wires, adequacy of moisture seal on electrical connections and that a minimum of one (1) inch of electrically insulated heater extends above the grounding connection. No strands of the ground braid should extend above this connection.
- Check all thermostats or sensor capillary leads to verify they are tied back and shielded from physical damage.
- Verify all enclosure, connection box, etc. covers are properly closed and that the thermostat is switching off and on by measuring current flow in the circuit when the unit switches on. Reset the knob to the proper temperature after completion of the test.

### *Frequency*

Inspections should be made prior to the start of the season on freeze protection systems. Process maintenance systems should be checked on a frequent basis, at least twice a year.

### *Personnel Training*

Qualified maintenance personnel must be used to maintain the system. It is recommended that periodic training programs be utilized to assist in keeping maintenance personnel up to date on equipment and procedures.

---

## ***Maintenance***

The heater cables will not require any maintenance. Mechanical temperature controls should be sprayed with a moisture repellent/corrosion inhibitor once a year on all metal parts.

## ***Piping Repairs***

Disconnect the electrical connection from the heater cable and protect it from mechanical or thermal damage during the repair. Check the heater cable installation after the repairs per established procedures. Replace and water seal the thermal insulation system.

## **DAMAGED PRODUCTS**

Do not attempt to repair a damaged heater cable. Fault currents will often destroy the bus wire / core material interface between the damaged portion and the voltage supply end of the circuit.

Replace the damaged heater cable immediately. Moisture migration into the good section of the heater cable may cause electrical shorting in that cable after repair of the damaged section.

Any product exposed to fire or flame should be removed from service immediately and replaced. Further fire damage could result if energized.

## TROUBLESHOOTING

SYMPTOMS	PROBABLE CAUSE	CORRECTION
<b>A. Circuit Breaker Trips (Standard)</b>	<ol style="list-style-type: none"> <li>1. Circuit breaker undersized</li> <li>2. Circuit length is longer than designed</li> <li>3. Start-up temperature is lower than designed</li> <li>4. Defective circuit breaker</li> <li>5. Connections or splices may be shorting out</li> <li>6. Physical damage to the heater cable may be causing a short</li> <li>7. Wires connected at end seal</li> </ol>	<ol style="list-style-type: none"> <li>1, 2, 3. Re-establish the current loads and resize the breakers*</li> <li>4. Replace circuit breaker</li> <li>5, 6. Locate and repair incorrect or damaged connections, splices, or sections of heater cable. ** Megger per installation instructions</li> <li>7. Disconnect wires and perform a current check for possible other damage</li> </ol>
<b>B. Circuit Breaker Trips (Ground Leakage Type)</b>	<ol style="list-style-type: none"> <li>1. All of section A</li> <li>2. Excessive moisture in connection boxes or splices</li> <li>3. Nick or cut in heater or power supply wire with moisture present</li> </ol>	<ol style="list-style-type: none"> <li>1. All of section A</li> <li>2. Dry out and re-seal connections and splices. Megger per Installation Instructions (20 megohms min.) Work on connections outside the thermal insulation first, going to the below insulation connections and seals after the others have been eliminated</li> <li>3. Locate and repair or replace damaged heater cable or power wire **</li> </ol>

\*Check to see if existing power wire sizing is compatible with larger sized breakers.

\*\*To locate shorting problems, follow these steps:

- 1) Visually inspect the power connections and splices that are outside of the thermal insulation for proper installation.
- 2) Check around the valves, pumps, and any area where there may have been maintenance work done for visual indications of damage.
- 3) Look for crushed or damaged insulation lagging along the pipe.
- 4) Inspect heater cable splices, if any, that are located under the thermal insulation.
- 5) If you have not located the problem by now, you will have to isolate one section of the heater cable at a time until you determine the general area of damage. First, isolate sections by disconnecting any tees or splices then remove insulation from that area until the specific damage is found. For long runs of cable, it may be necessary to cut the cable in half to isolate the shorted section.

SYMPTOMS	PROBABLE CAUSE	CORRECTION
<b>C. Power output is zero or lower than rated ***</b>	<ol style="list-style-type: none"> <li>1. Low or no input voltage</li> <li>2. Circuit is shorter than designed <ol style="list-style-type: none"> <li>a. Splices or tees may not have been connected</li> <li>b. Heater cable may have been severed</li> </ol> </li> <li>3. Improper crimping causing a high resistance connection</li> <li>4. Control thermostat is wired in the opened position</li> <li>5. Pipe is at an elevated temperature</li> <li>6. Heater cable has been exposed to excessive moisture</li> <li>7. Heater cable has been exposed to excessive temperatures</li> </ol>	<ol style="list-style-type: none"> <li>1. Repair electrical supply lines and equipment</li> <li>2. Check routing and length of heater cable and recalculate power requirements <ol style="list-style-type: none"> <li>a. Connect and recheck the power</li> <li>b. Locate and repair the damaged heater cable. Recheck the power</li> </ol> </li> <li>3. Re-crimp using correct procedure</li> <li>4. Rewire in the normally closed position</li> <li>5. Check pipe temperature and recalculate the power output ***</li> <li>6, 7. Replace the heater cable</li> </ol>
<b>D. Power output appears correct but pipe temperatures are below design values</b>	<ol style="list-style-type: none"> <li>1. Insulation is wet</li> <li>2. Insufficient heater cable used on valves, supports, and other heat sinks</li> <li>3. Thermostat was set incorrectly</li> <li>4. Thermal design inconsistencies</li> </ol>	<ol style="list-style-type: none"> <li>1. Remove and replace with dry insulation and insure proper weatherproofing</li> <li>2. Splice in additional heater cable but do not go over maximum circuit length</li> <li>3. Reset the thermostat</li> <li>4. Check with the local or factory representatives for design conditions. Modify as recommended</li> </ol>

\*\*\* The power output on self-regulating heater cable is temperature sensitive and requires a special procedure to determine its value.

- 1) Check the pipe temperature under the thermal insulation.
- 2) Allow heater cable to stabilize for 10 minutes and then measure the current.
- 3) Calculate the power (watts / ft.) of the heater cable by multiplying the current by the input voltage and dividing by the actual circuit length,  $I \times V / Ft. = Watts / Ft.$
- 4) Compare this measured value to the power output curves for the heater cable at the measured pipe temperature. If the heater cable's actual output is substantially below the theoretical output, the cable may have been damaged by excessive temperature exposure or fault currents and the cable must be replaced. This is not a highly accurate method of analysis; judgment should be used when comparing theoretical and actual values



## LETTER OF TRANSMITTAL

---

TO: East Harding Construction

DATE: April 3, 2024

RE: Stone Bank

JOB NO.: 23-057

ATTN: Jake Honeycutt, Jack Whitley,  
Kim Brass


COPIES	DATE	NO.	DESCRIPTION
1 Emailed	03/18/24	22 00 00-100	Heat Trace

### THESE ARE TRANSMITTED:

☐ For Approval    ☐ As Requested    ☐ Reviewed for General Compliance    ☐ Resubmit \_\_\_ copies for approval  
☐ For Your Use    ☐ For Review and Comment    ☒ Reviewed and Noted    ☐ Submit \_\_\_ copies for distribution  
☐ For Your Information    ☐ Revise and Resubmit Notes    ☐ Return \_\_\_ corrected prints

### REMARKS:

COPY TO: Job File

BY:   
JoAnn White, CIT  
Contract Administrator





Attention:	<b>JoAnn White</b>	Date:	<b>4-1-24</b>
To:	<b>WDD Architects 5050 Northshore Ln North Little Rock, AR 72118</b>	Project:	<b>Stone Bank</b>
From:	<b>Eddi Carlisle</b>	Batson Project #	<b>5978</b>

Sent Via:	<input type="checkbox"/> Mail/Courier <input checked="" type="checkbox"/> Electronic <input type="checkbox"/> Hand Delivered <input type="checkbox"/> Other
For Your:	<input type="checkbox"/> Approval <input checked="" type="checkbox"/> Records <input type="checkbox"/> Review & Comments <input checked="" type="checkbox"/> Use
The Following:	<input type="checkbox"/> Drawings <input checked="" type="checkbox"/> Submittals <input type="checkbox"/> Specifications <input type="checkbox"/> Other

Copies	Dated	Rev No.	Description
1	3-18-24		22 00 00 100 HeatTrace Submittals

**Remarks:**

APPROVED ☐  
APPROVED AS CORRECTED ☒  
REVISE & RESUBMIT ☐  
NOT APPROVED ☐

Approval is only for conformance with the design concept of this project and compliance with the information given in the contract documents. Contractor is responsible for dimension to be confirmed and correlated at the job site; for information that pertains solely to the fabrication processes or to techniques of construction; and for coordination of this work of all trades.

SEE DOCUMENTS FOR COMMENTS ☐  
SEE ATTACHED COMMENT SHEET ☒

BATSON INC.  
1300 BROOKWOOD DRIVE  
LITTLE ROCK, AR 72202  
501.664.3311

DATE 4-1-24  
BY CEC

[illegible]



2230 Cottdale Lane, Suite 3  
Little Rock, AR 72202  
501.661.1646 – 501.661.9546 (fax)  
www.eastharding.com

Submittal  
#58

## Distribution Summary

Distributed on by

To:

Message:

Additional Attachments:

NAME	RESPONSE	ATTACHMENTS	COMMENT
------	----------	-------------	---------

## 23.038 220000 100 Heat Trace

SPEC SECTION:		CREATED BY:	
STATUS:	Open	DATE CREATED:	03/18/2024
ISSUE DATE:	03/18/2024	REVISION:	0
RESPONSIBLE CONTRACTOR:	Comfort Systems USA (Arkansas), Inc.	RECEIVED FROM:	Matthew Aldridge
RECEIVED DATE:	//	SUBMIT BY:	//
FINAL DUE DATE:	04/06/2024	LOCATION:	
TYPE:	Product Information	COST CODE:	
APPROVERS:	Jake Honeycutt (East-Harding, Inc.), Jack Whitley (East-Harding, Inc.), JoAnn White (Wittenberg, Delony & Davidson, Inc.)		
Project: 23.038:			
Architect's Project: 23-057:			
BALL IN COURT:			
Matthew Aldridge (Comfort Systems USA (Arkansas), Inc.)			
DISTRIBUTION:			
Kim Brass (East-Harding, Inc.) , Jon Isham (East-Harding, Inc.) , Jake Honeycutt (East-Harding, Inc.) , Jack Whitley (East-Harding, Inc.)			
DESCRIPTION:			
ATTACHMENTS:			

## SUBMITTAL WORKFLOW

#	NAME	SUBMITTER/ APPROVER	SENT DATE	DUE DATE	RETURNED DATE	RESPONSE	ATTACHMENTS	COMMENTS
1	Matthew Aldridge	Submitter		3/19/2024		Pending		
2	Jake Honeycutt	Approver		3/21/2024		Pending		
3	Jack Whitley	Approver		3/23/2024		Pending		
4	JoAnn White	Approver		4/6/2024		Pending		

BY

DATE

COPIES TO



## **SUBMITTAL DATA**

**Date:** March 5, 2024  
**Project:** Stone Bank  
**Contractor:** Comfort Systems USA  
**Engineer:** Batson Inc.

---

### **HEAT TRACE** (plan sheet P2.1 on the sanitary sewer)

130' total length of piping for heat trace

5 power connection kits

5 thermostats

Warning Signs

Wrapping tape

---

**6815 Dewaffelbaker Dr., Maumelle, AR 72113**

*Phone (501) 663-8886 • Fax (501) 663-8738*

*www.fluidsolutionsinc.com*


# Type LT Self-Regulating Heater Cable

## For use in Ordinary and Hazardous (Classified) Locations

<b>UL:</b> -CB, JT or -J options: Class I, Division 2, Groups A, B, C, D; Class II, Division 2, Groups F, G; Class I, Zone 1, AEx e II	<b>UL:</b> -D1 option: Class I, Division 1, Groups B, C, D; Class II, Division 1, Groups E, F, G; Class III	<b>CSA:</b> -CB, -JT or -J options: Class I, Division 2, Groups B, C, D; Class II, Division 2, Groups E, F, G; Class III; Class 1, Zone 2, Group IIB+H2	<b>CSA:</b> -J option: Class I, Division 1, Groups B, C, D; Class II, Division 1, Groups E, F, G; Class I, Zone 1, Group IIB, Zone 1, Ex e II T6 (T5)	<b>FM:</b> -CB, -JT or -J options: Class I, Division 2, Groups A, B, C, D; Class II, Division 2, Groups F, G; Class III	<b>FM:</b> -J option: Class I, Zone 1 AEx e II; Group IIC	<b>FM:</b> -D1 option: Class I, Division 1, Groups B, C, D
---	--	---	---	---	--	---

### Operating Principle

- The parallel bus wires apply voltage along the entire length of the heater cable.
- The conductive core provides an infinite number of parallel conductive paths permitting the cable to be cut to any length in the field with no dead or cold zones developing.
- The heater cable derives its self regulating characteristic from the inherent properties of the conductive core material.
- As the core material temperature increases, the number of conductive paths in the core material decrease, automatically decreasing the heat output.
- As the temperature decreases, the number of conductive paths increase, causing the heat output to increase.
- This occurs at every point along the length of the cable, adjusting the power output to the varying conditions along the pipe.
- The self regulating effect allows the cable to be overlapped without creating hot spots or burnout.
- As the cable self-regulates its heat output, it provides for the efficient use of electric power, producing heat only when and where it is needed, and also limiting the maximum sheath temperature.



### Accessories

- Nelson AX Series Connection Kits for Power, Splice, Tee Splice, Powered Splices and End Terminations
- Nelson HASK Series Division 1 Connection Kits for Power, Splice, Tee Splice and End Terminations
- Nelson EX Series Zone 1 Connection Kits for Power, Splice, Tee Splice and End Terminations
- Nelson TA, TH, TE and HC Series Thermostats and Contactors
- Junction Boxes, Tapes and Warning Signs
- Custom Control, Monitoring and Power Panels

### Description

- Nelson Type LT self-regulating heater cable is a parallel circuit electric heater strip.
- An irradiation cross-linked conductive polymer core material is extruded over the multi stranded, tin-plated, 16 gauge copper bus wires.
- The conductive core material increases or decreases its heat output in response to temperature changes.
- Two jackets provide extra dielectric strength, moisture resistance, and protection from impact and abrasion damage.
- The inner thermoplastic jacket is extruded over and bonded to the core material.
- A thermoplastic elastomer over jacket is then extruded over the inner jacket.
- A stranded tinned copper metal braid is supplied on all heaters.
- An optional over jacket (fluoropolymer or modified polyolefin) can be specified when the heater cable is to be installed in wet or corrosive environments.
- The base product is supplied with a tinned copper metal braid that may be used in both general applications and in dry, non corrosive hazardous (classified) areas.

### Application

- Nelson's Type LT self regulating heater cable is ideal for use in maintaining fluid flow under low ambient conditions.
- Freeze protection and low watt density process temperature systems such as product pipelines, fire protection, process water, dust suppression systems, lube oil, condensate return, hot water and structure anti-icing are typical applications for this product.

# Type LT Self-Regulating Heater Cable

## For use in Ordinary and Hazardous (Classified) Locations

**UL:**  
-CB, -JT or -J  
options: Class I,  
Division 2, Groups  
A, B, C, D; Class II,  
Division 2, Groups  
F, G; Class I, Zone  
1, AEx e II

**UL:**  
-D1 option: Class I,  
Division 1, Groups  
B, C, D; Class II,  
Division 1, Groups  
E, F, G; Class III

**CSA:**  
-CB, -JT or -J  
options: Class I,  
Division 2, Groups  
B, C, D; Class II,  
Division 2, Groups  
E, F, G; Class III;  
Class 1, Zone 2,  
Group IIB+H2

**CSA:**  
-J option: Class I,  
Division 1, Groups  
B, C, D; Class II,  
Division 1, Groups  
E, F, G; Class I,  
Zone 1, Group IIB,  
Zone 1, Ex e II T6  
(T5)

**FM:**  
-CB, -JT or -J  
options: Class I,  
Division 2, Groups  
A, B, C, D; Class II,  
Division 2, Groups  
F, G; Class III

**FM:**  
-J option: Class  
I, Zone 1 AEx e II;  
Group IIC

**FM:**  
-D1 option: Class I,  
Division 1, Groups  
B, C, D

### Performance Rating

Service Voltage	Maximum Maintenance Temperature °C (°F)	Maximum Intermittent Exposure °C (°F)	Watts/M (Watts/Ft)	T-Rating ①
120	65 (150)	85 (185)	10 (3)	T6
240				
120	65 (150)	85 (185)	16 (5)	T6
240				
120	65 (150)	85 (185)	26 (8)	T5
240				
120	65 (150)	85 (185)	33 (10)	T5
240				

### Circuit Breaker Selection

Watts/M (Watts/Ft)		Start-Up Temp. °C (°F)	Max. Length in Meters (Feet) Vs. Circuit Breaker Size							
			120 VAC				240 VAC			
			15A	20A	30A	40A	15A	20A	30A	40A
10 (3)	10 (50)	100 (320)	115 (370)	115 (370)	115 (370)	190 (630)	225 (740)	225 (740)	225 (740)	225 (740)
	-18 (0)	65 (220)	90 (290)	115 (370)	115 (370)	140 (465)	175 (580)	225 (740)	225 (740)	225 (740)
	-29 (-20)	60 (195)	80 (260)	115 (370)	115 (370)	115 (385)	155 (515)	225 (740)	225 (740)	225 (740)
16 (5)	10 (50)	65 (220)	85 (280)	85 (280)	85 (280)	135 (445)	170 (560)	170 (560)	170 (560)	170 (560)
	-18 (0)	45 (150)	60 (200)	85 (280)	85 (280)	90 (300)	120 (400)	170 (560)	170 (560)	170 (560)
	-29 (-20)	40 (135)	55 (175)	80 (265)	85 (280)	80 (265)	105 (350)	160 (525)	170 (560)	170 (560)
26 (8)	10 (50)	45 (150)	65 (205)	70 (225)	70 (225)	90 (300)	120 (400)	135 (450)	135 (450)	135 (450)
	-18 (0)	30 (105)	45 (140)	65 (215)	70 (225)	65 (210)	85 (285)	130 (425)	135 (450)	135 (450)
	-29 (-20)	30 (95)	40 (125)	60 (190)	70 (225)	60 (190)	80 (255)	115 (380)	135 (450)	135 (450)
33 (10)	10 (50)	40 (125)	50 (165)	60 (200)	60 (200)	75 (250)	100 (335)	120 (400)	120 (400)	120 (400)
	-18 (0)	25 (90)	40 (125)	55 (185)	60 (200)	55 (185)	75 (245)	110 (365)	120 (400)	120 (400)
	-29 (-20)	25 (85)	35 (110)	50 (165)	60 (200)	50 (165)	65 (220)	100 (330)	120 (400)	120 (400)

① Electrical equipment T rating codes define the maximum surface temperature that equipment will reach. It is used in hazardous (classified) area applications.

#### Notes



1. Circuit breakers are sized per national electrical codes.
2. When using 240 volt product at 208, 220 or 277 volts, use the circuit adjustment factors shown in the Voltage Adjustment Table.
3. When using 2 or more heater cables of different wattage ratings in parallel on a single circuit breaker, use the 15A column amperage of 15 amps, divide it by the maximum footage to arrive at an amps/foot figure for each cable. You can then calculate circuit breaker sizes for these combination loads. These amps foot factors include the 125% sizing factor.
4. National electrical codes require ground-fault equipment protection for each branch circuit supplying electric heating equipment. Exceptions to this requirement can be found in the N.E.C.
5. Heater cables with D1 optional construction require the use of ground fault interrupter/ground leakage device with a trip setting no greater than 30mA.

# Type LT Self-Regulating Heater Cable

## For use in Ordinary and Hazardous (Classified) Locations

<b>UL:</b> -CB, JT or -J options: Class I, Division 2, Groups A, B, C, D; Class II, Division 2, Groups F, G; Class I, Zone 1, AEx e II	<b>UL:</b> -D1 option: Class I, Division 1, Groups B, C, D; Class II, Division 1, Groups E, F, G; Class III	<b>CSA:</b> -CB, -JT or -J options: Class I, Division 2, Groups B, C, D; Class II, Division 2, Groups E, F, G; Class III; Class 1, Zone 2, Group IIB+H2	<b>CSA:</b> -J option: Class I, Division 1, Groups B, C, D; Class II, Division 1, Groups E, F, G; Class I, Zone 1, Group IIB, Zone 1, Ex e II T6 (T5)	<b>FM:</b> -CB, -JT or -J options: Class I, Division 2, Groups A, B, C, D; Class II, Division 2, Groups F, G; Class III	<b>FM:</b> -J option: Class I, Zone 1 AEx e II; Group IIC	<b>FM:</b> -D1 option: Class I, Division 1, Groups B, C, D
---	--	---	---	---	--	---

### Power Output Rating



# Type LT Self-Regulating Heater Cable

## For use in Ordinary and Hazardous (Classified) Locations

<b>UL:</b> -CB, JT or -J options: Class I, Division 2, Groups A, B, C, D; Class II, Division 2, Groups F, G; Class I, Zone 1, AEx e II	<b>UL:</b> -D1 option: Class I, Division 1, Groups B, C, D; Class II, Division 1, Groups E, F, G; Class III	<b>CSA:</b> -CB, -JT or -J options: Class I, Division 2, Groups B, C, D; Class II, Division 2, Groups E, F, G; Class III; Class 1, Zone 2, Group IIB+H2	<b>CSA:</b> -J option: Class I, Division 1, Groups B, C, D; Class II, Division 1, Groups E, F, G; Class I, Zone 1, Group IIB, Zone 1, Ex e II T6 (T5)	<b>FM:</b> -CB, -JT or -J options: Class I, Division 2, Groups A, B, C, D; Class II, Division 2, Groups F, G; Class III	<b>FM:</b> -J option: Class I, Zone 1 AEx e II; Group IIC	<b>FM:</b> -D1 option: Class I, Division 1, Groups B, C, D
---	--	---	---	---	--	---

Selection Table

Service Voltage	Maximum Segment Length Meters (Feet)	Description	Catalog Number
120	115 (370)	Tinned Copper Braid	LT3-CB
		Tinned Copper Braid and Fluoropolymer	LT3-J
		Tinned Copper Braid and Modified Polyolefin	LT3-JT
		Class 1, Division 1, Groups B, C and D	D1-LT3
240	225 (740)	Tinned Copper Braid	LT23-CB
		Tinned Copper Braid and Fluoropolymer	LT23-J
		Tinned Copper Braid and Modified Polyolefin	LT23-JT
		Class 1, Division 1, Groups B, C and D	D1-LT23
120	85 (280)	Tinned Copper Braid	LT5-CB
		Tinned Copper Braid and Fluoropolymer	LT5-J
		Tinned Copper Braid and Modified Polyolefin	LT5-JT
		Class 1, Division 1, Groups B, C and D	D1-LT5
240	170 (560)	Tinned Copper Braid	LT25-CB
		Tinned Copper Braid and Fluoropolymer	LT25-J
		Tinned Copper Braid and Modified Polyolefin	LT25-JT
		Class 1, Division 1, Groups B, C and D	D1-LT25
120	70 (225)	Tinned Copper Braid	LT8-CB
		Tinned Copper Braid and Fluoropolymer	LT8-J
		Tinned Copper Braid and Modified Polyolefin	LT8-JT
		Class 1, Division 1, Groups B, C and D	D1-LT8
240	135 (450)	Tinned Copper Braid	LT28-CB
		Tinned Copper Braid and Fluoropolymer	LT28-J
		Tinned Copper Braid and Modified Polyolefin	LT28-JT
		Class 1, Division 1, Groups B, C and D	D1-LT28
120	60 (200)	Tinned Copper Braid	LT10-CB
		Tinned Copper Braid and Fluoropolymer	LT10-J
		Tinned Copper Braid and Modified Polyolefin	LT10-JT
		Class 1, Division 1, Groups B, C and D	D1-LT10
240	120 (400)	Tinned Copper Braid	LT210-CB
		Tinned Copper Braid and Fluoropolymer	LT210-J
		Tinned Copper Braid and Modified Polyolefin	LT210-JT
		Class 1, Division 1, Groups B, C and D	D1-LT210



# Type LT Self-Regulating Heater Cable

## For use in Ordinary and Hazardous (Classified) Locations

<b>UL:</b> -CB, JT or -J options: Class I, Division 2, Groups A, B, C, D; Class II, Division 2, Groups F, G; Class I, Zone 1, AEx e II	<b>UL:</b> -D1 option: Class I, Division 1, Groups B, C, D; Class II, Division 1, Groups E, F, G; Class III	<b>CSA:</b> -CB, -JT or -J options: Class I, Division 2, Groups B, C, D; Class II, Division 2, Groups E, F, G; Class III; Class 1, Zone 2, Group IIB+H2	<b>CSA:</b> -J option: Class I, Division 1, Groups B, C, D; Class II, Division 1, Groups E, F, G; Class I, Zone 1, Group IIB, Zone 1, Ex e II T6 (T5)	<b>FM:</b> -CB, -JT or -J options: Class I, Division 2, Groups A, B, C, D; Class II, Division 2, Groups F, G; Class III	<b>FM:</b> -J option: Class I, Zone 1 AEx e II; Group IIC	<b>FM:</b> -D1 option: Class I, Division 1, Groups B, C, D
---	--	---	---	---	--	---

### Voltage Adjustment ①

Absolute Max Length Meters (Feet)	Adjustment Multiplier						Product
	208 VAC		220 VAC		277 VAC		
	Power	Length	Power	Length	Power	Length	
225 (740)	0.76	0.93	0.85	0.96	1.27	1.07	LT23
170 (560)	0.79	0.93	0.87	0.96	1.24	1.07	LT25
135 (450)	0.84	0.93	0.90	0.96	1.19	1.08	LT28
120 (400)	0.86	0.93	0.92	0.96	1.16	1.09	LT210

① Use of Self-Regulating heater products at other than rated voltages require minor adjustments in power and maximum circuit lengths.

Nelson's PLT Series non-metallic connection kits are Factory Mutual, Underwriter's Laboratory and Canadian Standards Association approved for use in ordinary and Division 2 hazardous areas when used with approved. PLT Series connection kits are approved for use with all Nelson LT, HLT and NC Series field-fabricated heating cables. Enclosures supplied in PLT Series connection kits are rated NEMA 4X.




### PLT-BC Power Connection Kit:

The PLT-BC Power Connection Kit is suitable for connecting up to two heating cables to customer supplied power wiring.

#### Kit Contents:

- 1 Universal Base, Box Adapter, Sealing Gasket, O-Ring and Locknut
- 1 Junction Box with Sealing Gasket and Cover
- 1 Sealing Grommet (Specify Cable Construction\*)
- 1 Power Termination and Cable End Seal with Adhesive Sealant
- 1 3-Point Floating Terminal Block
- 1 Ground Connection Splice
- 2 Stainless Steel Pipe Clamps (Specify Pipe Size)

\* Selection of -U grommet includes (1) additional power termination and (1) additional end seal for multiple cable entry.




### PLT-BS Splice Connection Kit:

The PLT-BS Splice Connection Kit is designed for connecting two heating cables in an in-line splice configuration.

#### Kit Contents:

- 1 Universal Base, Box Adapter, Sealing Gasket, O-Ring and Locknut
- 1 Junction Box with Sealing Gasket and Cover
- 1 Universal Sealing Grommet
- 2 Power Terminations with Adhesive Sealant
- 1 3-Point Floating Terminal Block
- 1 Ground Connection Splice
- 2 Stainless Steel Pipe Clamps (Specify Pipe Size)



### PLT-BY Tee Connection Kit:

The PLT-BY Tee Connection Kit is designed for connecting three heating cables in a tee splice configuration.

#### Kit Contents:

- 1 Universal Base, Box Adapter, Sealing Gasket, O-Ring and Locknut
- 1 Junction Box with Sealing Gasket and Cover
- 1 Watertight Connection Fitting and Hi-Temp Flexible Tubing
- 1 Sealing Grommet (Specify Cable Construction)
- \* Power Terminations and Cable End Seals with Adhesive Sealant
- 1 3-Point Floating Terminal Block
- 1 Ground Connection Splice
- 2 Stainless Steel Pipe Clamps (Specify Pipe Size)
- \* Number of cable terminations based on standard usage of tee splice configuration; (3) power terminations and (2) end seals.

PLT-

[illegible]

**EGS**  
Electrical Group

**NELSON  
HEAT TRACE**

# NELSON™ HEAT TRACING SYSTEMS

## TF4X40 THERMOSTAT

SPECIFICATION / APPLICATION  
INSTALLATION

### DESCRIPTION



These thermostats are used for controlling heat tracing systems in ordinary locations. The capillary bulb should be mounted on the side of the pipe.

### ENCLOSURE

Molded Fiberglass Polyester

### CLASSIFICATIONS

NEMA Type 4X IP66

### TEMPERATURE RANGE

#### Fixed Range

4.4°C (40°F)

### CAPILLARY

#### Length

0.9m (3ft.)

#### Material

Copper

#### Max. Bulb Temp.

71°C (160°F)

### ELECTRICAL DATA

#### CSA Rating

22 amp Resistance 480VAC

#### UL Rating

22 amp Resistance 480VAC


### CALIBRATION ACCURACY

2.2°C (4°F)

### SWITCH TYPE

Single Pole Single Throw

### OUTLINE



### Annual Maintenance:

1. Remove cover.
2. Spray a coat of lubricant and rust preventative such as CRC Stor & Lube, electrical grade, on the thermostat body.
3. Replace cover.

### Approvals:

#### General Locations

UL - E50023    CSA - LR52088-4    CE


# NELSON™ HEAT TRACING SYSTEMS

## TF4X40 THERMOSTAT


### SPECIFICATION / APPLICATION

### INSTALLATION

#### INSTALLATION



#### WIRING DIAGRAM



Nelson Heat Tracing Systems products are supplied with a limited warranty. Complete Terms and Conditions may be found on Nelson's website at [www.nelsonheaters.com](http://www.nelsonheaters.com).

# Accessories for Field Fabricated Heater Cables

## General Accessories

General Accessories for use with Type LT, HLT, XLT, CLT Self-Regulating Heating Cables

### Molded Silicone Terminations

- LT-MP (-LLT for Type LLT heating cable)
  - Molded Silicone Power End Termination Kit with Adhesive. Used for terminating field-fabricated heater cables inside the power connection box. Each kit makes 5 complete terminations.
- LT-ME (-LLT for Type LLT heating cable)
  - Molded Silicone End Seal Termination Kit with Adhesive. Used for terminating the ends of field-fabricated heater cables. Each kit makes 5 complete terminations.

### Quick-Connect End Seal Terminations

- CES Push-On End Seal Kit (Type CLT heating cable)
  - Quick connect SR End Seal Kit. Used for terminating the ends of field-fabricated heating cables and can be used on all 3, 5 and 8-watt CLT heating cables. Easy push-on design allows for quick installation, forming a permanent connection. Used without heat gun for portability on job site. Indoor/Outdoor approved for wet/dry Pipe Trace and Roof & Gutter applications. Each kit includes two (2) water-resistant End Seals.

### Heat Shrinkable Terminations

- LT-SP (Type LT/CLT)
- LT-HSP (Type HLT)
  - LT-NSP (Type NC)  
Heat-Shrinkable Power End Termination Kit. Used for terminating field-fabricated heater cables inside the power connection box. Approved for use with Braided (-CB) product, in ordinary (unclassified) areas. (Exception: LT-SP kits may also be used with Over Jacketed (-JT) product.) Each kit makes 5 complete terminations.
- LT-SE (Type LT/CLT)
- LT-HSE (Type HLT)
- LT-NSE (Type NC)
  - Heat-Shrinkable End Seal Termination Kit. Used for terminating the ends of field-fabricated heater cables. Approved for use with Braided (-CB,) product, in ordinary (unclassified) areas. (Exception: LT-SE kits may also be used with Over Jacketed (-JT) product.) Each kit makes 5 complete terminations.

### Pipe and Tank Adapters

- LT-P
  - Pipe Adapter Kit. Used to mount the base of PLT Series connection kits on small diameter (0.875" and below) pipe or tubing.
- LT-T
  - Tank Adapter Kit. Used to mount the base of PLT Series connection kits directly to the wall of a tank or vessel.
- HC-SPA
  - Pipe Adapter Kit. Used to mount the base of AX/EX Series connection kits on small diameter (1.315" and below) pipe or tubing.

### End of Circuit Lights

- PLK-120, PLK-208, PLK-240, PLK-277
  - End of Circuit Light Assembly. Used with Nelson PLT-L connection kits.
- LB6R
  - Spare Replacement Bulb. For PLK series light assemblies.

### Conduit Entry Seals

- ES-B (Braided Heater)
- ES-J (Over Jacketed Heater)
- ES-U (Multiple (2) Cable Entry or Special Constructions)
  - Waterproof Conduit Entry Seal, 0.5" NPT. Used for terminating field-fabricated heater cables when standard connection kits are not utilized.

### Pipe Clamps

- PC-03 (3.0" Diameter and below)
- PC-12 (3.5" – 12.0" Diameter)
- PC-20 (12.5" – 20.0" Diameter)
  - Pipe Clamps, stainless steel. Used to attach connection kits to pipe.

### Terminal Blocks

- TB-1 (3-Point)
- TB-4 (4-Point)
  - Floating Terminal Block. Used in any enclosure to provide positive, sure electrical connections. Rated 40 Amps at 440 Vac, requires no lugs.

### Universal Grommets

- PLT-U
  - Universal Grommet with Adhesive. Used with Nelson PLT-B kits for multiple (2) cable entry or special heater constructions.

### Junction Box

- JB552
  - Non-Metallic Junction Box, 5" x 5" x 2", NEMA 4X. Used for terminating field-fabricated heating cables.

### Warning Sign

- WS-100
  - Weatherproof Warning Sign. Used for cautioning maintenance personnel of the presence of electric heat tracing cable under the insulation. Attached to the outside of pipe insulation in frequent intervals. Black Lettering with Yellow background.

### Tape

- GT-60 (60 Yards)
- GT-6 (20 Yards)
  - Fiberglass Tape, 0.5" wide. Used to attach heater cables to pipe or to attach temperature sensors to the pipe when corrosive conditions prevent the use of aluminum tape.
- AT-50 (50 Yards)
  - Aluminum Foil Tape, 2.0" wide. Used to attach heater cable to vessels to dissipate heat on non-metallic surfaces or to attach thermostat sensing bulbs to pipes.