



1. COORDINATE WITH ALL OTHER DISCIPLINES FOR NEW AND EXISTING UNDERGROUND CONDITIONS PRIOR TO EXCAVATION RE: CIVIL PLANS
2. ROUTE CONDUIT TIGHT TO STRUCTURE, PERPENDICULAR AND PARALLEL TO STRUCTURAL BRACING. MOUNT ABOVE CEILING WHERE APPLICABLE.
3. COORDINATE WITH FIRE SUPPRESSION PLANS FOR FINAL LOCATION OF ALL FIRE SUPPRESSION DEVICES PRIOR TO ELECTRICAL ROUGH-IN.
4. CONTRACTOR SHALL REMOVE AND REMOUNT ALL HVAC AND ELECTRICAL DEVICES IN ROOMS WHERE THE CEILING WILL BE REPLACED. COORDINATE WITH ARCHITECTURAL PLANS.

- 1 EXISTING SERVER RECEPTACLES TO REMAIN ENERGIZED. PROVIDE NEW STANBY EMERGENCY POWER OUTLETS FOR SERVER RACK.
- 2 PROVIDE GENERATOR PAD WITH NEW GENERATOR. COORDINATE WITH MANUFACTURER SPECIFICATIONS AND CIVIL ENGINEER.
- 3 LOCATION OF GENERATOR PAD IS BASED ON AS BUILT DOCUMENTATION. CONTRACTOR SHALL SURVEY BELOW GRADE PRIOR TO EXCAVATION. COORDINATE WITH ENGINEER FOR RELOCATION OF PAD AS NECESSARY TO AVOID ALL UTILITIES. INSTALLING THE GENERATOR IN AN ALTERNATE LOCATION DUE TO UNFORESEEN CONDITIONS SHALL BE AT NO COST TO THE OWNER.
- 4 REMOVE FIRE ALARM CONTROL PANEL, CIRCUIT AND CONDUIT BACK TO SOURCE PANELBOARD. FIELD TRACE PRIOR TO REMOVAL. EXISTING EQUIPMENT SHALL REMAIN FOR CONNECTION TO NEW CIRCUITRY.
- 5 REMOVE ALL EXISTING LIGHTING FIXTURES, WIRE AND CONDUIT BACK TO NEAREST LIGHTING BOX IN ROOM THAT WILL HAVE DEMOLISHED WALLS. COORDINATE WITH ARCHITECTURAL PLANS FOR SCOPE OF DEMOLITION. TYPICAL.
- 6 PROVIDE NEW LIGHT FIXTURES WITHIN INDICATED ROOM. CONNECT TO NEAREST LIGHTING CIRCUIT. TYPE LITE TO BE LITIGLORA CSS L48 4000LM 100CRI 35K 80R1E/16WPC. TYPE AURA LITEX 224 4000LM 90CRI 35K 80R1E/27 MVOLT E10LWPC. TYPICAL.

**BILL AND HILLARY CLINTON
NATIONAL AIRPORT
LITTLE ROCK, ARKANSAS 72206**

DRAWING NUMBER
EP-107

