



NOTES:

1. AS AN OPTION, CONTRACTOR MAY PROVIDE PRICING TO REHABILITATE THE EXISTING SWITCHGEAR IN PLACE FOR USE WITH THE NEW PUMPS AND EQUIPMENT. THIS WILL INCLUDE ROUTING NEW CONDUCTORS TO NEW EQUIPMENT, CLEANING OF EXISTING GEAR, SOURCING AND REPLACING EXISTING BREAKERS AND OVERCURRENT PROTECTION TO MEET NEW REQUIREMENTS.



© 2025 GARVER, LLC  
IS DOCUMENT, ALONG WITH THE  
IDEAS AND DESIGNS CONVEYED  
HEREIN, SHALL BE CONSIDERED  
INSTRUMENTS OF PROFESSIONAL  
SERVICE AND ARE PROPERTY OF  
GARVER, LLC. ANY USE,  
REPRODUCTION, OR DISTRIBUTION  
OF THIS DOCUMENT, ALONG WITH  
THE IDEAS AND DESIGN CONTAINED  
HEREIN, IS PROHIBITED UNLESS  
AUTHORIZED IN WRITING BY  
GARVER, LLC OR EXPLICITLY  
ALLOWED IN THE GOVERNING  
PROFESSIONAL SERVICES  
AGREEMENT FOR THIS WORK.



Digitally Signed 05/02/2025

[illegible]

NATIONAL AIRPORT  
LITTLE ROCK, AR 72206

## FIRE SUPPRESSION IMPROVEMENTS

# ELECTRICAL ONE-LINE DIAGRAM BUILDING 1000

DB NO.: 21A10111  
DATE: MAY 2025  
DESIGNED BY: NAH  
DRAWN BY: ICC

BAR IS ONE INCH ON  
ORIGINAL DRAWING

DRAWING NUMBER

## EP-604