

PART 1 - GENERAL

1.1 SUMMARY

- A. Contractor shall provide and install a Schneider Electric Ecostuxure Smart X system for full control of all HVAC equipment. The system, controls, and computer shall replace all existing controls on the current HVAC equipment, and have the capacity to manage and expand to control all HVAC systems throughout the facility. The initial installation shall replace all field components and sensors associated with the Liebert Units that are part of this project as well as the two Liebert units in the detached Power Conditioning Building. The new system shall include all components and field wiring to make the new system fully operation when complete, including a new computer interface/control work station, with Enterprise Server software installed. Contractor shall create new EBO graphic page, and create new control schematic layout. Contractor shall provide and install all new CAT6 cable and ring topology network as required for a fully operational system.
- B. This Section includes control equipment for HVAC systems and components, including control components for terminal heating and cooling units not supplied with factory-wired controls.
- C. See Division 23 Section "Sequence of Operations for HVAC Controls" for requirements that relate to this Section.

1.2 SUBMITTALS

- A. Product Data: For each control device indicated.
- B. Shop Drawings:
  - 1. Schematic flow diagrams.
  - 2. Power, signal, and control wiring diagrams.
  - 3. Details of control panel faces.
  - 4. Damper schedule.
  - 5. Valve schedule.
  - 6. DDC System Hardware: Wiring diagrams, schematic floor plans, and schematic control diagrams.
  - 7. Control System Software: Schematic diagrams, written descriptions, and points list.
- C. Software and firmware operational documentation.
- D. Field quality-control test reports.
- E. Operation and maintenance data.

1.3 QUALITY ASSURANCE

- A. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, Article 100, by a testing agency acceptable to authorities having jurisdiction, and marked for intended use.

## PART 2 - PRODUCTS

### 2.1 MANUFACTURERS

- A. In other Part 2 articles where titles below introduce lists, the following requirements apply to product selection:
  - 1. Available Manufacturers: Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, manufacturers specified.
  - 2. Manufacturers: Subject to compliance with requirements, provide products by one of the manufacturers specified.

### 2.2 CONTROL SYSTEM

- A. Manufacturers:
  - 1. Schneider Electric
- B. Control system shall consist of sensors, indicators, actuators, final control elements, interface equipment, other apparatus, and accessories to control mechanical systems.
- C. Control system shall consist of sensors, indicators, actuators, final control elements, interface equipment, other apparatus, accessories, and software connected to distributed controllers operating in multiuser, multitasking environment on token-passing network and programmed to control mechanical systems. An operator workstation permits interface with the network via dynamic color graphics with each mechanical system, building floor plan, and control device depicted by point-and-click graphics.

### 2.3 DDC EQUIPMENT

- A. Operator Workstation: PC-based microcomputer as recommended by controls system manufacturer, but shall have no less than the following minimum configuration as follows:
  - 1. Monitor: 24 inches or greater, LCD color.
  - 2. Keyboard: QWERTY, 105 keys in ergonomic shape.
  - 3. Hard-Disk Drive: 1 TB
  - 4. CD-ROM Read/Write Drive:
  - 5. Mouse: Three button, optical.
  - 6. Operating System: Microsoft Windows – latest capability as required with high-speed Internet access.
  - 7. Printer: Color, Laser Printer with minimum print capability of 20 pages per minute
    - a. Paper Handling: Minimum of 500 sheets.
    - b. Paper: 8.5" x 11", and 11"x 17" capability.
    - c. Application Software.
- B. Control Units: Modular, comprising processor cards with programmable, nonvolatile, random-access memory; local operator access and display panel; integral interface equipment; and backup power source.
  - 1. Units monitor or control each I/O point; process information; execute commands from other control units, devices, and operator stations; and download from or upload to operator workstation.
  - 2. Stand-alone mode control functions operate regardless of network status. Functions include the following:

- a. Global communications.
  - b. Discrete/digital, analog, and pulse I/O.
  - c. Monitoring, controlling, or addressing data points.
  - d. Software applications, scheduling, and alarm processing.
  - e. Testing and developing control algorithms without disrupting field hardware and controlled environment.
- C. Local Control Units: Modular, comprising processor board with electronically programmable, nonvolatile, read-only memory; and backup power source.
  - 1. Units monitor or control each I/O point, process information, and download from or upload to operator workstation or diagnostic terminal unit.
  - 2. Stand-alone mode control functions operate regardless of network status. Functions include the following:
    - a. Global communications.
    - b. Discrete/digital, analog, and pulse I/O.
    - c. Monitoring, controlling, or addressing data points.
  - 3. Local operator interface provides for download from or upload to operator workstation.
- D. Power Supplies: Transformers with Class 2 current-limiting type or overcurrent protection; limit connected loads to 80 percent of rated capacity. DC power supply shall match output current and voltage requirements and be full-wave rectifier type with the following:
  - 1. Output ripple of 5.0 mV maximum peak to peak.
  - 2. Combined 1 percent line and load regulation with 100-mic.sec. response time for 50 percent load changes.
  - 3. Built-in overvoltage and overcurrent protection and be able to withstand 150 percent overload for at least 3 seconds without failure.

## 2.4 ELECTRONIC SENSORS

- A. Electronic and fiber-optic cables for control wiring are specified in Division 27 Section "Communications Horizontal Cabling."

## PART 3 - EXECUTION

### 3.1 INSTALLATION

- A. Verify location of thermostats, humidistats, and other exposed control sensors with Drawings and room details before installation. Install devices 60 inches above the floor.
  - 1. Install averaging elements in ducts and plenums in crossing or zigzag pattern.
- B. Install guards on thermostats in the following locations:
  - 1. Entrances.
  - 2. Public areas.
  - 3. Where indicated.
- C. Install automatic dampers according to Division 23 Section "Air Duct Accessories."

- D. Install damper motors on outside of duct in warm areas, not in locations exposed to outdoor temperatures.
- E. Install labels and nameplates to identify control components according to Division 23 Section "Identification for HVAC Piping and Equipment."
- F. Install hydronic instrument wells, valves, and other accessories according to Division 23 Section "Hydronic Piping."
- G. Install refrigerant instrument wells, valves, and other accessories according to Division 23 Section "Refrigerant Piping."
- H. Install duct volume-control dampers according to Division 23 Sections specifying air ducts.
- I. Install electronic and fiber-optic cables according to Division 27 Section "Communications Horizontal Cabling."

### 3.2 ELECTRICAL WIRING AND CONNECTION INSTALLATION

- A. Install raceways, boxes, and cabinets according to Division 26 Section "Raceway and Boxes for Electrical Systems."
- B. Install building wire and cable according to Division 26 Section "Low-Voltage Electrical Power Conductors and Cables."
- C. Install signal and communication cable according to Division 27 Section "Communications Horizontal Cabling."
  - 1. Conceal cable, except in mechanical rooms and areas where other conduit and piping are exposed.
  - 2. Install exposed cable in raceway.
  - 3. Install concealed cable in raceway.
  - 4. Bundle and harness multiconductor instrument cable in place of single cables where several cables follow a common path.
  - 5. Fasten flexible conductors, bridging cabinets and doors, along hinge side; protect against abrasion. Tie and support conductors.
  - 6. Number-code or color-code conductors for future identification and service of control system, except local individual room control cables.
  - 7. Install wire and cable with sufficient slack and flexible connections to allow for vibration of piping and equipment.
- D. Connect manual-reset limit controls independent of manual-control switch positions. Automatic duct heater resets may be connected in interlock circuit of power controllers.
- E. Connect hand-off-auto selector switches to override automatic interlock controls when switch is in hand position.

### 3.3 FIELD QUALITY CONTROL

- A. Manufacturer's Field Service: Engage a factory-authorized service representative to inspect, test, and adjust field-assembled components and equipment installation, including connections, and to assist in field testing. Report results in writing.
- B. Perform the following field tests and inspections and prepare test reports:

1. Operational Test: After electrical circuitry has been energized, start units to confirm proper unit operation. Remove and replace malfunctioning units and retest.
2. Test and adjust controls and safeties.
3. Test calibration of controllers by disconnecting input sensors and stimulating operation with compatible signal generator.
4. Test each point through its full operating range to verify that safety and operating control set points are as required.
5. Test each control loop to verify stable mode of operation and compliance with sequence of operation. Adjust PID actions.
6. Test each system for compliance with sequence of operation.
7. Test software and hardware interlocks.

C. DDC Verification:

1. Verify that instruments are installed before calibration, testing, and loop or leak checks.
2. Check instruments for proper location and accessibility.
3. Check instrument installation for direction of flow, elevation, orientation, insertion depth, and other applicable considerations.
4. Check instrument tubing for proper fittings, slope, material, and support.
5. Check pressure instruments, piping slope, installation of valve manifold, and self-contained pressure regulators.
6. Check temperature instruments and material and length of sensing elements.
7. Check control valves. Verify that they are in correct direction.
8. Check air-operated dampers. Verify that pressure gages are provided and that proper blade alignment, either parallel or opposed, has been provided.
9. Check DDC system as follows:
  - a. Verify that DDC controller power supply is from emergency power supply, if applicable.
  - b. Verify that wires at control panels are tagged with their service designation and approved tagging system.
  - c. Verify that spare I/O capacity has been provided.
  - d. Verify that DDC controllers are protected from power supply surges.

D. Replace damaged or malfunctioning controls and equipment and repeat testing procedures.

### 3.4 DEMONSTRATION

- A. Engage a factory-authorized service representative to train Owner's maintenance personnel to adjust, operate, and maintain HVAC instrumentation and controls. Refer to Division 01 Section "Demonstration and Training."

END OF SECTION 230900