

Clark & Enersen | 2020 Baltimore Avenue Suite 300 Kansas City MO 64108-1914 United States

PROJECT: UAMS Biomed Bldg Viv Reno 769-017-22 DATE SENT: 11/3/2025

SUBJECT: 230548-01 Seismic and Vibration Isolation Controls Submittal ID: 230548-01

TYPE: Submittal TRANSMITTAL ID: 00582

PURPOSE: Approved as Noted VIA: Email

SPEC SECTION: 23 05 48

FROM

NAME	COMPANY	EMAIL	PHONE
Lance Nozik	Clark & Enersen	Lance.Nozik@clarkenersen.com	816.474.8237

TO

NAME	COMPANY	EMAIL	PHONE
Tamara Barron	UAMS	TBarron@uams.edu	

REMARKS:

CONTENTS

QUANTITY: 1 DATED: 11/3/2025 NUMBER:

DESCRIPTION:
230548-01 Seismic and Vibration Isolation Controls RN.pdf

ACTION:
REMARKS:



CDI CONTRACTORS CDI Contractors, LLC
 3000 Cantrell Road
 Little Rock AR 72202

Transmittal
No 2025.11.03-001

PROJECT: UAMS- CAMID

DATE: Nov 03, 2025

To: UAMS
 4301 W MARKHAM ST. SLOT 545
 LITTLE ROCK AR 72205
 US

RE: 230548 Seismic and Vibration Isolation Controls

ATTN: TAMARA BARRON

JOB: 240147

WE ARE SENDING:		SUBMITTED FOR:		ACTION TAKEN:	
<input type="checkbox"/>	Shop Drawings	<input checked="" type="checkbox"/>	Approval	<input type="checkbox"/>	Approved as Submitted
<input type="checkbox"/>	Letter	<input type="checkbox"/>	Your Use	<input type="checkbox"/>	Approved as Noted
<input type="checkbox"/>	Prints	<input type="checkbox"/>	As Requested	<input type="checkbox"/>	Returned After Loan
<input type="checkbox"/>	Change Order	<input type="checkbox"/>	Review and Comment	<input type="checkbox"/>	Resubmit
<input type="checkbox"/>	Plans	<input type="checkbox"/>		<input type="checkbox"/>	Submit
<input type="checkbox"/>	Samples	SENT VIA:		<input type="checkbox"/>	Returned
<input type="checkbox"/>	Specifications	<input type="checkbox"/>	Attached	<input type="checkbox"/>	Separate Cover
<input type="checkbox"/>	Other:	<input type="checkbox"/>		<input checked="" type="checkbox"/>	Due Nov 10, 2025
<input checked="" type="checkbox"/>	Submittal:	<input type="checkbox"/>		<input type="checkbox"/>	Other:

Line	Item	Package	Code	Rev.	QTY	Date	Description	Status
1	Submittal		230548-01	1		Nov 03, 2025	PD:Descriptive Data of Seismic and Vibration Controls	Submitted

REMARKS:

CC:

Signed:

FRANCISCA GUTIERREZ



CDI CONTRACTORS, LLC

APPROVED AS NOTED REJECTED
 APPROVED REVISE

BY gutierf **DATE** 11/3/2025
SUBMITTAL# 230548-01 **SPEC** 230548

This submittal has been reviewed for compliance with the contract documents. Approval does not relieve the subcontractor/supplier of the responsibility for conformance to the quality standards as set forth in the contract document, nor does it relieve the responsibility for field verification of all conditions relating to this contract.

REVIEWED REVIEWED AND NOTED
 REVISE AND RESUBMIT REJECTED

Corrections or comments made on the shop drawings during this review do not relieve contractor from compliance with requirements of the drawings and specifications. This check is only for review of general conformance with design concept of the project and general compliance with the information given in the contract documents. The contractor is responsible for confirming and correlating all quantities and dimensions; selecting fabrication process and techniques of construction; coordinating their work with that of all other trades; and performing their work in a safe and satisfactory manner.

CLARK & ENERSEN

By James Beecher Date 11/03/2025



PRELIMINARY SUBMITTAL DATA

DATE: October 30, 2025
PROJECT: UAMS CAMID
ENGINEER: Clarks Enersen

MASON INDUSTRIES SEISMIC RESTRAINTS

This is a preliminary submittal showing the type of restraints we will provide. They could differ when final drawings are done depending on the equipment's submittal weights and footprints. Fluid Solutions will provide detailed shop drawings and calculations for the equipment as listed below. The shop drawings will be prepared in detail and along with calculations after approval of the equipment submittals.

Systems related to the BSL-3

Electrical

- Panelboards
 - LL1, LE5

Plumbing Systems – Nothing

Mechanical Systems

- Ductwork – SCB/SCBH Cable Bracing
- HFH-1
 - SAST/HG Bolt Down
- HRU-5
 - SAST/HG Bolt down
- AH-5A/5B
 - SAST/HG
- EXH-6/7 - CALC, attachment to steel

Understood. Contractor to engage a specialty seismic restraint engineer to produce sealed calculations and drawings showing restraint types, locations and anchorage details.

EQUIPMENT RESTRAINTS

10350 Riverview Corporate Dr., Maumelle, AR 72113


Phone (501) 663-8886 • Fax (501) 663-8738

www.fluidsolutionsinc.com

FLOOR MOUNTED EQUIPMENT

RIGIDLY MOUNTED NON-ISOLATED EQUIPMENT


Rigidly mounted or non-isolated equipment must be bolted in position. Bolts should be selected in accordance with the anchor bolt section. For most equipment, stud type wedge anchors can be installed with equipment in place, because the drilling hole of stud anchors matches the stud's diameter. Where this is not possible due to lack of clearance, female wedge anchor bolts should be used, as the equipment can be slid into place and not lifted over the bolts. Most equipment is supplied with holes for bolting. Equipment that does not have holes may be drilled or have angles bolted or welded to them when drilling is not practical. In areas within high seismic zones, the bolt hole locations and sizes may not be adequate. In these cases, additional holes must be drilled or other attachments provided.



RIGIDLY MOUNTED TANK

Anchor subject to vibrating loads should be installed with our HG Neoprene bushing that surrounds the bolt shaft and head and protects the anchor from vibration.

RIGIDLY MOUNTED PUMPS



MASON INDUSTRIES, INC.

NY Mailing Address— P.O. Box 410 • Smithtown, NY 11787
 350 Rabro Drive • Hauppauge, NY 11788 • 631/348-0282 • FAX 631/348-0279
 2101 W. Crescent Ave., Suite D • Anaheim, CA 92801 • 714/535-2727 • FAX 714/535-5738
 Email Addresses— Info@Mason-Ind.com • Info@MasonAnaheim.com

Page

FM13



MASON INDUSTRIES, Inc.
Manufacturers of Vibration Control Products

350 Rabro Drive 2101 W. Crescent Ave., Suite D
Hauppauge, NY 11788 Anaheim, CA 92801
631/348-0282 714/535-2727
FAX 631/348-0279 FAX 714/535-5738
Info@Mason-Ind.com Info@MasonAnaheim.com

CERTIFIED FOR

JOB NAME :
CUSTOMER :
CUSTOMER P.O. :
MASON M.I. :
DWG. NO. :



TYPE

SAB

Certified Seismic
Anchor Bolt
with Washer

**ALL PARTS
ELECTROPLATED**

"CS" CAP SCREW
WITH STANDARD
WASHER



TYPE SAB ANCHOR BOLT RATINGS installed into 3000 psi (20 Mpa) concrete

Size	Minimum Anchor Embedment (in) (mm)	Minimum Edge Distance (in) (mm)	Minimum Anchor Spacing (in) (mm)	Concrete Type			
				Stone Aggregate		Lightweight	
				Tension* (lbs)(kg) [†]	Shear (lbs)(kg) [†]	Tension* (lbs)(kg) [†]	Shear (lbs)(kg) [†]
SAB-3/8	2 5/8 67	5 1/4 133	7 7/8 200	720 327	1050 476	575 261	840 382
SAB-1/2	3 1/2 89	7 178	10 1/2 267	1010 458	1830 830	800 363	1500 680
SAB-5/8	4 3/8 111	8 3/4 222	13 1/8 333	2220 1007	2970 1347	1625 737	2720 1234
SAB-3/4	5 1/4 133	10 1/2 267	15 3/4 400	2330 1057	3340 1515	— —	— —
SAB-1	5 3/4 146	11 1/2 292	17 1/4 438	3660 1524	6610 2998	— —	— —

*These tension values are applicable when the anchors are installed without special inspection as set forth in Section 1701.1 of UBC. When anchors are installed with special inspection as set forth in Section 1701.1 of the UBC, the tabulated values may be increased by 100%.

[†]For kN divide kg by 102

Notes:

The tabulated values are for anchors installed at the specified spacings and edge distance. Spacings may be reduced by 67% provided the tension values are reduced to 50% (65% for SAB-1) and the shear values are reduced by 60%. Edge distances may be reduced by 50% provided the tension values are reduced by 30% and the shear values are reduced by 50%. Linear interpolation may be used for intermediate spacings.

For combined tension and shear forces on anchors, use the following equations:
 $(P_s/P_t)^{5/3} + (V_s/V_t)^{5/3} \leq 1.0$, where: P_s and V_s are Applied Forces
and P_t and V_t are Allowable Forces

Ratings may be increased 33 1/3 % to accommodate periodic forces such as wind or seismic loads. Tabulated values include a safety factor of 8 to 1 for tension forces and 4 to 1 for shear forces.

For Stone Aggregate Concrete, refer to ICBO Report #ER-5063.
For Lightweight Concrete, refer to Techmar report #TR-1193.

TYPE SAB ANCHOR BOLT DIMENSIONS

Size	A		B		CS	
	(in)	(mm)	(in)	(mm)	(in)	(mm)
SAB-3/8	2 5/16	67	1/2	13	3/8"-16 UNC x 1 1/4	3/8"-16 UNC x 32
SAB-1/2	3 1/16	89	5/8	16	1/2"-13 UNC x 1 1/2	1/2"-13 UNC x 38
SAB-5/8	3 13/16	111	7/8	22	5/8"-11 UNC x 1 3/4	5/8"-11 UNC x 44
SAB-3/4	4 5/8	133	1	25	3/4"-10 UNC x 2 1/4	3/4"-10 UNC x 57
SAB-1	5	146	1 1/4	32	1"- 8 UNC x 2 1/2	1"- 8 UNC x 64

CERTIFICATION DATA

DWN : _____ CHKD : _____ DATE : _____

FORM S-105-2

DWG NO. : _____

11/99

Chapter 10

SUSPENDED EQUIPMENT

The basic design requirements for bracing of suspended equipment are as follows:

1. Sway braces should be arranged so that they limit motion of the equipment in all directions.
2. Threaded rods should be designed to resist vertical seismic loads and support equipment.
3. Equipment supported by vibration-isolation hangers should be detailed and installed with isolation hangers close to the structure and upward limit stops located directly below the hangers.
4. Avoid bracing equipment to separate portions of the structure that may act differently in response to an earthquake. For example, do not connect a transverse brace to a wall and a longitudinal brace to a floor or roof at the same brace location.

HANGER ROD REQUIREMENTS

The effects of sway bracing on the hanger rod are discussed in more detail in Chapter 7. Following is a discussion of how loads are applied to hanger rods for suspended equipment.




Figure 10-1 Typical solid brace arrangement.

SWAY BRACING

Sway bracing of suspended equipment differs from piping, ductwork, or other suspended systems. Equipment is braced independently of surrounding systems, such as ductwork and piping, and requires restraint in all horizontal and vertical directions.

There are two types of sway braces, solid and cable, each with advantages and disadvantages as discussed in Chapter 7.

Figures 10-1 and 10-2 show typical solid and cable brace arrangements for suspended equipment. In the extreme case the unit is square in plan, it is possible the unit may rotate and therefore an eight-cable arrangement is recommended, as shown in Figure 10-3.




Figure 10-2 Typical cable brace arrangement.



MASON INDUSTRIES, Inc.

Manufacturers of Vibration Control Products
 NY Mailing Address: PO Box 410, Smithtown, NY 11787
 350 Rabro Drive 2101 W. Crescent Ave., Suite D
 Hauppauge, NY 11788 Anaheim, CA 92801
 631/348-0282 714/535-2727
 FAX 631/348-0279 FAX 714/535-5738
 Info@Mason-Ind.com Info@MasonAnaheim.com

CERTIFIED FOR


JOB NAME :
 CUSTOMER :
 CUSTOMER P.O. :
 MASON M.I. :
 DWG NO. :

TYPE

SCB

Seismic Cable
 Brace Anchor
 & Assembly

SCB-1,2,3 & 4



SCB-3-2B

TYPE SCB ASSEMBLY RATING AS CONTROLLED BY CABLE BREAK STRENGTH

Size	Cable Diameter (in)	Cable Diameter (mm)	OSHPD Max Ratings	
			(lbs)	(kg)
SCB-1	1/8	3	975	442
SCB-2	3/16	5	2050	930
SCB-3 & -3-2B	1/4	6	3150	1429
SCB-4	3/8	10	6875	3119

Ratings are from test data and calculations used to obtain California OSHPD Preapproval Number R-0349.

Testing was supervised and certified by an independant engineer registered in the state of california.

Ratings are based on attachment to steel.

Preferred installation angle is 45° Maximum variation ±15°.

NOTE: Not to be used as a vertical hanger for equipment, duck work or piping. To be used as a seismic restraint only.

TYPE SCB ANCHOR DIMENSIONS (inches)

Size	A	B	C	D	E	F	G	H
SCB-1	1 3/8	2	1	15/16	3 3/8	1 1/2	9/16	1/2
SCB-2	1 5/8	2 3/4	1 3/8	1 3/16	4 3/8	1 3/4	1 1/16	5/8
SCB-3	2	3 1/2	1 3/4	1 7/16	4 3/4	2	1 3/16	3/4
SCB-3-2B	2	4 3/4	1	1 7/16	4 3/4	2	1 3/16	3/4
SCB-4	3 1/8	5	2 1/2	1 15/16	5 3/4	2 1/4	1 5/16	1

TYPE SCB ANCHOR DIMENSIONS (mm)

Size	A	B	C	D	E	F	G	H
SCB-1	35	51	25	24	86	38	14	13
SCB-2	41	70	35	30	111	44	17	16
SCB-3	51	89	44	37	121	51	21	19
SCB-3-2B	51	121	25	37	121	51	21	19
SCB-4	79	127	64	49	146	57	33	25

TORQUE VALUES

Diameter	Torque Foot Pounds		Torque Kilogram-Meters	
	Minumum	Maximum	Minimum	Maximum
1/2"	25	29	3.5	4.1
5/8"	45	52	6.3	7.3
3/4"	55	64	7.7	9.0

APPROVED

California Office of Statewide
 Health Planning and Development

FIXED EQUIPMENT ANCHORAGE

OPA-0349 August 5, 2002

*Valid for 3 Years Maximum



Bill Staehlin
 Bill Staehlin (916) 654-3362

CERTIFICATION DATA

TAG: _____

UNIT: _____

DWN : _____ CHKD: _____ DATE : _____

DWG NO. : _____



MASON INDUSTRIES, Inc.

Manufacturers of Vibration Control Products
 NY Mailing Address: PO Box 410, Smithtown, NY 11787
 350 Rabro Drive 2101 W. Crescent Ave., Suite D
 Hauppauge, NY 11788 Anaheim, CA 92801
 631/348-0282 714/535-2727
 FAX 631/348-0279 FAX 714/535-5738
 Info@Mason-Ind.com Info@MasonAnaheim.com

CERTIFIED FOR

JOB NAME : _____
 CUSTOMER : _____
 CUSTOMER P.O. : _____
 MASON M.I. : _____
 DWG. NO. : _____

TYPE
SCBH
 SEISMIC CABLE
 BRACE HOOK
 ANCHOR &
 ASSEMBLY

TYPE SCBH ANCHOR DIMENSIONS (inches mm)


Size	For use with Rod Sizes	A	B	C	D	E	F	G	H
SCBH-0	3/8	1 3/8	2 1/16	1 1/16	15/16	1 3/4	--	3/8	1/2
SCBH-1	1/2, 5/8	1 7/8	2 3/8	1	1	3 3/8	1 1/2	5/8	1/2
SCBH-2	3/4, 7/8	2 7/8	3 3/4	1 3/8	1 3/8	4 3/8	1 3/4	7/8	5/8
SCBH-3	1, 1 1/8	3 1/2	4 3/4	1 3/4	1 3/4	4 3/4	2	1 1/8	3/4

TORQUE VALUES

Diameter	Torque Foot Pounds		Torque Kilogram-Meters	
	Minimum	Maximum	Minimum	Maximum
1/2"	25	29	3.5	4.1
5/8"	45	52	6.3	7.3
3/4"	55	64	7.7	9.0

RATINGS AS CONTROLLED BY CABLE BREAK STRENGTH

Size	Cable Dia. (in)	OSHPD Max. Ratings (lbs) (kgs)
SCBH-0	1/16 (1.5)	240 (110)
SCBH-1	1/8 (3.0)	975 (442)
SCBH-2	3/16 (5.0)	2050 (930)
SCBH-3	1/4 (6.0)	3150 (1429)



Ratings for SCBH-1 thru -3 are from test data and calculations used to obtain California OSHPD Preapproval Number OPA-0349. Testing was supervised and certified by an independent engineer registered in the state of California. Ratings are based on attachment to steel. SCBH assemblies will fit rod sizes as tabulated. Preferred installation angle is 45 degrees. Maximum variation is ± 15 degrees

APPROVED

California Office of Statewide Health Planning and Development

FIXED EQUIPMENT ANCHORAGE

OPA-0349 AUGUST 5, 2002



*Valid for 3 Years Maximum

Bill Staehlin (916) 654-3362

CERTIFICATION DATA

TAG : _____

UNIT _____

DWN : _____ CHKD: _____ DATE : _____

DWG NO. : _____


DUCTWORK RESTRAINTS

10350 Riverview Corporate Dr., Maumelle, AR 72113

Phone (501) 663-8886 • Fax (501) 663-8738

www.fluidsolutionsinc.com

TRANSVERSE SEISMIC CABLE BRACE HOOK GUIDELINES FOR RECTANGULAR/OVAL DUCT



NOTE 1: A ROD STIFFENER ANGLE MAY BE REQUIRED AS SHOWN. FOR ADDITIONAL INFORMATION, REF. PAGE E1 OR E2. BRACE ANGLE RATIO MAY BE INCREASED TO 2(VERT.): 1(HORIZ.). REFER TO SECTION D FOR LIMITATIONS. REFER TO PAGE X2 FOR PROPER INSTALLATION OF SCBHS.

NOTE 2: FOR TIGHTENING REQUIREMENTS OF BOLTS, NUTS AND STRUT NUTS REFERENCE H15.



MASON INDUSTRIES, Inc.

Manufacturers of Vibration Control Products

NY Mailing Address: PO Box 410, Smithtown, NY 11787

350 Rabro Drive 2101 W. Crescent Ave., Suite D
Hauppauge, NY 11788 Anaheim, CA 92801
631/348-0282 714/535-2727
FAX 631/348-0279 FAX 714/535-5738
Info@Mason-Ind.com Info@MasonAnaheim.com

A P P R O V E D
California Office of Statewide
Health Planning and Development
FIXED EQUIPMENT ANCHORAGE
OPA-0349 August 5, 2002



Bill Staehlin
Bill Staehlin (916) 654-3362


Page

F14

Dhiru Mali

Dhiru Mali
Structural Engineer
California SE No. 2811

LONGITUDINAL SEISMIC CABLE BRACE HOOK GUIDELINES FOR RECTANGULAR/OVAL DUCT



NOTE 1: A ROD STIFFENER ANGLE MAY BE REQUIRED AS SHOWN. FOR ADDITIONAL INFORMATION, REF. PAGE E1 OR E2.
BRACE ANGLE RATIO MAY BE INCREASED TO 2(VERT.): 1(HORIZ.). REFER TO SECTION D FOR LIMITATIONS. REFER TO PAGE
X2 FOR PROPER INSTALLATION OF SCBHS.

NOTE 2: FOR TIGHTENING REQUIREMENTS OF BOLTS, NUTS AND STRUT NUTS REFERENCE H15.

A P P R O V E D
California Office of Statewide
Health Planning and Development
FIXED EQUIPMENT ANCHORAGE
OPA-0349 August 5, 2002



Bill Staehlin
Bill Staehlin (916) 654-3362



MASON INDUSTRIES, Inc.
Manufacturers of Vibration Control Products

NY Mailing Address: PO Box 410, Smithtown, NY 11787

350 Rabro Drive 2101 W. Crescent Ave., Suite D
Hauppauge, NY 11788 Anaheim, CA 92801
631/348-0282 714/535-2727
FAX 631/348-0279 FAX 714/535-5738
Info@Mason-Ind.com Info@MasonAnaheim.com

Dhiru Mali

Dhiru Mali
Structural Engineer
California SE No. 2811

Page

F15



MASON INDUSTRIES, Inc.

Manufacturers of Vibration Control Products
 NY Mailing Address: PO Box 410, Smithtown, NY 11787
 350 Rabro Drive 2101 W. Crescent Ave., Suite D
 Hauppauge, NY 11788 Anaheim, CA 92801
 631/348-0282 714/535-2727
 FAX 631/348-0279 FAX 714/535-5738
 Info@Mason-Ind.com Info@MasonAnaheim.com

CERTIFIED FOR


JOB NAME :
 CUSTOMER :
 CUSTOMER P.O. :
 MASON M.I. :
 DWG NO. :

TYPE

SCB

Seismic Cable
 Brace Anchor
 & Assembly

SCB-1,2,3 & 4



SCB-3-2B

APPROVED

California Office of Statewide
 Health Planning and Development

FIXED EQUIPMENT ANCHORAGE

OPA-0349 August 5, 2002

*Valid for 3 Years Maximum



Bill Staehlin (916) 654-3362

TYPE SCB ASSEMBLY RATING AS CONTROLLED BY CABLE BREAK STRENGTH

Size	Cable Diameter		OSHPD Max Ratings	
	(in)	(mm)	(lbs)	(kg)
SCB-1	1/8	3	975	442
SCB-2	3/16	5	2050	930
SCB-3 & -3-2B	1/4	6	3150	1429
SCB-4	3/8	10	6875	3119

Ratings are from test data and calculations used to obtain California OSHPD Preapproval Number R-0349.

Testing was supervised and certified by an independent engineer registered in the state of California.

Ratings are based on attachment to steel.

Preferred installation angle is 45° Maximum variation ±15°.

NOTE: Not to be used as a vertical hanger for equipment, duck work or piping. To be used as a seismic restraint only.

TYPE SCB ANCHOR DIMENSIONS (inches)

Size	A	B	C	D	E	F	G	H
SCB-1	1 3/8	2	1	15/16	3 3/8	1 1/2	9/16	1/2
SCB-2	1 5/8	2 3/4	1 3/8	1 3/16	4 3/8	1 3/4	1 1/16	5/8
SCB-3	2	3 1/2	1 3/4	1 7/16	4 3/4	2	1 3/16	3/4
SCB-3-2B	2	4 3/4	1	1 7/16	4 3/4	2	1 3/16	3/4
SCB-4	3 1/8	5	2 1/2	1 15/16	5 3/4	2 1/4	1 5/16	1

TYPE SCB ANCHOR DIMENSIONS (mm)

Size	A	B	C	D	E	F	G	H
SCB-1	35	51	25	24	86	38	14	13
SCB-2	41	70	35	30	111	44	17	16
SCB-3	51	89	44	37	121	51	21	19
SCB-3-2B	51	121	25	37	121	51	21	19
SCB-4	79	127	64	49	146	57	33	25

TORQUE VALUES

Diameter	Torque Foot Pounds		Torque Kilogram-Meters	
	Minimum	Maximum	Minimum	Maximum
1/2"	25	29	3.5	4.1
5/8"	45	52	6.3	7.3
3/4"	55	64	7.7	9.0

CERTIFICATION DATA

TAG: _____
 UNIT: _____

DWN : _____ CHKD: _____ DATE : _____

DWG NO. : _____




MASON INDUSTRIES, Inc.

Manufacturers of Vibration Control Products
 NY Mailing Address: PO Box 410, Smithtown, NY 11787
 350 Rabro Drive 2101 W. Crescent Ave., Suite D
 Hauppauge, NY 11788 Anaheim, CA 92801
 631/348-0282 714/535-2727
 FAX 631/348-0279 FAX 714/535-5738
 Info@Mason-Ind.com Info@MasonAnaheim.com

CERTIFIED FOR
JOB NAME : _____
CUSTOMER : _____
CUSTOMER P.O. : _____
MASON M.I. : _____
DWG. NO. : _____

TYPE
SCBH
 SEISMIC CABLE
 BRACE HOOK
 ANCHOR &
 ASSEMBLY



TYPE SCBH ANCHOR DIMENSIONS (inches mm)


Size	For use with Rod Sizes									
	A	B	C	D	E	F	G	H		
SCBH-0	3/8	1 3/8	2 1/16	1 1/16	15/16	1 3/4	--	3/8	1/2	
SCBH-1	1/2, 5/8	1 7/8	2 3/8	1	1	3 3/8	1 1/2	5/8	1/2	
SCBH-2	3/4, 7/8	2 7/8	3 3/4	1 3/8	1 3/8	4 3/8	1 3/4	7/8	5/8	
SCBH-3	1, 1 1/8	3 1/2	4 3/4	1 3/4	1 3/4	4 3/4	2	1 1/8	3/4	

TORQUE VALUES

Diameter	Torque Foot Pounds		Torque Kilogram-Meters	
	Minimum	Maximum	Minimum	Maximum
1/2"	25	29	3.5	4.1
5/8"	45	52	6.3	7.3
3/4"	55	64	7.7	9.0

RATINGS AS CONTROLLED BY CABLE BREAK STRENGTH

Size	Cable Dia. (in)	Cable Dia. (mm)	OSHPD Max. Ratings (lbs) (kgs)
SCBH-0	1/16	(1.5)	240 (110)
SCBH-1	1/8	(3.0)	975 (442)
SCBH-2	3/16	(5.0)	2050 (930)
SCBH-3	1/4	(6.0)	3150 (1429)

APPROVED
 California Office of Statewide Health Planning and Development
FIXED EQUIPMENT ANCHORAGE
OPA-0349 AUGUST 5, 2002
 *Valid for 3 Years Maximum

 Bill Staehlin (916) 654-3362

Ratings for SCBH-1 thru -3 are from test data and calculations used to obtain California OSHPD Preapproval Number OPA-0349. Testing was supervised and certified by an independent engineer registered in the state of California. Ratings are based on attachment to steel. SCBH assemblies will fit rod sizes as tabulated. Preferred installation angle is 45 degrees. Maximum variation is ± 15 degrees

CERTIFICATION DATA

TAG : _____
UNIT _____

DWN : _____ **CHKD:** _____ **DATE :** _____

DWG NO. : _____