

SECTION 32 17 23
PAVEMENT MARKINGS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Painted pavement markings.

1.02 RELATED REQUIREMENTS

- A. Section 32 12 16 - Asphalt Paving.
- B. Section 32 13 13 - Concrete Paving.

1.03 REFERENCE STANDARDS

- A. AASHTO M 247 - Standard Specification for Glass Beads Used in Pavement Markings; 2013 (Reapproved 2018).
- B. AASHTO M 249 - Standard Specification for White and Yellow Reflective Thermoplastic Striping Material (Solid Form); 2012 (Reapproved 2020).
- C. AASHTO MP 24 - Standard Specification for Waterborne White and Yellow Traffic Paints; 2015 (Reapproved 2020).
- D. FHWA MUTCD - Manual on Uniform Traffic Control Devices for Streets and Highways; U.S. Department of Transportation, Federal Highway Administration; Current Edition.

1.04 SUBMITTALS

- A. See Section 01 30 00 - Administrative Requirements for submittal procedures.
- B. Product Data: Manufacturer's data sheets on each product to be used.

1.05 DELIVERY, STORAGE, AND HANDLING

- A. Deliver paint in containers of at least 5 gallons accompanied by batch certificate.
- B. Store products in manufacturer's unopened packaging until ready for installation.
- C. Store and dispose of solvent-based materials, and materials used with solvent-based materials, in accordance with requirements of local authorities having jurisdiction.

1.06 FIELD CONDITIONS

- A. Do not install products under environmental conditions outside manufacturer's absolute limits.
- B. Do not apply paint if temperature of surface to be painted or the atmosphere is less than 50 degrees F or more than 95 degrees F.

1.07 SEQUENCING

- A. Allow new pavement surfaces to cure for a period of not less than 14 days before application of markings or a period recommended by manufacturer.

PART 2 PRODUCTS

2.01 PAINTED PAVEMENT MARKINGS

- A. Comply with State of Arkansas Highway Department standards.
- B. Comply with FHWA MUTCD.
- C. Painted Pavement Markings: As indicated on drawings.
 - 1. Marking Paint: In accordance with AASHTO MP 24.
 - a. Parking Lots: White.
 - b. Symbols and Text: White.
 - c. Wheelchair Symbols: Provide blue and white.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verification of Conditions: Verify that pavement is dry and ready for installation.
- B. Notify Architect Engineer of unsatisfactory conditions before proceeding.

3.02 PREPARATION

- A. Clean surfaces prior to installation.
 - 1. Remove dust, dirt, and other debris.
- B. Apply paint stencils by type and color at necessary intervals.

3.03 INSTALLATION

- A. General:
 - 1. Position pavement markings as indicated on drawings.
 - 2. Field location adjustments require approval of Architect Engineer.
- B. Painted Pavement Markings:
 - 1. Apply in accordance with manufacturer's instructions.
 - 2. Apply in accordance with State of Arkansas Highway Department standards.
 - 3. Apply in accordance with FHWA MUTCD standards.
 - 4. Marking Paint: Apply uniformly, with sharp edges.
 - a. Applications: One coat.
 - b. Wet Film Thickness: 0.015 inch, minimum.
 - c. Stencils: Lay flat against pavement, align with striping, remove after application.
 - d. Glass Beads: Apply directly to paint, 10 second lag time, 6 lbs/gal of paint, uniform thickness and coverage.
 - e. Length Tolerance: Plus or minus 3 inches.
 - f. Width Tolerance: Plus or minus 1/8 inch.

3.04 PROTECTION

- A. Prevent approaching traffic from crossing newly applied pavement markings.
- B. Replace damaged or removed markings at no additional cost to Owner.

END OF SECTION